

Power System Toolbox 4

–User Manual–

Documentation Version 0.0.0-a.5

by

Thad Haines

Last Update: September 9, 2020

Introduction - WIP

This paragraph should contain a bit of history about how Power System Toolbox (PST) has developed into its current form- Possibly written/drafted by Trudnowski... Mention of renewed interest in PST via SETO/Sandia and the new MIT license may be appropriate.

The purpose of this user manual is to document work done on PST 3 to form PST 4. It is meant only to augment the previous user manual provided with PST 3 [1]. Major code changes presented include how global variables are handled and the functionalization of the non-linear simulation routine. Descriptions of new models created for inverter based resources and automatic generation control are also presented. Additionally, work to add functionality to PST such as variable time step integration routines, generator tripping, and code compatibility with Octave is documented. To demonstrate and debug new and old PST capabilities, an example library has been created and brief explanations of examples are intended to be included. Unfortunately, due to time constraints, details may be rather lacking and intentions may only matter so much.

Finally, it is worth noting that all source code, examples, and other research documentation can be accessed at <https://github.com/thadhaines/MT-Tech-SETO/tree/master/PST>.

Acknowledgments - WIP

- Original Creators (graham and joe)
- Known contributors (trudnowski, ...)
- funding that made this work possible.

Table of Contents

Acknowledgments	iii
Table of Contents	iv
List of Tables	vii
List of Figures	viii
List of Equations	ix
Glossary of Terms	x
1 PST Version History - WIP	1
2 Code Fixes	2
2.1 exc_dc12	2
2.2 exc_st3	2
2.3 lmod	2
2.4 mac_tra	2
2.5 rlmod	2
3 Changes and Additions	3
3.1 Area Definitions - WIP	3
3.2 Automatic Generation Control	5
3.2.1 AGC Block Diagrams	5
3.2.2 Weighted Average Frequency (calcAveF)	7
3.2.3 Other Area Calculations (calcAreaVals)	8
3.3 Global Variable Management - WIP	9
3.3.1 agc - WIP	9
3.3.2 area - WIP	9
3.3.3 bus - WIP	10
3.3.4 dc	10
3.3.5 exc	11
3.3.6 igen	12
3.3.7 ind	12
3.3.8 ivm - WIP	13
3.3.9 k	13

3.3.10	line	13
3.3.11	lmod	13
3.3.12	lmon - WIP	14
3.3.13	mac	14
3.3.14	ncl	14
3.3.15	pss	15
3.3.16	pwr	15
3.3.17	rlmod	15
3.3.18	svc	16
3.3.19	sys	16
3.3.20	tcsc	16
3.3.21	tg	17
3.3.22	vtc	17
3.3.23	y - WIP	18
3.4	handleNewGlobals Function	18
3.5	Internal Voltage Model (ivmmod) - WIP	19
3.6	Line Monitoring Functionality (lmon) - WIP	20
3.7	Live Plotting Functionality (liveplot) - WIP	21
3.8	Machine Trip Logic (mac_trip_logic) - WIP	21
3.9	Octave Compatibility	22
3.10	Power Injection Model (pwrmod) - WIP	22
3.11	Power System Stabilizer Model	22
3.12	Reset Original Files Function (resetORIG)	23
3.13	s_simu Changes	24
3.13.1	Functionalization	24
3.13.1.1	cleanZeros	24
3.13.1.2	correctorIntegration	24
3.13.1.3	dcSolution	25
3.13.1.4	dynamicSolution	25
3.13.1.5	initNLsim	26
3.13.1.6	initStep	26
3.13.1.7	initTblocks	26
3.13.1.8	initZeros	26
3.13.1.9	monitorSolution	27
3.13.1.10	networkSolution & networkSolutionVTS	27
3.13.1.11	predictorIntegration	27

3.13.1.12	standAlonePlot	28
3.13.1.13	trimLogs	28
3.14	Sub-Transient Machine Models	28
3.15	sw_con Updates	29
3.16	Variable Time Step Integration - WIP	29
3.16.1	Solver Control Array (solver_con)	29
3.16.2	MATLAB ODE Solvers	30
3.16.3	Functions Specific to VTS	31
3.16.3.1	vtsInputFcn	32
3.16.3.2	vtsOutputFcn	33
3.16.3.3	handleNetworkSln	34
3.16.3.4	handleStDx	35
4	PST Operation Overview - WIP	37
4.1	Simulation Loop - WIP	37
5	Examples Explained - WIP	40
5.1	Automatic Generation Control - WIP	41
5.2	Variable Time Step - WIP	41
6	Loose Ends - WIP	42
7	Bibliography	44
8	Document History - WIP	45
A	Appendix A: Formatting Examples	46
A.1	Numberings in Equations	46
A.2	Numberings in Tables	46
A.3	Numberings in Figures	46
A.4	Code using Minted	47

List of Tables

A.14	Another Table.	46
------	------------------------	----

List of Figures

3.1	AGC calculation of <i>RACE</i> and <i>SACE</i>	5
3.2	AGC calculation of <i>ace2dist</i>	6
3.3	AGC handling of <i>ace2dist</i> to individual governor signals.	6
3.4	MATLAB ODE block diagram.	31
A.67	A boxcat in its natural environment.	46
A.68	Code listing as a figure.	47

List of Equations

3.1	Area Inertia Calculation	7
3.2	Area Average System Frequency Calculation	7
3.3	System Inertia Calculation	7
3.4	System Average System Frequency Calculation	7
3.5	Area-less System Inertia Calculation	7
3.6	Area-less System Average System Frequency Calculation	7
A.42	Ohm's Law	46

Glossary of Terms

Term	Definition
AC	Alternating Current
ACE	Area Control Error
AGC	Automatic Generation Control
BA	Balancing Authority
BES	Bulk Electrical System
CTS	Classical Transient Stability
DACE	Distributed ACE
EIA	United States Energy Information Administration
FERC	Federal Energy Regulatory Commission
FTS	Fixed Time Step
Hz	Hertz, cycles per second
IC	Interchange
ISO	Independent Service Operator
J	Joule, Neton meters, Watt seconds
LFC	Load Frequency Control
NERC	North American Electric Reliability Corporation
ODE	Ordinary Differential Equation
P	Real Power
PI	Proportional and Integral
PSS	Power System Stabilizer
PST	Power System Toolbox
PU	Per-Unit
Q	Reactive power
RACE	Reported ACE
RTO	Regional Transmission Organization
SACE	Smoothed ACE
SI	International System of Units
US	United States of America

Term	Definition
VAR	Volt Amps Reactive
VTs	Variable Time Step
W	Watt, Joules per second
WECC	Western Electricity Coordinating Council

1 PST Version History - WIP

- 2 - Original PST from 199x?
- 2.1 - Dan Trudnowski added batch running capability and machine tripping.
- 2.2 - Dan Trudnowski added power and current injection via the pwrmod model.
- 2.3 - Dan Trudnowski added a voltage behind a reactance model as ivmmod.
- 3.0 - From Joe Chow's website. Includes fixes and alterations. Notably multiple DC lines and PSS modifications.
- 3.1 - Based on 3.0, incorporates Dan Trudnowski's pwrmod and ivmmod models in non-linear simulation and machine tripping functionality. pwrmod included linear simulation and various model patches. Multiple generator tripping code is included, but untested.
- 3.1.1 - Based on 3.1. Version by Ryan Elliott at Sandia National Labs with energy storage and updated linear simulation along with various other fixes and code cleanup alterations.
- SETO - Based on 3.1. New global structure introduced. Includes automatic generation control models and variable time step options.
- 4.0.0 - Based on SETO version. Includes a refined VTS routine, confirmed multi-generator tripping, improved AGC action/modulation, code cleanup, example library, and documentation. Represents the end result of work by Thad Haines.

2 Code Fixes

Notable code fixes to code from PST 3 are collected in this chapter.

2.1 `exc_dc12`

In 2015 there were ‘errors’ corrected in the saturation block of the DC excitation model that create differences between version 2 and 3 of the `exc_dc12` model. Effects are noticeable, but a solution has not been investigated. The previous model version is included with PST 4 as `exc_dc12_old.m` but was not updated to use the new global structure.

2.2 `exc_st3`

There were two notable errors in the IEEE Type ST3 compound source rectifier exciter model `exc_st3` that were corrected:

- `theta` index variable changed to `n_bus` from `n` per Ryan Elliott.
- To use proper multiplication, the simple `*` was changed to `.*` in the `if ~isempty(nst3_sub)` section.

2.3 `lmod`

Load modulation had an error with state limiting. If over-limit, the derivative was set to zero, but the state was not set to the maximum/minimum value correctly. This issue has been resolved.

2.4 `mac_tra`

The transient machine model had commented code that prevented the setting equal of the transient reactances. These comments have been removed so that reactances are set equal.

2.5 `rlmod`

The same state limiting issues associated with `lmod` was found in `rlmod`. The issue was corrected in the same manner as `lmod`.

3 Changes and Additions

This chapter contains information on changes and additions to PST since version 3.

3.1 Area Definitions - WIP

Created area functionality via the `area_def`. The `area_indx` function creates the required data structures and indices.

To enable allow for AGC and the required area calculations, each bus in the `bus` array must be assigned to an area in the `area_def` array. An example `area_def` array is shown below.

```
%% area_def data format
% should contain same number of rows as bus array (i.e. all bus areas defined)
% col 1 bus number
% col 2 area number
area_def = [ ...
            1  1;
            2  1;
            3  1;
            4  1;
           10  1;
           11  2;
           12  2;
           13  2;
           14  2;
           20  1;
          101  1;
          110  2;
          120  2];
```

It should be noted that rows may not have to be in the same order as the bus array (untested). The `area_def` array is automatically placed into the global `g` structure.

```
>> g.area
ans =
    area_def: [13x2 double]
    n_area: 2
```

```
area: [1x2 struct]
```

Each area currently contains values that may be relevant to AGC calculations. The `calcAreaVals` function is used to calculate and store such values. An example of what is stored in the `g.area.area(x)` structure is shown below.

```
>> g.area.area(2)
ans =
    number: 2
   areaBuses: [6x1 double]
    macBus: [2x1 double]
 macBusNdx: [3 4]
   loadBus: [4x1 double]
loadBusNdx: [8 9 12 13]
    genBus: [2x1 double]
 genBusNdx: [6 7]
    totH: [1x4063 double]
    aveF: [1x4063 double]
   totGen: [1x4063 double]
  totLoad: []
    icA: [1x4063 double]
    icS: []
exportLineNdx: [11 12]
importLineNdx: []
   n_export: 2
   n_import: []
```

It should be noted that `icS` represents a placeholder for a scheduled interchange value and the `totLoad` is a field for collected total load. The collection of actual running load values may prove more complicated as the bus array does not seem to be updated every step, only a reduced Y matrix used in the `nc_load` function called from `i_simu`.

3.2 Automatic Generation Control

Automatic generation control (AGC) is an extended-term model that acts to restore system frequency and area interchange values to set values over the course of minutes. This restoration is accomplished by calculating an area control error (ACE) that is distributed to controlled generation sources to correct any deviation from reference values.

3.2.1 AGC Block Diagrams

The AGC process is shown in Figures 3.1, 3.2, and 3.3. *RACE* (reporting ACE) and *SACE* (smoothed ACE) are calculated using PU values assuming B is a positive non-PU value with units of $MW/0.1Hz$. If K_{bv} is not zero, the resulting *RACE* is not the industry standard (WECC defined) *RACE* value. The scheduled interchange may be altered by the user via a `mAGC_sig` file that controls the behavior of the IC_{adj} input.




Figure 3.1: AGC calculation of *RACE* and *SACE*.

$RACE$ and $SACE$ are calculated every simulation time step, however distribution of $SACE$ is determined by the user defined `startTime` and `actionTime` variables. Assuming action, the conditional $\Delta\omega$ logic is processed before adjusting the `aceSig` value which is then gained to become `ace2dist`.




Figure 3.2: AGC calculation of $ace2dist$.

The `ace2dist` value is distributed to all controlled generators associated with the AGC model according to their respective participation factor `pF`. Each `ctrlGen` has a unique low pass filter to allow for different ‘ramping’ of signals to individual machines. The output of the low pass filter is gained by -1 and added to the existing associated governor `tg_sig` value to drive ACE to zero.




Figure 3.3: AGC handling of $ace2dist$ to individual governor signals.

3.2.2 Weighted Average Frequency (`calcAveF`)

An inertia weighted average frequency is used as the ‘actual’ frequency ω in ACE calculations. The `calcAveF` function calculates an average weighted frequency for the total system and for each area (if areas are defined). System values are stored in `g.sys.aveF` and area values are stored in `g.area.area(x).aveF` where `x` is the area number. The calculation involves a sum of system inertias that changes with generator trips.

In a system with N generators, M areas, and N_M generators in area M , the `calcAveF` function performs the following calculations for each area M :

$$H_{tot_M} = \sum_i^{N_M} MV A_{base_i} H_i \quad (3.1)$$

$$F_{ave_M} = \left(\sum_i^{N_M} Mach_{speed_i} MV A_{base_i} H_i \right) \frac{1}{H_{tot_M}} \quad (3.2)$$

System total values are calculated as:

$$H_{tot} = \sum_i^M H_{tot_M} \quad (3.3)$$

$$F_{ave} = \left(\sum_i^M F_{ave_M} \right) \frac{1}{M} \quad (3.4)$$

If $M == 0$ (areas are not defined), `calcAveF` performs:

$$H_{tot} = \sum_i^N MV A_{base_i} H_i \quad (3.5)$$

$$F_{ave} = \left(\sum_i^N Mach_{speed_i} MV A_{base_i} H_i \right) \frac{1}{H_{tot}} \quad (3.6)$$

3.2.3 Other Area Calculations (`calcAreaVals`)

The `calcAreaVals` function calculates real and reactive power generated by all area machines and actual area interchange every time step. It should be noted that power injected via loads, `pwrmod`, or `ivmmmod` are not included in the `g.area.area(n).totGen(k)` value. An area's actual interchange is calculated using the `line_pq2` function to collect area to area line power flows.

3.3 Global Variable Management - WIP

Previous versions of PST rely on the use of over 340 global variables. It was decided to create a global structure that contains all exiting globals to enable easier development and use of PST. After global restructuring, initial simulation results showed a speed up of over 2 times. In other words, it could be assumed previous versions of PST spent half of their computation time handling globals.

Inside the global variable `g` are fields that corresponds to models, or groups, of other globals. Essentially, globals defined in the `pst_var` script were collected into related fields. For example, the `g.mac.mac_spd` global contains a all machine speeds while the `g.bus.bus_v` contains all bus voltages, etc. The following subsections describe the globals contained in each field of the global `g`. Consult [1] for a description of what most global variables represent.

3.3.1 agc - WIP

This field contains variables related to AGC models, calculations, and operations. An example of AGC variables are shown below

```
>> g.agc
ans =
    agc: [1x2 struct]
    n_agc: 2
do better
```

3.3.2 area - WIP

This field contains variables for area calculations and operations. An example of area variables are shown below.

```
>> g.area
ans =
    area_def: [13x2 double]
```

```

        n_area: 2
        area: [1x2 struct]
>> g.area.area(1)
do better

```

3.3.3 bus - WIP

The `g.bus` field contains the user supplied `bus` array and all altered bus arrays associated with faults created in `y_switch`. The bus field also contains the `bus_v` and `theta` information related to buses.

3.3.4 dc

This field contains variables for DC models, calculations, and operations.

```

%% HVDC link variables

global dcsp_con dcl_con dcc_con

global r_idx i_idx n_dcl n_conv ac_bus rec_ac_bus inv_ac_bus

global inv_ac_line rec_ac_line ac_line dcli_idx

global tap tapr tapi tmax tmin tstep tmaxr tmaxi tminr tmini tstepr tstepi

global Vdc i_dc P_dc i_dcinj dc_pot alpha gamma

global VHT dc_sig cur_ord dcr_dsig dci_dsig

global ric_idx rpc_idx Vdc_ref dcc_pot

global no_cap_idx cap_idx no_ind_idx l_no_cap l_cap

global ndcr_ud ndci_ud dcrud_idx dciud_idx dcrd_sig dcid_sig

%% States

%line

global i_dcr i_dci v_dcc

global di_dcr di_dci dv_dcc

global dc_dsig % added 07/13/20 -thad

%rectifier

```

```

global v_conr dv_conr
%inverter

global v_coni dv_coni
% added to global dc

global xdcr_dc dxdcr_dc xdc_i_dc dxdci_dc angdcr angdci t_dc
global dcr_dc dci_dc % damping control
global ldc_idx
global rec_par inv_par line_par

```

Some DC related functions reused global variable names for local values but avoided conflict by not importing the specific globals. During global conversion, this coding approach caused some issues with accidental casting to global and overwriting issues. While the non-linear and linear simulations run, there may be issues with this problem yet to be discovered. More specifically, the `tap` variable is re-written numerous times during a simulation when calculating line flows.

3.3.5 exc

This field contains variables for exciter models, calculations, and operations.

```

%% Exciter variables

global exc_con exc_pot n_exc
global Efd V_R V_A V_As R_f V_FB V_TR V_B
global dEfd dV_R dV_As dR_f dV_TR
global exc_sig
global smp_idx n_smp dc_idx n_dc dc2_idx n_dc2 st3_idx n_st3
global smppi_idx n_smppi smppi_TR smppi_TR_idx smppi_no_TR_idx
global smp_TA smp_TA_idx smp_noTA_idx smp_TB smp_TB_idx smp_noTB_idx
global smp_TR smp_TR_idx smp_no_TR_idx
global dc_TA dc_TA_idx dc_noTR_idx dc_TB dc_TB_idx dc_noTB_idx
global dc_TE dc_TE_idx dc_noTE_idx

```

```

global dc_TF dc_TF_idx dc_TR dc_TR_idx
global st3_TA st3_TA_idx st3_noTA_idx st3_TB st3_TB_idx st3_noTB_idx
global st3_TR st3_TR_idx st3_noTR_idx

```

3.3.6 igen

This field contains variables for induction generator models, calculations, and operations.

```

%% induction genertaor variables
global tmig pig qig vdig vqig idig iqig igen_con igen_pot
global igen_int igbus n_ig
%states
global vdpig vqpig slig
%dstates
global dvdpig dvqpig dslig
% added globals
global s_igen

```

3.3.7 ind

This field contains variables for induction motor models, calculations, and operations.

```

%% induction motor variables
global tload t_init p_mot q_mot vdmot vqmot idmot iqmot ind_con ind_pot
global motbus ind_int mld_con n_mot t_mot
% states
global vdp vqp slip
% dstates
global dvdp dvqp dslip
% added globals

```

```

global s_mot
global sat_idx dbc_idx db_idx % has to do with version 2 of mac_ind
% changed all pmot to p_mot (mac_ind1 only)

```

Two models of this are included as `mac_ind1` (a basic version from 2.3), and `mac_ind2` which is an updated induction motor model. Default behavior is to use the newer model (`mac_ind2`).

3.3.8 ivm - WIP

voltage model...

get the tstuff

3.3.9 k

To allow for functionalized running, various index values were placed into the global structure in the `g.k` field

```

global k_inc h ks h_sol
golbal k_incdc h_dc

```

3.3.10 line

The `g.line` field contains the user supplied `line` array and all altered line arrays associated with faults created in `y_switch`.

3.3.11 lmod

This field contains variables for real load modulation models, calculations, and operations.

```

global lmod_con % defined by user
global n_lmod lmod_idx % initialized and created in lm_idx
global lmod_sig lmod_st dlmod_st % initialized in s_simu
global lmod_pot % created/initialized in lmod.m
global lmod_data % added by Trudnowski - doesn't appear to be used

```


3.3.12 lmon - WIP

This field contains variables for line monitoring not previously collected during simulation. An example of lmon contents is shown below.

```
>> g.lmon
```

```
ans =
```

```
do better
```

3.3.13 mac

This field contains variables for machine models, calculations, and operations.

```
global mac_con mac_pot mac_int ibus_con
global mac_ang mac_spd eqprime edprime psikd psikq
global curd curq curdg curqg fldcur
global psidpp psiqpp vex eterm ed eq
global pmech pelect qelect
global dmac_ang dmac_spd deqprime dedprime dpsikd dpsikq
global n_mac n_em n_tra n_sub n_ib
global mac_em_idx mac_tra_idx mac_sub_idx mac_ib_idx not_ib_idx
global mac_ib_em mac_ib_tra mac_ib_sub n_ib_em n_ib_tra n_ib_sub
global pm_sig n_pm
global psi_re psi_im cur_re cur_im
% added
global mac_trip_flags
global mac_trip_states
```

3.3.14 ncl

This field contains variables for non-conforming load models, calculations, and operations.

```
global load_con load_pot nload
```

3.3.15 pss

This field contains variables for power system stabilizer models, calculations, and operations.

```
global pss_con pss_pot pss_mb_idx pss_exc_idx
global pss1 pss2 pss3 dpss1 dpss2 dpss3 pss_out
global pss_idx n_pss pss_sp_idx pss_p_idx;
global pss_T pss_T2 pss_T4 pss_T4_idx
global pss_noT4_idx % misspelled in pss_idx as pss_noT4
```

Despite the renaming of the `pss_noT4_idx`, it doesn't seem to actually be used anywhere.

3.3.16 pwr

This field contains variables for power or current injection models, calculations, and operations that use the `pwrmod` model.

```
global pwrmod_con n_pwrmod pwrmod_idx
global pwrmod_p_st dpwrmod_p_st
global pwrmod_q_st dpwrmod_q_st
global pwrmod_p_sig pwrmod_q_sig
global pwrmod_data
```

3.3.17 rlmod

This field contains variables for reactive load modulation models, calculations, and operations.

```
global rlmod_con n_rlmod rlmod_idx
global rlmod_pot rlmod_st drlmod_st
global rlmod_sig
```

3.3.18 svc

This field contains variables for static VAR control system models, calculations, and operations.

```
global svc_con n_svc svc_idx svc_pot svcll_idx
global svc_sig
% svc user defined damping controls
global n_dcud dcud_idx svc_dsig
global svc_dc % user damping controls?
global dxsvc_dc xsvc_dc
%states
global B_cv B_con
%dstates
global dB_cv dB_con
```

There seems to be code related to user defined damping control of SVC, but it does not seem to be described in any available documentation. This damping functionality was added by Graham Rogers circa 1998/1999.

3.3.19 sys

This field contains variables that deal with simulation operations.

```
global basmva basrad syn_ref mach_ref sys_freq
% globals added
global sw_con livePlotFlag Fbase t t_OLD
global aveF totH
global ElapsedNonLinearTime clearedVars
```

3.3.20 tcsc

This field contains variables for thyristor controlled series reactor models, calculations, and operations.

```

global tcsc_con n_tcsc tcsvf_idx tcsct_idx
global B_tcsc dB_tcsc
global tcsc_sig tcsc_dsig
global n_tcscud dtcscud_idx %user defined damping controls
% previous non-globals added as they seem to relavant
global xtcsc_dc dxtcsc_dc td_sig tcscf_idx
global tcsc_dc

```

Similar to the SVC model, there seems to be some added functionality for controlled damping, but no examples or previous documentation could be found. This damping functionality was added by Graham Rogers circa 1998/1999.

3.3.21 tg

This field contains variables for turbine governor models, calculations, and operations.

```

%% turbine-governor variables
global tg_con tg_pot
global tg1 tg2 tg3 tg4 tg5 dtg1 dtg2 dtg3 dtg4 dtg5
global tg_idx n_tg tg_sig tgh_idx n_tgh

```

It should be noted that the hydro governor model `tgh` has not been modified as no examples could be found that use it.

3.3.22 vts

Globals associated with variable time step simulation runs were placed in the `g.vts` field. A description of the included variables is shown below.

```

dataN      % Used as a the data index for logging values
dxVec      % Vector used to collect current dataN derivatives
fsdn       % A cell of fields, states, derivatives, and number of states
fts        % Cell containing any fixed step time vectors

```

```

fts_dc      % Cell containing any fixed step time vectors for DC simulation
iter        % Counter to monitor number of solutions per step
n_states    % Total system state count
netSlnCell  % Similar to fsdn, but related to network variables
netSlnVec   % Vector used to store initial network solution results
options     % MATLAB ODE solver options
slns        % A running history of solution iterations per step
solver_con  % User defined array defining what solution method to use
stVec       % Vector used to collect current dataN states
t_block     % A list of time blocks collected from sw_con
t_blockN    % Current time block index being executed
tot_iter    % Total number of solutions

```

3.3.23 y - WIP

Contains reduced Y matrices, voltage recovery matrices, and bus order variables created in `y_switch` associated with faults. Example variables are shown below.

```

>> g.int
ans =
    Y_gprf: [4x4 double]
do better....

```

3.4 handleNewGlobals Function

The `handleNewGlobals` function checks for user defined system arrays and puts them into the required global fields. This allows for PST input to remain the same between PST 4 and previous versions.

3.5 Internal Voltage Model (ivmmmod) - WIP

This is the ideal voltage behind an impedance model Dan created. It's meant to model a 'grid forming' inverter where voltage and angle can be set. While there are questions about the reality of such operations and how PST simulates them, the model exists and appears to 'work' in the non-linear simulation of PST 4. There is pre-existing documentation and an example that should be condensed into this document.

3.6 Line Monitoring Functionality (lmon) - WIP

Coded to actually monitor line current and power flow during non-linear simulation. The `lmon_indx` function creates the required data structures and indices.

Power flow on a line must be calculated each step as AGC requires actual area interchange for the ACE calculation. The previously existing `line_pq` function performed this task, but was not fully incorporated into the simulation to allow calculation during execution. This minor oversight has been resolved and the `lmon_con` array is still used to define monitored lines as in previous version of PST. It should be noted that areas with AGC automatically track area interchange flows and do not need to be user defined.

```
%% Line Monitoring
% Each value corresponds to an array index in the line array.
% Complex current and power flow on the line will be calculated and logged during
↪ simulation

%lmon_con = [5, 6, 13]; % lines between bus 3 and 101, and line between 13 and 120

lmon_con = [3,10]; % lines to loads
```

Line monitoring data is collected in the `g.lmon` field of the global variable.

```
>> g.lmon
ans =
    lmon_con: [3 10]
      n_lmon: 2
 busFromTo: [2x2 double]
       line: [1x2 struct]
```

Each `g.lmon.line` entry contains the following fields and logged data:

```
>> g.lmon.line(2)
ans =
    busArrayNdx: 10
      FromBus: 13
```

```

ToBus: 14
iFrom: [1x4063 double]
iTo: [1x4063 double]
sFrom: [1x4063 double]
sTo: [1x4063 double]

```

3.7 Live Plotting Functionality (liveplot) - WIP

Default action of PST 3 was to plot the bus voltage magnitude at a faulted bus. However, it may be useful to plot other values or turn off the plotting during a simulation. The live plotting routine is now functionalized to allow users to more easily define what is displayed (if anything) during simulations. The `livePlot` function was designed to be overwritten in a similar fashion as PSS or machine models previously described.

There are currently XXX live plot functions:

- `liveplot_ORIG` - Original faulted bus voltage plot.
- `liveplot_1` - Faulted bus voltage and system machine speeds plus any lmod signals.
- `liveplot_2` - AGC signals.

It should be noted that the live plotting can cause extremely slow simulations and occasional crashes. To disable live plotting:

- In stand-alone mode:

Change the 'live plot?' field from a 1 to a 0 in the popup dialog box.

- In batch mode:

Create a variable `livePlotFlag` and set as 0 or `false`.

3.8 Machine Trip Logic (`mac_trip_logic`) - WIP

This section should cover how machines are tripped and mention later examples?

3.9 Octave Compatibility

To more fully support free and open-source software, PST 4 has been developed to be compatible with Octave. It should be noted that more experimental features, like VTS, hasn't been tested fully in Octave. It is known that not all ODE options that exist in MATLAB are included in Octave. Current Octave compatible solution methods are:

- huens
- ode23
- ode15s

Additionally, MATLAB simulations run are generally faster than Octave. It should be noted that when using Octave, calls to save and load data must include explicit file endings (i.e. `save someData.mat`).

3.10 Power Injection Model (pwrmod) - WIP

This is the power/current injection model Dan created for version 2.3. It's meant to model the 'grid-following' type of inverters. It is included in both the non-linear and linear simulation modes of PST 4. There is pre-existing documentation and an example that should be condensed into this document.

3.11 Power System Stabilizer Model

There was a modification to the washout time constant in the power system stabilizer (PSS) model between PST version 2 and 3 that affects the output of the model in a fairly drastic way. To accommodate for this, PST 4 has two PSS files named `pss2` and `pss3` which mimic the computation of each PST version PSS model respectively. This enables the user to specify which PSS model should be used by copying the numbered PSS files over the non-numbered PSS file. A code example of this overwriting process is shown below where `PSTpath` is a variable containing the full path to the root directory of PST 4.

```
copyfile([PSTpath 'pss2.m'],[PSTpath 'pss.m']); % use version 2 model of PSS
copyfile([PSTpath 'pss3.m'],[PSTpath 'pss.m']); % use version 3 model of PSS
```

It should be noted that the default PSS model used in PST 4 is `pss2`.

3.12 Reset Original Files Function (`resetORIG`)

As the operation of PST commonly involves replacing system models and modulation files, the need to restore all original files can be very useful. Especially if unexpected behavior is observed in simulation output. The `resetORIG` script replaces all possible model and modulation files with the default versions. As of this writing, the correct operation of this script is as follows:

1. Navigate to root PST 4 directory in MATLAB
2. Execute `resetORIG`

A text message should be displayed stating the restoration process has completed. If other models are preferred for default use, the restoration process can be modified. Simply change the `**_ORIG` file name to the file that should be copied instead.

3.13 s_simu Changes

The `s_simu` script used to run non-linear simulations from PST 3 was relatively long and objectively messy. Work has been done to clean up the pre-existing code and functionalize sections for easier readability and process understanding. Additionally, 'stand alone mode' and 'batch mode' capabilities have been condensed into one file. The difference between batch and stand alone mode is that the later will prompt the user for input of a system file and other simulation parameters while batch mode assumes the file to run is the `DataFile.m` in the root PST directory.

- To use stand alone mode:

Run `s_simu` after issuing the `clear all; close all` commands.

- To use batch mode:

Ensure at least 1 non-global variable is in the workspace prior to running `s_simu`.

3.13.1 Functionalization

The use of a single global allowed for easier functionalization of easily identifiable parts of code. Below are some of the functions that were created from code originally in `s_simu`.

3.13.1.1 cleanZeros

The `cleanZeros` function cleans all entirely zero variables from the global `g` and places the names of cleared variables into the `clearedVars` cell that is stored in `g.sys`. The function is executed near the end of `s_simu`.

3.13.1.2 correctorIntegration

As shown in the code except below, the `correctorIntegration` function performs the corrector integration step of the simulation loop to calculate the next accepted value of integrated states. The executed code was taken directly from `s_simu` and modified to work with the new global `g`.

```

function correctorIntegration(k, j, h_sol)
% CORRECTORINTEGRATION Performs  $x(j) = x(k) + h\_sol*(dx(j) + dx(k))/2$ 
%
% Input:
% k - data index for 'n'
% j - data index for 'n+1'
% h_sol - time between k and j

```

It should be noted that the two integration functions write new states to the same `j` data index. Additionally, the `h_sol` value is updated in `i_simu` (called during the network solution) from the index of `ks` referencing an `h` array containing time step lengths. . . While this process seemed unnecessarily confusing and sort of round-about, it has not been changed as of this writing.

3.13.1.3 dcSolution

The portion of `s_simu` that integrates DC values at 10 times the rate of the normal time step was moved into the `dcSolution` function. This has not been tested with VTS, but was functionalized to enable future development. It appears to work as normal when using Huen's method (FTS), but a thorough testing has yet to be performed as of this writing.

Realistically, it doesn't make much sense to include a multi-rate integration routine into a variable step routine. If DC is to be integrated into VTS, the models should be handled as all other models. While this may defeat the purpose of VTS simulation due to DC models traditionally having very fast time constants, it is an avenue to explore should future development be desired.

3.13.1.4 dynamicSolution

As the name implies, the `dynamicSolution` function performs the dynamic model calculations at data index `k` by calling each required model with the input flag set to 2. This functionalized code is again taken directly from `s_simu`.

3.13.1.5 initNLsim

The `initNLsim` function is a collection of code from `s_simu` that performs initialization operations before a non-linear simulation. This is essentially the creation of the various Y-matrices used for fault conditions and the calling of the dynamic models with the input flag set to 0.

3.13.1.6 initStep

Code from `s_simu` that was performed at the beginning of each solution step was collected into `initStep`. Operations are related to setting values for the next step equal to current values for mechanical powers and DC currents, as well as handling machine trip flags.

3.13.1.7 initTblocks

The `initTblocks` function analyzes the global `sw_con` and `solver_con` to create appropriate *time blocks* that are used in non-linear simulation. Any fixed time vectors associated with time blocks that use Huen's method are also created. Care was taken to ensure a unique time vector (no duplicate time points). With the option to switch between fixed step and variable step methods, this method may require slight modifications/refinements in the future.

3.13.1.8 initZeros

A large amount of code (≈ 400 lines) in PST 3's `s_simu` was dedicated to initializing zeros for data to be written to during non-linear simulation. This code has been collected into the `initZeros` function with inputs defining the desired length of vectors for normally logged data and DC data.

```
function initZeros(k, kdc)
% INITZEROS Creates zero arrays for logged values based on passed in input
%
%   Input:
%   k - total number of time steps in the simulation
%   kdc - total number of DC time steps in the simulation
```

3.13.1.9 monitorSolution

The `monitorSolution` function takes a single input that defines the data index used to calculate any user defined line monitoring values, average system and/or area frequencies, and other interchange values for defined areas. It should be noted that these calculations are mostly based on complex voltages that are calculated during the network solution.

3.13.1.10 networkSolution & networkSolutionVTS

The `networkSolution` function is a collection of code from `s_simu` dealing with calls to dynamic models with the flag set to 1 and Y-matrix switching. The call to `i_simu` (which updates `g.k.h_sol`) is also located in this function.

The `networkSolutionVTS` function is essentially the same as the `networkSolution` function, except instead of relying on index number to switch Y-matrices, the switching is done based on passed in simulation time. This was a required change when using VTS as the previous method relied on a known number of steps between switching events, and that is no longer a reality with the experimental VTS methods.

The default behavior of PST 4 is to use `newtowrkSolutionVTS` which requires the input of the current data index `k` and the simulation time.

3.13.1.11 predictorIntegration

The `predictorIntegration` function performs the predictor (forward Euler) integration step of the simulation loop. The code was taken directly from `s_simu` and uses the same variable names adapted for use with the global `g`.

```
function predictorIntegration(k, j, h_sol)
% PREDICTORINTEGRATION Performs  $x(j) = x(k) + h\_sol * dx(k)$ 
%
% Input:
% k - data index for 'n'
% j - data index for 'n+1'
% h_sol - time between k and j
```

3.13.1.12 `standAlonePlot`

The `standAlonePlot` function is the updated plotting routine based on user input previously found at the end `s_simu`. After a completed simulation, it is called from `s_simu` if stand alone mode is detected. Alternatively, it can be run independently from the simulation to analyze a pre-existing global `g` by being invoked as `standAlonePlot(1)`.

3.13.1.13 `trimLogs`

As there is no way to accurately predict the amount of (length of) data to be logged during a variable time step simulation, extra space is allocated, and then all logged values are trimmed to the proper length post simulation. It should be noted that the current size allocation was arbitrary and can be altered as deemed fitting. Typically, an extended term simulation using VTS will requires fewer steps than a fixed step method, but that is not always the case. It's important to note that if not enough space is allocated, the simulation will crash when the code attempts to access data indices outside of the allocated range.

The `trimLogs` function trims all logged values in the global `g` to a given length `k`. It is executed near the end of `s_simu` before `cleanZeros`.

```
function trimLogs(k)
% TRIMLOGS trims logged data to input index k.
%
% NOTES: nCell not made via logicals - may lead to errors if fields not initialized
% → (i.e. model not used). Issue not encountered yet, but seems possible
%
% Input:
% k - data index
```

3.14 Sub-Transient Machine Models

There are three versions of the sub-transient machine model (`mac_sub`) included with PST 4. The `mac_sub_ORIG` model is the standard PST model based on the R. P. Schulz, "Synchronous machine modeling" algorithm. The `mac_sub_NEW` model is based on the PSLF

'genrou' model by John Undrill. The `mac_sub_NEW2` model is the same as the `_NEW` model with minor bug fixes and alterations by Dan Trudnowski. Any model may be copied over the `mac_sub` file for simulation use as shown below.

```
copyfile([PSTpath 'mac_sub_NEW2.m'],[PSTpath 'mac_sub.m']); % use genrou model
copyfile([PSTpath 'mac_sub_ORIG.m'],[PSTpath 'mac_sub.m']); % restore model
```

3.15 `sw_con` Updates

Undocumented changes to the `sw_con` have occurred in version 3. The valid trip options of the `sw_con` row 2 column 6 are:

1. Three phase fault
2. Line-to-Ground
3. Line-to-Line
4. Loss of line with no fault
5. Loss of load at bus
6. No action
7. Clear fault without loss of line

3.16 Variable Time Step Integration - WIP

Variable time step (VTS) simulations are possible using standard MATLAB ODE solvers.

Explain FTS and VTS

Cover speed up possibility

explain zeroing derivatives.

NOTE: Variable time step simulation is still experimental and should be used with caution.

3.16.1 Solver Control Array (`solver_con`)

To use variable time step integration methods, a user will have to create a `solver_con` to a valid data file. If a `solver_con` is not specified, Huen's method is used for all time blocks

(i.e. default PST 3 behavior).

Between each `sw_con` entry, a *time block* is created that is then solved using a the defined solution method in the `solver_con`. As such, the `solver_con` array has 1 less row than the `sw_con` array. An example `solver_con` array (with code comments) is shown below.

```
%% solver_con format
% A cell with a solver method in each row corresponding to the specified
% 'time blocks' defined in sw_con
%
% Valid solver names:
% huens - Fixed time step default to PST
% ode113 - works well during transients, consistent # of slns, time step stays
% → relatively small
% ode15s - large number of slns during init, time step increases to reasonable size
% ode23 - relatively consistent # of required slns, timestep doesn't get very large
% ode23s - many iterations per step - not efficient...
% ode23t - occasionally hundreds of iterations, most times not... decent performance
% ode23tb - similar to 23t, sometimes more large solution counts

solver_con = { ...
    'huens'; % pre fault - fault
    'huens'; % fault - post fault 1
    'huens'; % post fault 1 - post fault 2
    'huens'; % post fault 2 - sw_con row 5
    'ode113'; % sw_con row 5 - sw_con row 6
    'ode23t'; % sw_con row 6 - sw_con row 7 (end)
};
```

3.16.2 MATLAB ODE Solvers

The VTS implementation in PST revolves around using the built in MATLAB ODE solvers. All these methods perform actions depicted in Figure 3.4.

The input to an ODE solver include, an input function, a time interval (time block), initial conditions, and solver options. The current options used for VTS are shown below and deal with error tolerance levels, initial step size, max step size, and an Output function.




Figure 3.4: MATLAB ODE block diagram.

```

% Configure ODE settings
%options = odeset('RelTol',1e-3,'AbsTol',1e-6); % MATLAB default settings
options = odeset('RelTol',1e-4,'AbsTol',1e-7, ...
    'InitialStep', 1/60/4, ...
    'MaxStep',60, ...
    'OutputFcn',outputFcn); % set 'OutputFcn' to function handle
  
```

3.16.3 Functions Specific to VTS

A number of new functions were created to enable VTS to be integrated into PST. Most functions were created to handle data or perform other tasks specifically related to VTS. The following sections provide information about such functions.

3.16.3.1 vtsInputFcn

To use the MATLAB ODE solvers, a function must be passed in that returns a vector of derivatives associated with the states to integrate. The `vtsInputFcn` was created to perform this critical task. The slightly abbreviated input function is shown below.

```
function [dxVec] = vtsInputFcn(t, y)
% VTSINPUTFCN passed to ODE solver to perform required step operations
%
% NOTES: Updates and returns g.vts.dxFcn
%
% Input:
% t - simulation time
% y - solution vector (initial conditions)
%
% Output:
% dxVec - required derivative vector for ODE solver
global g

%% call handleStDx with flag==2 to update global states with newest passed in soln.
% write slnVec vector of values to associated states at index k
% i.e. update states at g.vts.dataN with newest solution
handleStDx(g.vts.dataN, y, 2)

%% Start initStep action =====
initStep(g.vts.dataN)

%% Start of Network Solution =====
networkSolutionVTS(g.vts.dataN, t)

%% Start Dynamic Solution =====
dynamicSolution(g.vts.dataN )

%% Start of DC solution =====
dcSolution(g.vts.dataN )

%% save first network solution
if g.vts.iter == 0
    handleNetworkSln(g.vts.dataN ,1)
end

g.vts.iter = g.vts.iter + 1; % increment solution iteration number
```

```

handleStDx(g.vts.dataN , [], 1) % update g.vts.dxFcn
dxVec = g.vts.dxFcn; % return updated derivative vector
end % end vtsInputFcn

```

3.16.3.2 vtsOutputFcn

After each acceptable solution, the ODE solver calls a passed in ‘output function’. The `vtsOutputFcn` was created to handle restoring the network solution and performing the monitor solution. Additionally, the `vtsOutputFcn` handles required indexing and iteration accumulation and logging. The slightly abbreviated output function is shown below.

```

function status = vtsOutputFcn(t,y,flag)
% VTSOUTPUTFCN performs associated flag actions with ODE solvers.
%
% Input:
% t - simulation time
% y - solution vector
% flag - dictate function action
%
% Output:
% status - required for normal operation (return 1 to stop)

global g
status = 0; % required for normal operation

if isempty(flag) % normal step completion
    % restore network to initial solution
    handleNetworkSln(g.vts.dataN ,2) % may cause issues with DC.

    monitorSolution(g.vts.dataN); % Perform Line Monitoring and Area Calculations

    %% Live plot call
    if g.sys.livePlotFlag
        livePlot(g.vts.dataN)
    end

    % after each successful integration step by ODE solver:
    g.vts.dataN = g.vts.dataN+1; % increment logged data index 'dataN'
    g.sys.t(g.vts.dataN) = t; % log step time
    g.vts.stVec = y; % update state vector
    handleStDx(g.vts.dataN, y, 2) % place new solution results into associated globals

```

```

g.vts.tot_iter = g.vts.tot_iter + g.vts.iter;    % update total iterations
g.vts.slms(g.vts.dataN) = g.vts.iter;           % log solution step iterations
g.vts.iter = 0;                                % reset iteration counter

elseif flag(1) == 'i'
    % init solver for new time block
    g.sys.t(g.vts.dataN) = t(1);                % log step time
    handleStDx(g.vts.dataN, y, 2)               % set initial conditions

elseif flag(1) == 'd'
    % only debug screen output at the moment
end % end if
end % end function

```

3.16.3.3 handleNetworkSln

The `handleNetworkSln` function was created to store, and restore, calculated values set to globals during a network solution. The purpose of this function was to allow for the first network solution performed each step to be carried forward after multiple other network solutions may over-write the calculated values at the same data index. This over-writing may occur during the MATLAB ODE solver's repeated calls to the input function. As shown below, `handleNetworkSln` takes a data index `k` and an operation `flag` as inputs.

```

function handleNetworkSln(k, flag)
% HANDLENETWORKSLN saves or restores the network solution at data index k
%
% NOTES: Used to reset the network values to the initial solution in VTS.
%
% Input:
% k - data index to log from and restore to
% flag - choose function operation
%     0 - initialize globals used to store data
%     1 - collect network solution values from index k into a global vector
%     2 - write stored network solution vector to network globals data at index k

```

3.16.3.4 handleStDx

The `handleStDx` function was created to perform the required state and derivative handling to enable the use internal MATLAB ODE solvers. Its general operation is probably best described via the internal function documentation provided below.

```
function handleStDx(k, slnVec, flag)
% HANDLESTDx Performs required state and derivative handling for ODE solvers
%
% NOTES: Requires state and derivative values are in the same g.(x) field.
%        Not all flags require same input.
%
% Input:
% k - data index
% flag - choose between operations
%       0 - initialize state and derivative cell array, count states
%       1 - update g.vts.dxFVec with col k of derivative fields
%       2 - write slnVec vector of values to associated states at index k
%       3 - update g.vts.stVec with col k of state fields
% slnVec - Input used to populate states with new values
```

The new global structure created in PST 4 enables this function to complete the stated operations by relying heavily on dynamic field names. Essentially, all required field names, sub-field names, and states are collected into a cell (flag operation 0) that is then iterated through to collect data from, or write data to the appropriate location (all other flag operations).

The usefulness of `handleStDx` is that the standard MATLAB ODE solvers require a single derivative vector as a returned value from some passed in ‘input function’, and each PST model calculates derivatives and places them into various globals. Thus, a derivative collection algorithm was needed (flag operation 1). Once the ODE solver finishes a step, the returned solution vector (of integrated states) must then be parsed into the global state variables associated with the supplied derivatives (flag operation 2). At the beginning of time blocks that use the MATLAB ODE solvers, an initial conditions vector of all the states related to the derivative vector is required (flag operation 3).

To avoid handling function output, global vectors `g.vts.dxVec` and `g.vts.stVec` are used to hold updated derivative and state vector information.

It should be noted that original PST globals follow the same data structure, however, new models (such as AGC and pwrmod/ivmmmod) use a slightly different data structure and must be handled in a slightly different way. As of this writing AGC, pwrmod, and ivmmmod functionality has been added to `handleStdX` and it seems very possible to add more models that require integration as they arise.

4 PST Operation Overview - WIP

This is likely to include a flow chart/ multiple flow charts.

Mention partitioned explicit method via Huen's, partitioned implicit via VTS.

Overview of running `s_simu` in batch or stand alone mode.

copying of modulation files

4.1 Simulation Loop - WIP

The complete simulation loop code is shown below. This code was copied from `s_simu_BatchVTS` with corresponding line numbers.

```

362 %% Simulation loop start
363 warning('*** Simulation Loop Start')
364 for simTblock = 1:size(g.vts.t_block)
365
366     g.vts.t_blockN = simTblock;
367     g.k.ks = simTblock; % required for huen's solution method.
368
369     if ~isempty(g.vts.solver_con)
370         odeName = g.vts.solver_con{g.vts.t_blockN};
371     else
372         odeName = 'huens'; % default PST solver
373     end
374
375     if strcmp(odeName, 'huens')
376         % use standard PST huens method
377         fprintf('*** Using Huen''s integration method for time block %d\n*** t=[%7.4f,
378             ↪ %7.4f]\n', ...
379             simTblock, g.vts.fts{simTblock}(1), g.vts.fts{simTblock}(end))
380
381         % add fixed time vector to system time vector
382         nSteps = length(g.vts.fts{simTblock});
383         g.sys.t(g.vts.dataN:g.vts.dataN+nSteps-1) = g.vts.fts{simTblock};
384
385         % account for pretictor last step time check
386         g.sys.t(g.vts.dataN+nSteps) = g.sys.t(g.vts.dataN+nSteps-1)+
387             ↪ g.sys.sw_con(simTblock,7);
388
389         for cur_Step = 1:nSteps

```



```

388     k = g.vts.dataN;
389     j = k+1;
390
391     % display k and t at every first, last, and 50th step
392     if ( mod(k,50)==0 ) || cur_Step == 1 || cur_Step == nSteps
393         fprintf('*** k = %5d, \tt(k) = %7.4f\n',k,g.sys.t(k)) % DEBUG
394     end
395
396     %% Time step start
397     initStep(k)
398
399     %% Predictor Solution =====
400     networkSolutionVTS(k, g.sys.t(k))
401     monitorSolution(k);
402     dynamicSolution(k)
403     dcSolution(k)
404     predictorIntegration(k, j, g.k.h_sol) % g.k.h_sol updated i_simu
405
406     %% Corrector Solution =====
407     networkSolutionVTS(j, g.sys.t(j))
408     dynamicSolution(j)
409     dcSolution(j)
410     correctorIntegration(k, j, g.k.h_sol)
411
412     % most recent network solution based on completely calculated states is k
413     monitorSolution(k);
414     %% Live plot call
415     if g.sys.livePlotFlag
416         livePlot(k)
417     end
418
419     g.vts.dataN = j; % increment data counter
420     g.vts.tot_iter = g.vts.tot_iter + 2; % increment total solution counter
421     g.vts.slns(g.vts.dataN) = 2; % track step solution
422 end
423 % Account for next time block using VTS
424 handleStDx(j, [], 3) % update g.vts.stVec to initial conditions of states
425 handleStDx(k, [], 1) % update g.vts.dxDxVec to initial conditions of derivatives
426
427 else % use given variable method
428     fprintf('*** Using %s integration method for time block %d\n*** t=[%7.4f,
429     ↪ %7.4f]\n', ...
430     odeName, simTblock, g.vts.t_block(simTblock, 1), g.vts.t_block(simTblock,
431     ↪ 2))

```

```
430      % feval used for ODE call - could be replaced with if statements.
431      feval(odeName, inputFcn, g.vts.t_block(simTblock,:), g.vts.stVec , options);
432
433      % Alternative example of using actual function name:
434      %ode113(inputFcn, g.vts.t_block(simTblock,:), g.vts.stVec , options);
435
436  end
437
438 end% end simulation loop
```

5 Examples Explained - WIP

As github as many examples, this is a chapter to explain what the purpose of them is and detail non-linear vs linear operation of examples that do such things.

- Experimental VTS
- AGC
- AGC interchange modulation
- Extended term with VTS
- Hiskens NE model via Ryan
- MiniWECC via Dan
- Experimental Un-tripping
- Modulation via `_mod` files
- Linear simulation where applicable

Variables to note in associated examples (where `x` is the internal model number):

- exciter $V_{ref} = \text{g.exc.exc_pot}(x,3)$
- governor $P_{ref} = \text{g.tg.tg_pot}(x,5)$
- governor $\omega_{ref} = \text{g.tg.tg_con}(x,3)$

5.1 Automatic Generation Control - WIP

A variety of examples were created for AGC testing. While some may use VTS, this section covers information only related to AGC. The VTS example section contains VTS specific information.

The `0-examples/AGC` folder contains all system and modulation files associated with the AGC examples. The `run***` files are designed to run PST in using the batch mode.

5.2 Variable Time Step - WIP

6 Loose Ends - WIP

As software development is never actually over, this chapter is meant to contain any loose ends that felt relevant. The below is copied from the most recent weekly (09/02/20) and some minor additions

1. As infinite buses don't seem to be used in dynamic simulation, they were not converted to use the global `g`.
2. `tgh` model not converted for use with global `g`. (no examples of `tgh gov`)
3. In original (and current) `s_simu`, the global `tap` value associated with HVDC is overwritten with a value used to compute line current multiple times.
It probably shouldn't be.
4. Constant Power or Current loads seem to require a portion of constant Impedance.
5. PSS design functionality not explored
6. No examples of of delta P omega filter or user defined damping controls for SVC and TCSC models
7. Differences in `mac_ind` between pst 2 and 3 seem backward compatible - untested.
8. DC is not implemented in VTS - Just combine into main routine? Seems counter intuitive to do multi-rate variable time step integration.
9. AGC capacity should consider defined machine limits instead of assuming 1 PU max.
10. AGC should allow for a 'center of inertia' frequency option instead of the weighted average frequency.
11. A method to initialize the power system with tripped generators should be devised and occur before the first power flow solution.

12. A method to zero derivatives of any model attached to a tripped generator should be created to enable VTS to optimize time steps.
13. Re-initializing a tripped generator in VTS will likely require indexing the `g.vts.stVec`. This could be aided by adding indices to the `g.vts.fsdn` cell.
14. miniWECC DC lines (modeled as power injection) is not included in AGC calculations as the power does not travel over simulated lines.

7 Bibliography

- [1] Joe Chow, Graham Rogers, *Power System Toolbox Version 3.0 User Manual*, 2008.

8 Document History - WIP

- 09/02/20 - 0.0.0-a.1 - Document initialization.
- 09/03/20 - 0.0.0-a.2 - Population with sections and some previously generated content, addition of glossary
- 09/07/20 - 0.0.0-a.3 - Added and alphabetized more sections, collected raw material from research documents
- 09/08/20 - 0.0.0-a.4 - Figure and equation formatting in AGC, more logical sectioning, minor editing
- 09/09/20 - 0.0.0-a.5 - Introduction work, AGC section editing, restructure of various sections, readability edits to a majority of sections, WIP added to sections requiring more work.

A Appendix A: Formatting Examples

This appendix is included to show how appendices work, blowing up of numbering, and to also serve as an easy L^AT_EX formatting template. Despite this being an appendix, it is still numbered like a chapter.

A.1 Numberings in Equations

Additionally, a reminder of Ohm's law

$$V = IR \tag{A.42}$$

shows that equation numbering has blown up. This is to show spacing on the table of contents.

A.2 Numberings in Tables

Table A.14 is full of nonsense data and is numbered artificially large.

Table A.14: Another Table.

One	Two	Three	Four	Five
2.35	45.87	9.00	1.00	0.33
5.88	48.01	7.85	2.35	0.45

A.3 Numberings in Figures

Finally, Figure A.67 shows how figure numbers look when double digit.



Figure A.67: A boxcat in its natural environment.

A.4 Code using Minted

Code can be added using the `minted` package. The example below is for a Python example, but can be configured other ways. Note that a `--shell-escape` command had to be added to the `TeXStudio` build command due to peculiarities with the package. Additionally, the `minted` `LaTeX` package requires python to be installed with the `pygments` package. This can be done via the `'py -m pip install -U pygments'` console command.

```

1  def sumPe(mirror):
2      """Returns sum of all electrical power from active machines"""
3      sysPe = 0.0
4
5      # for each area
6      for area in mirror.Area:
7          # reset current sum
8          area.cv['Pe'] = 0.0
9
10         # sum each active machine Pe to area agent
11         for mach in area.Machines:
12             if mach.cv['St'] == 1:
13                 area.cv['Pe'] += mach.cv['Pe']
14
15         # sum area agent totals to system
16         sysPe += area.cv['Pe']
17
18     return sysPe

```

Figure A.68: Code listing as a figure.

Other packages exist for code insertion, but they may or may not be as pretty. Remember, as with anything, this is totally optional and voluntary...