

**Recent Progress:**

1. Generator un-tripping work:
  - Tripping method examined
  - Un-Tripping experimental method created
  - Re-initialize functions created for `smpecx`, `tg`, `mac_sub`
  - Test case and result document created
2. Zeroing out of derivatives for tripped machines added to fixed time-step routine. (Huen's Method)
3. GitHub updated:  
<https://github.com/thadhaines/MT-Tech-SET0>

**Current Tasks:**

1. Work on un-trip functionality:
  - Further study re-initialization actions / requirements
  - More generic/functionalized programming
  - Compatibility with VTS
2. Create extended term event:
  - Use miniWECC and `pwrmod`
  - Issue: rolling blackouts in CA
  - High PV penetration
  - Drought has led to lower hydro output
  - Initial low N→S flows
  - Solar generation declines as load increases
  - Inadequate CA dispatchable generation
  - Leads to large N→S flows
  - EIA data from 8/14/20 18:00?
3. Work towards PST 4.0.0:
  - Optimize Y-matrix reduction when tripping generators
  - Verify and Validate operation of AGC, PWRMOD, IVMMOD, and VTS.
  - Refine documentation
  - Clean up examples
  - Clean up code/comments
  - Clean up readme files
4. Rework AGC doc to better explain model/example?
5. Work on understanding PST operation
6. Document findings of PST functionality
7. Investigate Octave compatibility

**Current Questions:**

1. Only 1 `pwrmod` **model** allowed per case?
2. Real data for case?

**Loose ends:**

1. As infinite buses don't seem to be used in dynamic simulation, they were not converted to use the global `g`.
2. `tgh` model not converted for use with global `g`. (no examples of `tgh gov`)
3. In original (and current) `s_simu`, the global `tap` value associated with HVDC is over-written with a value used to compute line current multiple times. It probably shouldn't be.
4. Constant Power or Current loads seem to require a portion of constant Impedance.
5. PSS design functionality not explored
6. No examples of of delta P omega filter or user defined damping controls for SVC and TCSC models
7. Differences in `mac_ind` between `pst 2` and `3` seem backward compatible - untested.
8. DC is not implemented in VTS - Just combine into main routine? Seems counter intuitive to do multi-rate variable time step integration.
9. AGC capacity should consider defined machine limits instead of assuming 1 PU max.
10. AGC should allow for a 'center of inertia' frequency option instead of the weighted average frequency.

**Coding Thoughts:**

1. Rework how switching & perturbation events are handled into a more flexible and general format. (flags? objects?)
2. Generate comparison scripts to verify simulated results match between code revisions and modifications.