

**LONG-TERM DYNAMIC SIMULATION OF POWER SYSTEMS
USING PYTHON, AGENT BASED MODELING,
AND TIME-SEQUENCED POWER FLOWS**

by
Thad Haines

A thesis submitted in partial fulfillment of the
requirements for the degree of

Master of Science in Electrical Engineering

Montana Technological University
2020



Abstract

Automated controls facilitate reliable and efficient operation of modern power systems. Engineers employ computer simulations to develop, analyze, and tune such controls. Short-term dynamic, or transient, power system simulation is a useful and standardized power industry tool. Researchers have developed effective long-term dynamic (LTD) simulators, but there is not yet an industry standard computational method or software package for LTD simulation.

This work introduces a novel LTD simulation tool and provides examples of various engineering applications. The newly created software tool, Power System Long-Term Dynamic Simulator (PSLTDSim), uses a time-sequenced power flow (TSPF) technique to simulate LTD events. The TSPF technique incorporates a number of modeling assumptions that simplify certain engineering calculations. Despite such simplifications, PSLTDSim demonstrates an acceptable amount of accuracy for ramp and small step type perturbations when compared to industry standard transient simulation software. Demonstrated PSLTDSim engineering applications include: investigation of long-term governor deadband effects, automatic generation control tuning, and switched shunt coordination during multi-hour events. Further demonstrated examples consist of user modified turbine speed governor behavior and variable system damping and inertia. This material is based upon work supported by the U.S. Department of Energy, Office of Science, Basic Energy Sciences, under Award Number DE-SC0012671.

Keywords: Power system simulation, Long-term dynamics, Time-sequenced power flow, Automatic generation control, AGC, Agent based modeling, ABM, Advanced message queueing protocol, AMQP, Python, IronPython

Dedication

For you...
And others too.

Acknowledgments

Acknowledgments must first be made to all teachers and fellow students who took part in my educational career. It's hard to know what you don't know until someone tells you otherwise. Further, without these relationships, academia would be a very strange and solitary place.

I'd like to thank Matt Donnelly for agreeing to be my graduate advisor and committee chair. Matt provided much appreciated research direction and industry insight over the course of this research project. It was nice to work with someone who was never afraid to disagree with me and thus provide continuous opportunities for me to prove him wrong. His unassuming wisdom and approach to problem solving would be very useful in any effort to burn the man.

Without the School of Mines and Engineering Dean, Dan Trudnowski, casually mentioning graduate school to me during my undergrad, I probably never would've even considered it. His classes and general approach to teaching were informative and entertaining. While he certainly could've failed me just for fun, he didn't - and that was real nice of him. True 'power' requires true restraint right? I'm glad he's teaching classes again as I don't think anyone else is going to kick tables, draw on walls, or pretend to be confused quite like he does.

Committee member Josh Wold deserves recognition for teaching me various control techniques that are implemented in this work. His simple questions and generous understanding of incomplete answers were encouraging throughout the course of my research. His early support of L^AT_EX documents in the electrical engineering department was also a big plus.

Many thanks are in order for Phillip Curtiss who, despite being in the computer science department, agreed to be on a graduate committee full of electrical engineers (Sorry if we seem a little pompous - it's probably because we are). Themes from his data structures and discrete time simulation classes were employed heavily in the coding of this project. His coding knowledge, software advice, and computational insights were vital during development of the presented **working** software.

Curtis Link deserves recognition for 'volunteering' to be my freshman advisor and introducing me to the most basic engineering and MATLAB concepts. He's a good guy, and an unofficial member of my committee. I wonder if he'll ever retire or move to a place that has less snow... I suppose only time will tell.

Technical concepts presented by Matthew "not-pronounced-stage-car" Stajcar in his master's thesis provided a great starting point for this research. Without his previous work and presentation of long-term simulation methods, this project would've been much more difficult.

It should be acknowledged that this material is based upon work supported by the U.S. Department of Energy, Office of Science, Basic Energy Sciences, under Award Number DE-SC0012671.

The public GitHub repository (<https://github.com/thadhaines/PSLTDSim>) contains all source and validation code. Many test cases and extra code used in the research project are also collected there. A version of PSLTDSim has been uploaded to PyPI, but most recent versions will probably be on GitHub.

A personal thanks to Sarah Wolfe for being interested in, and actually following through on offers, to edit this document. Work on properly forming sentences where the thing does a thing to other things is a useful thought, but you know, not all thoughts turn into actions.

As of this writing, the presence of COVID-19 is growing across the globe. Much like some organized religions, it's responsible for death and destruction of cultural norms. However, also like some organized religions, the pandemic allows for positive human characteristics to shine through, be recognized, and hopefully, appreciated. The human species didn't manage to inhabit every part of this world by not being resilient. I'm optimistic we'll collectively survive this event to better deal with another one in the future. On a less heavy note, the closing of bars and a government issued shelter in place order are surprisingly conducive to finishing a thesis.

General acknowledgments for support, motivation, and inspiration go to family, friends, lovers, acquaintances, employers, clients, haters, burners, bartenders, musicians, drunks, addicts, street people, creatives, imagined entities, strangers, and anyone I didn't mention existing in this plane or otherwise. Specific words to describe what you mean to me are varied and numerous.

Musical acknowledgments are in order, as without music, there's really no telling how my life would be. Material from: Claude Debussy, Chet Baker, Miles Davis, Brian Eno, Aphex Twin, Radiohead, Shlohmo, Four Tet, Mount Kimbie, STRFKR, toyGuitar, Jaguwar, Thee Oh Sees, The Clash, Television, Neu!, Sonic Youth, Talking Heads, Portishead, Spoon, Max Richter, Shigeto, BadBadNotGood, Melt-Banana, Yo La Tango, Squarepusher, and Thievery Corporation (to name a few), provided an ever changing background score during the course of this work.

Finally, to incite a sense of curiosity, the quoted ‘nap enthusiast’ once reflected:

To create,
is to align yourself with creation.

Table of Contents

ABSTRACT	ii
DEDICATION	iii
ACKNOWLEDGMENTS	iv
TABLE OF CONTENTS	vi
LIST OF TABLES	xi
LIST OF FIGURES	xii
LIST OF EQUATIONS	xix
GLOSSARY OF TERMS	xx
1. Introduction	1
2. Electrical Engineering Background	3
2.1. <i>Power System Basics</i>	3
2.2. <i>Power Flow</i>	8
2.3. <i>The Swing Equation</i>	10
2.4. <i>Turbine Speed Governors</i>	11
2.5. <i>Automatic Generation Control</i>	12
2.6. <i>Reactive Power and Voltage Control</i>	13
3. Software Background	14
3.1. <i>Classical Transient Stability Simulation</i>	14
3.2. <i>Python</i>	14
3.2.1. Python Packages	14
3.2.2. Varieties of Python	15
3.2.3. Python Specific Data Types	15
3.3. <i>Advanced Message Queueing Protocol</i>	16
3.4. <i>Agent Based Modeling</i>	16
4. Software Tool	18
4.1. <i>Time-Sequenced Power Flows</i>	18
4.2. <i>Simulation Assumptions and Simplifications</i>	20
4.2.1. General Assumptions and Simplifications	20
4.2.2. Time Step Assumptions and Simplifications	20

4.2.3.	Combined System Frequency	21
4.2.4.	Distribution of Accelerating Power	22
4.2.5.	Governor models	22
4.2.5.1.	Casting Process for genericGov	23
4.3.	<i>General Software Explanation</i>	25
4.3.1.	Interprocess Communication	26
4.3.2.	Simulation Inputs	26
4.3.2.1.	PSLF Compatible Input	26
4.3.2.2.	Simulation Parameter Input (.py)	27
4.3.2.3.	Long-Term Dynamic Input (.ltd.py)	28
4.3.2.3.1.	Perturbance List	28
4.3.2.3.2.	Noise Agent Attribute	30
4.3.2.3.3.	Balancing Authority Dictionary	31
4.3.2.3.4.	Load Control Dictionary	31
4.3.2.3.5.	Generation Control Dictionary	33
4.3.2.3.6.	Governor Input Delay and Filtering Dictionary	34
4.3.2.3.7.	Governor Deadband Dictionary	35
4.3.2.3.8.	Definite Time Controller Dictionary	36
4.3.3.	Simulation Initialization	38
4.3.3.1.	Process Creation	38
4.3.3.2.	Mirror Initialization	38
4.3.3.3.	Dynamic Initialization Pre-Simulation Loop	40
4.3.4.	Simulation Loop	41
4.3.5.	Simulation Outputs	43
4.4.	<i>Software Validation</i>	44
4.4.1.	Validation Plots Explained	44
4.4.1.1.	Comparison Plot	45
4.4.1.2.	Difference Plot	45
4.4.1.3.	Percent Difference Plot	46
4.4.1.4.	Weighted Frequency Plot	47
4.4.2.	Six Machine System	48
4.4.2.1.	Simulated Scenario Descriptions	48
4.4.2.2.	Frequency Results	49
4.4.2.3.	Generator Mechanical Power Results	50
4.4.2.4.	Generator Real Power Results	51
4.4.2.5.	Voltage Magnitude Results	52

4.4.2.6.	Voltage Angle Results	54
4.4.2.7.	Generator Reactive Power Results	55
4.4.2.8.	Branch Current Results	56
4.4.2.9.	Branch Real Power Flow Results	58
4.4.2.10.	Branch Reactive Power Flow Results	59
4.4.2.11.	Six Machine Result Summary	60
4.4.3.	Mini WECC System	61
4.4.3.1.	Simulated Scenario Descriptions	61
4.4.3.2.	Frequency Results	63
4.4.3.3.	Generator Mechanical Power Results	64
4.4.3.4.	Generator Real Power Results	65
4.4.3.5.	Voltage Magnitude Results	66
4.4.3.6.	Voltage Angle Results	68
4.4.3.7.	Generator Reactive Power Results	69
4.4.3.8.	Branch Current Results	70
4.4.3.9.	Branch Real Power Flow Results	71
4.4.3.10.	Branch Reactive Power Flow Results	73
4.4.3.11.	Mini WECC Result Summary	74
4.4.4.	Mini WECC with PSS System	75
4.4.4.1.	Simulated Scenario Descriptions	75
4.4.4.2.	Frequency Results	75
4.4.4.3.	Generator Mechanical Power Results	76
4.4.4.4.	Generator Real Power Results	78
4.4.4.5.	Voltage Magnitude Results	79
4.4.4.6.	Voltage Angle Results	80
4.4.4.7.	Generator Reactive Power Results	81
4.4.4.8.	Branch Current Results	82
4.4.4.9.	Branch Real Power Flow Results	84
4.4.4.10.	Branch Reactive Power Flow Results	85
4.4.4.11.	Mini WECC with PSS Result Summary	86
4.4.5.	Full WECC System	87
4.4.5.1.	Load Step	88
4.4.6.	Validation Summary	90
5.	Engineering Applications	91
5.1.	<i>Simulated Events of Interest</i>	91
5.2.	<i>Relevant NERC Standards</i>	92

5.2.1.	BAL-001-2	92
5.2.2.	BAL-002-3	93
5.2.3.	BAL-003-1.1	94
5.2.4.	NERC Standard Summary	94
5.3.	<i>Simulated Balancing Authority Controls</i>	95
5.3.1.	Governor Deadbands	96
5.3.2.	Area Wide Governor Droops	97
5.3.3.	Automatic Generation Control	97
5.3.3.1.	Frequency Bias	97
5.3.3.2.	Integral of Area Control Error	98
5.3.3.3.	Conditional Area Control Error Summing	98
5.3.3.4.	Area Control Error Filtering	99
5.3.3.5.	Controlled Generators and Participation Factors	100
5.4.	<i>Governor Deadband Effect on Valve Travel</i>	101
5.4.1.	Governor Deadband Simulation Configuration	101
5.4.2.	Governor Deadband Simulation Results	102
5.5.	<i>Automatic Generation Control Tuning</i>	104
5.5.1.	AGC Simulation Configuration	104
5.5.2.	AGC Simulation Results	105
5.5.2.1.	Base Case Results	105
5.5.2.2.	AGC Tuning Results	106
5.5.2.3.	Noise and Deadband Simulation Results	108
5.5.2.4.	Conditional ACE Results	109
5.5.2.5.	BAAL Results	112
5.5.3.	AGC Result Summary	113
5.6.	<i>Long-Term Simulation with Shunt Control</i>	114
5.6.1.	Morning Peak Forecast Demand Simulation	114
5.6.1.1.	Morning Peak Forecast Demand Results	115
5.6.2.	Morning Peak Forecast Demand Result Summary	120
5.6.3.	Virtual Wind Ramp Simulation	121
5.6.3.1.	Virtual Wind Ramp Results	121
5.6.4.	Long-Term Simulation with Shunt Control Result Summary	127
5.7.	<i>Feed-Forward Governor Action</i>	128
5.7.1.	Feed-Forward Governor Simulation Configuration	128
5.7.2.	Feed-Forward Governor Simulation Results	130
5.8.	<i>Variable System Damping and Inertia</i>	131

5.8.1.	Damping and Inertia Simulation Configuration	131
5.8.2.	Damping and Inertia Simulation Results	132
6.	Conclusion	135
7.	Future Work	136
8.	Bibliography	137
9.	Six Machine System Details	142
10.	Code Examples	145
11.	Large Tables	153
12.	Detailed Valve Travel Results	155
13.	Additional AGC Results	160
14.	Additional BAAL Results	167

List of Tables

Table I: Generic governor model casting between LTD and PSDS.	24
Table II: Generic governor model parameters.	24
Table III: Perturbance agent identification options.	29
Table IV: Perturbance agent action options.	29
Table V: WECC machine model count and capacity.	87
Table VI: WECC governor models used in PSDS.	88
Table VII: WECC governor models used in PSLTDSim.	88
Table VIII: Tie-line bias AGC type ACE calculations.	99
Table IX: Total valve travel for various deadband scenarios.	103
Table X: Six machine bus table.	142
Table XI: Six machine line table.	142
Table XII: Six machine transformer table.	143
Table XIII: Six machine generator table.	143
Table XIV: Six machine load table.	143
Table XV: Six machine shunt table.	143
Table XVI: Balancing authority dictionary input information.	153
Table XVII: Simulation parameters dictionary input information.	154

List of Figures

Figure 1: General form of a modern power system.	3
Figure 2: Location and size of US electric generation.	4
Figure 3: US Interconnections.	5
Figure 4: Frequency relation to electric supply and demand.	6
Figure 5: Classic frequency and automatic control response.	7
Figure 6: Two buses with power flow between them.	8
Figure 7: Ideal governor droop action.	11
Figure 8: Time-sequenced power flows visualized.	18
Figure 9: CTS and TSPF data output comparison.	19
Figure 10: Block diagram of modified tgov1 model.	23
Figure 11: Block diagram of genericGov model.	23
Figure 12: High level software flow chart.	25
Figure 13: An example of a simParams dictionary.	27
Figure 14: Perturbation agent examples.	30
Figure 15: Noise agent creation example.	30
Figure 16: Load control agent dictionary definition example.	32
Figure 17: Generation control agent dictionary definition example.	33
Figure 18: Block diagram of delay block.	34
Figure 19: Governor delay dictionary definition example.	35
Figure 20: Governor deadband dictionary definition example.	36
Figure 21: Definite time controller dictionary definition example.	37
Figure 22: Simulation time step flowchart.	42
Figure 23: Validation plot examples.	44
Figure 24: Comparison plot examples.	45
Figure 25: Difference plot example.	45
Figure 26: Percent difference plot examples.	46
Figure 27: Frequency comparison plot example.	47
Figure 28: Six machine system.	48
Figure 29: Six machine load step system frequency comparison.	49
Figure 30: Six machine load ramp system frequency comparison.	49
Figure 31: Six machine generator trip system frequency comparison.	50
Figure 32: Six machine load step mechanical power comparison.	50
Figure 33: Six machine load ramp mechanical power comparison.	51
Figure 34: Six machine generator trip mechanical power comparison.	51
Figure 35: Six machine load step real power comparison.	52

Figure 36: Six machine load ramp real power comparison.	52
Figure 37: Six machine generator trip real power comparison.	52
Figure 38: Six machine load step voltage comparison.	53
Figure 39: Six machine load ramp voltage comparison.	53
Figure 40: Six machine generator trip voltage comparison.	54
Figure 41: Six machine load step voltage angle comparison.	54
Figure 42: Six machine load ramp voltage angle comparison.	55
Figure 43: Six machine generator trip voltage angle comparison.	55
Figure 44: Six machine load step reactive power comparison.	56
Figure 45: Six machine load ramp reactive power comparison.	56
Figure 46: Six machine generator trip reactive power comparison.	56
Figure 47: Six machine load step branch current flow comparison.	57
Figure 48: Six machine load ramp branch current flow comparison.	57
Figure 49: Six machine generator trip branch current flow comparison.	57
Figure 50: Six machine load step branch real power flow comparison.	58
Figure 51: Six machine load ramp branch real power flow comparison.	58
Figure 52: Six machine generator trip branch real power flow comparison.	59
Figure 53: Six machine load step branch reactive power flow comparison.	59
Figure 54: Six machine load ramp branch reactive power flow comparison.	60
Figure 55: Six machine generator trip branch reactive power flow comparison.	60
Figure 56: Mini WECC system.	62
Figure 57: Mini WECC load step system frequency comparison.	63
Figure 58: Mini WECC load ramp system frequency comparison.	63
Figure 59: Mini WECC generator trip system frequency comparison.	64
Figure 60: Mini WECC load step mechanical power comparison.	64
Figure 61: Mini WECC load ramp mechanical power comparison.	65
Figure 62: Mini WECC generator trip mechanical power comparison.	65
Figure 63: Mini WECC load step real power comparison.	66
Figure 64: Mini WECC load ramp real power comparison.	66
Figure 65: Mini WECC generator trip real power comparison.	66
Figure 66: Mini WECC load step voltage comparison.	67
Figure 67: Mini WECC load ramp voltage comparison.	67
Figure 68: Mini WECC generator trip voltage comparison.	67
Figure 69: Mini WECC load step voltage angle comparison.	68
Figure 70: Mini WECC load ramp voltage angle comparison.	68
Figure 71: Mini WECC generator trip voltage angle comparison.	69

Figure 72: Mini WECC load step reactive power comparison.	69
Figure 73: Mini WECC load ramp reactive power comparison.	70
Figure 74: Mini WECC generator trip reactive power comparison.	70
Figure 75: Mini WECC load step branch current flow comparison.	71
Figure 76: Mini WECC load ramp branch current flow comparison.	71
Figure 77: Mini WECC generator trip branch current flow comparison.	71
Figure 78: Mini WECC load step branch real power flow comparison.	72
Figure 79: Mini WECC load ramp branch real power flow comparison.	72
Figure 80: Mini WECC generator trip branch real power flow comparison.	72
Figure 81: Mini WECC load step branch reactive power flow comparison.	73
Figure 82: Mini WECC load ramp branch reactive power flow comparison.	73
Figure 83: Mini WECC generator trip branch reactive power flow comparison.	74
Figure 84: Mini WECC with PSS load step system frequency comparison.	76
Figure 85: Mini WECC with PSS load ramp system frequency comparison.	76
Figure 86: Mini WECC with PSS generator trip system frequency comparison.	76
Figure 87: Mini WECC with PSS load step mechanical power comparison.	77
Figure 88: Mini WECC with PSS load ramp mechanical power comparison.	77
Figure 89: Mini WECC with PSS generator trip mechanical power comparison.	77
Figure 90: Mini WECC with PSS load step real power comparison.	78
Figure 91: Mini WECC with PSS load ramp real power comparison.	78
Figure 92: Mini WECC with PSS generator trip real power comparison.	79
Figure 93: Mini WECC with PSS load step voltage comparison.	79
Figure 94: Mini WECC with PSS load ramp voltage comparison.	80
Figure 95: Mini WECC with PSS generator trip voltage comparison.	80
Figure 96: Mini WECC with PSS load step voltage angle comparison.	81
Figure 97: Mini WECC with PSS load ramp voltage angle comparison.	81
Figure 98: Mini WECC with PSS generator trip voltage angle comparison.	81
Figure 99: Mini WECC with PSS load step reactive power comparison.	82
Figure 100: Mini WECC with PSS load ramp reactive power comparison.	82
Figure 101: Mini WECC with PSS generator trip reactive power comparison.	82
Figure 102: Mini WECC with PSS load step branch current flow comparison.	83
Figure 103: Mini WECC with PSS load ramp branch current flow comparison.	83
Figure 104: Mini WECC with PSS generator trip branch current flow comparison.	83
Figure 105: Mini WECC with PSS load step branch real power flow comparison.	84
Figure 106: Mini WECC with PSS load ramp branch real power flow comparison.	84
Figure 107: Mini WECC with PSS generator trip branch real power flow comparison.	85

Figure 108: Mini WECC with PSS load step branch reactive power flow comparison.	85
Figure 110: Mini WECC with PSS generator trip branch reactive power flow comparison. .	85
Figure 109: Mini WECC with PSS load ramp branch reactive power flow comparison. . . .	86
Figure 111: Full WECC frequency comparison.	89
Figure 112: Full WECC absolute frequency difference.	89
Figure 113: Balancing authority ACE limit for different values of B.	93
Figure 114: Single sysBA dictionary definition.	95
Figure 115: Examples of available deadband action.	96
Figure 116: Block diagram of ACE calculation and manipulation.	97
Figure 117: Block diagrams of optional ACE filters.	99
Figure 118: Cumulative system change in load for governor deadband simulation.	101
Figure 119: System frequency comparison of different deadband scenarios.	102
Figure 120: Detail comparison of initial valve movement.	102
Figure 121: Area valve travel for homogeneous and non-homogeneous scenarios.	103
Figure 122: Random noise added to AGC simulations.	104
Figure 123: Frequency response to generation loss event in area 1.	105
Figure 124: Calculated BA values during generation loss event in area 1.	105
Figure 125: Calculated values during generation loss event in area 2.	106
Figure 126: AGC Frequency response to area 1 base case scenario.	106
Figure 127: Calculated BA values during area 1 AGC tuning.	107
Figure 128: Area 1 controlled generation response during AGC tuning.	107
Figure 129: Area 2 controlled generation response during AGC tuning.	107
Figure 130: AGC frequency response with noise and deadbands.	108
Figure 131: Calculated BA values with noise and deadbands.	108
Figure 132: Area 1 controlled generation response to noise and deadbands.	109
Figure 133: Area 2 controlled generation response to noise and deadbands.	109
Figure 134: Frequency response to event using TLB 0.	109
Figure 135: Calculated BA values during an event using TLB 0.	110
Figure 136: Area 1 controlled generation response to internal area event using TLB 0. . .	110
Figure 137: Area 2 controlled generation response to external area event using TLB 0. . .	110
Figure 138: Frequency response to event using TLB 4.	111
Figure 139: Calculated BA values during an event using TLB 4.	111
Figure 140: Area 1 controlled generation response to internal area event using TLB 4. . .	112
Figure 141: Area 1 controlled generation response to external area event using TLB 4. . .	112
Figure 142: Area 1 BAAL during internal area event using TLB 0.	113
Figure 143: Area 2 BAAL during external area event using TLB 0.	113

Figure 144: Normalized forecast and demand of parsed EIA data.	114
Figure 145: Changes in load caused by noise agent action during morning peak.	115
Figure 146: Morning peak area P_e and Load.	115
Figure 147: Morning peak area P_e and Load with noise and governor deadbands.	115
Figure 148: Morning peak system Frequency.	116
Figure 149: Morning peak system frequency with noise and governor deadbands.	116
Figure 150: Detail morning peak system frequency with noise and governor deadbands. . .	116
Figure 151: Morning peak calculated BA values.	117
Figure 152: Morning peak calculated BA values with noise and governor deadbands. . . .	117
Figure 153: Detail morning peak calculated BA values with noise and governor deadbands.	117
Figure 154: BAAL of area 1 during morning peak.	118
Figure 155: BAAL of area 2 during morning with noise and governor deadbands.	118
Figure 156: Morning peak system shunt bus voltage.	119
Figure 157: Morning peak system shunt bus voltage with noise and governor deadbands. .	119
Figure 158: Morning peak system shunt bus MVAR.	120
Figure 159: Morning peak system shunt bus MVAR with noise and governor deadbands. .	120
Figure 160: Changes in load caused by noise agent action during virtual wind ramp. . . .	121
Figure 161: Virtual wind ramp P_e distribution under ideal conditions.	122
Figure 162: Virtual wind ramp P_e distribution with noise and governor deadbands. . . .	122
Figure 163: Virtual wind ramp system frequency under ideal conditions.	122
Figure 164: Virtual wind ramp system frequency with noise and governor deadbands. . . .	123
Figure 165: Virtual wind ramp calculated BA values under ideal conditions.	123
Figure 166: Virtual wind ramp calculated BA values with noise and governor deadbands. .	123
Figure 167: Virtual wind ramp area P_e and P_{load} under ideal conditions.	124
Figure 168: Virtual wind ramp area P_e and P_{load} with noise and governor deadbands. . . .	124
Figure 169: Virtual wind ramp BAAL under ideal conditions.	124
Figure 170: Virtual wind ramp BAAL with noise and governor deadbands.	125
Figure 171: Virtual wind ramp shunt bus voltage under ideal conditions.	125
Figure 172: Virtual wind ramp shunt bus voltage with noise and governor deadbands. . .	125
Figure 173: Virtual wind ramp shunt bus MVAR under ideal conditions.	126
Figure 174: Virtual wind ramp shunt bus MVAR with noise and governor deadbands. . . .	126
Figure 175: Provided information of undesired governor response.	128
Figure 176: Long-term dynamic settings for feed-forward governor simulation.	129
Figure 177: Feed-forward governor frequency comparison.	130
Figure 178: Feed-forward governor electric power comparison.	130
Figure 179: Long-term dynamic settings for variable system inertia simulation.	131

Figure 180: Frequency effects of system damping.	132
Figure 181: Frequency effects of system inertia.	132
Figure 182: Governor response to varied system inertia.	133
Figure 183: Varied system inertia during simulation.	133
Figure 184: System frequency response to varying system inertia.	133
Figure 185: Dyd file used in six machine validations.	144
Figure 186: An example of a full .py simulation file.	146
Figure 187: Required .py file for external AGC event with conditional ACE.	147
Figure 188: Required .ltd file for external AGC event with conditional ACE.	148
Figure 189: Required .ltd file for forecast demand scenario with noise and deadbands.	152
Figure 190: Area 1 valve travel using no deadband.	155
Figure 191: Area 2 valve travel using no deadband.	155
Figure 192: Area 3 valve travel using no deadband.	155
Figure 193: Area 1 valve travel using a step deadband.	156
Figure 194: Area 2 valve travel using a step deadband.	156
Figure 195: Area 3 valve travel using a step deadband.	156
Figure 196: Area 1 valve travel using a no-step deadband.	157
Figure 197: Area 2 valve travel using a no-step deadband.	157
Figure 198: Area 3 valve travel using a no-step deadband.	157
Figure 199: Area 1 valve travel using a non-linear droop deadband.	158
Figure 200: Area 2 valve travel using a non-linear droop deadband.	158
Figure 201: Area 3 valve travel using a non-linear droop deadband.	158
Figure 202: Area 1 valve travel in a non-homogeneous deadband system.	159
Figure 203: Area 2 valve travel in a non-homogeneous deadband system.	159
Figure 204: Area 3 valve travel in a non-homogeneous deadband system.	159
Figure 205: Frequency response to generation loss event in area 2.	160
Figure 206: Area 1 controlled generation response to generation loss event in area 2.	160
Figure 207: Area 2 controlled generation response to generation loss event in area 2	160
Figure 208: AGC frequency response to area 2 base case scenario.	161
Figure 209: Calculated BA values during area 2 AGC tuning.	161
Figure 210: Area 1 controlled generation response during area 2 AGC tuning.	161
Figure 211: Area 2 controlled generation response during area 2 AGC tuning.	162
Figure 212: AGC frequency response with noise and deadbands.	162
Figure 213: Calculated BA values with noise and deadbands.	162
Figure 214: Area 1 controlled generation response to noise and deadbands.	163
Figure 215: Area 2 controlled generation response to noise and deadbands.	163

Figure 216: Frequency response to event using TLB 0.	163
Figure 217: Calculated BA values during an even using TLB 0.	164
Figure 218: Area 1 controlled generation response to external area event using TLB 0. . . .	164
Figure 219: Area 2 controlled generation response to internal area event using TLB 0. . . .	164
Figure 220: Frequency response to event using TLB 4.	165
Figure 221: Calculated BA values during an event using TLB 4.	165
Figure 222: Area 1 controlled generation response to external area event using TLB 4. . . .	165
Figure 223: Area 2 controlled generation response to internal area event using TLB 4. . . .	166
Figure 224: Morning peak minute average frequency.	167
Figure 225: Morning peak minute average frequency with deadbands and noise.	167
Figure 226: BAAL of area 2 during morning peak.	167
Figure 227: BAAL of area 2 during morning with noise and governor deadbands.	168
Figure 228: Virtual wind ramp minute average frequency.	168
Figure 229: Virtual wind ramp minute average frequency with deadbands and noise.	168
Figure 230: Area 2 virtual wind ramp BAAL under ideal conditions.	169
Figure 231: Area 2 virtual wind ramp BAAL with noise and governor deadbands.	169

List of Equations

Equation (1) Branch Current Flow	9
Equation (2) Branch Real Power Flow	9
Equation (3) Branch Reactive Power Flow	9
Equation (4) Per-Unit Swing Equation	10
Equation (5) Per-Unit Speed Deviation	10
Equation (6) Area Control Error	12
Equation (7) Area Frequency Response Characteristic	12
Equation (8) Total System Inertia	21
Equation (9) System Accelerating Power	21
Equation (10) Combined Swing Equation	21
Equation (11) System Frequency Integration	22
Equation (12) Distribution of Accelerating Power	22
Equation (13) Random Noise Injection	30
Equation (14) Data for Difference Plot	46
Equation (15) Absolute Average	46
Equation (16) Percent Difference	47
Equation (17) Weighted Frequency	47
Equation (18) Balancing Authority ACE Limit	92
Equation (19) Frequency Trigger Limit	93
Equation (20) BAAL Exceeded	93
Equation (21) Variable Frequency Bias	98

Glossary of Terms

Term	Definition
ABM	Agent Based Modeling
ABS	Agent Based Simulation
AC	Alternating Current
ACE	Area Control Error
AGC	Automatic Generation Control
AMQP	Advanced Message Queue Protocol
API	Application Programming Interface
BA	Balancing Authority
BES	Bulk Electrical System
CLR	Common Language Runtime
CTS	Classical Transient Stability
DACE	Distributed ACE
DTC	Definite Time Controller
EIA	United States Energy Information Administration
ERCOT	Electric Reliability Council of Texas
FERC	Federal Energy Regulatory Commission
FTL	Frequency Trigger Limit
GE	General Electric
Hz	Hertz, cycles per second
IACE	Integral of ACE
IC	Interchange
IPC	Interprocess Communication
IPY	IronPython
ISO	Independent Service Operator
J	Joule, Neton meters, Watt seconds
LFC	Load Frequency Control
LTD	Long-Term Dynamic
NERC	North American Electric Reliability Corporation

Term	Definition
ODE	Ordinary Differential Equation
P	Real Power
PI	Proportional and Integral
PMIO	PSLF Model Information Object
PSDS	PSLF Dynamic Subsystem
PSLF	Positive Sequence Load Flow
PSLTDSim	Power System Long-Term Dynamic Simulator
PSS	Power System Stabilizer
PST	Power System Toolbox
PU	Per-Unit
PY3	Python version 3.x
PyPI	Python Package Index
Q	Reactive power
RACE	Reported ACE
RTO	Regional Transmission Organization
SACE	Smoothed ACE
SI	International System of Units
TLB	Tie-Line Bias
TSPF	Time-Sequenced Power Flow
US	United States of America
VAR	Volt Amps Reactive
W	Watt, Joules per second
WECC	Western Electricity Coordinating Council

1. Introduction

Over the past 140 years, an increasing demand for electricity has forced power systems to evolve. This evolution has caused power systems to continuously grow larger and more complicated. The earliest power systems were often single generating stations designed to meet only local needs. Modern power systems involve many remote generating units connected together to serve a wide area of distributed customers. As most things do, these changes came about quite naturally. Additional generation stations were built and connected together to meet the ever increasing electric demand. As populations became more dispersed, areas of demand also became more dispersed and the use of high voltage transmission lines were used to link nearby power systems together.

The gradual connection of many remote power systems not only allowed for a pooling of resources, but with appropriate control, also offered increased system stability and reliability. Unfortunately, independent systems developed non-uniformly and created a complex network that requires intricate control and near constant attention. To further muddle matters, the aging North American electric power system is often pushed to its operating limits. This is due in part to, permitting or financial obstacles that may arise when attempting to add or update infrastructure to relieve system stress. Approved additions must be properly planned to handle a variety of environmental, economic, and social concerns. Well planned system modifications contribute long-term operational benefits while adhering to federal mandates. As such, to simply avoid costly and complicated new construction, various control schemes have been employed to better manage existing power system assets. However, advanced control requires advanced planning and testing.

Fortunately, we live in the future and can use computers to monitor, control, design, and simulate power systems in ways not previously possible. Networked system monitoring has enabled digital controls to act on remote data and provided a way to create time-stamped histories of events as they unfold. Computer software can help analyze system characteristics and predict issues arising from common contingencies. Dynamic computer simulations can further the study of various events. Typical dynamic simulation focus is on system reactions tens of seconds after

an event; while realistic recovery may require multiple minutes.

The engineering goal of this work is to simulate various frequency and voltage conditions that represent ‘long-term’ engineering problems, such as system recovery, daily load patterns, or wind ramp response, and provide customizable controls that can be used to simulate user control systems or simply explore possible system responses. A long-term dynamic simulation framework based on a time-sequenced power flow technique is believed to be capable of accomplishing such a task. Furthermore, the resulting open-source software may be expanded upon by future research for other related applications.

A simulation tool to accomplish the desired engineering goal does not yet exist. Therefore, a time-sequenced power flow simulation software program must be created and validated. Certain elements such as system model format and power-flow solver can be reused from previously existing software solutions, but features like automatic generation control, programmable logic controllers, and dynamic governor models must be created. Due to time limitations and engineering intuition, several modeling simplifications are employed.

Specific requirements have been identified to facilitate software development and ensure the end product can accomplish stated goals. General code structure must allow for modular expansion, custom procedure insertion, and large system scaling. The software must also be able to run full base case scenarios involving thousands of buses and generators. The finished code solution must be able to output data that can be validated against industry standard software. Output data should provide enough detail so that analysis of system control validity and efficiency can be performed.

This thesis provides a brief explanation of some basic concepts involved with the electrical engineering aspects of this work, as well as the computer science, or software aspects. The created software is explained and validated before engineering applications are introduced. Simulation results related to engineering applications are then presented and analyzed. Finally, conclusions are stated and future work suggested.

2. Electrical Engineering Background

2.1. Power System Basics

Before covering the physical structure of power systems, it is worth providing a general introduction to the regulatory and operational structure of the North American bulk electric system (BES). The BES, more commonly known as ‘the grid’, is regulated by multiple tiers of organizations. At the top of the United States (US) bureaucratic pyramid is the federally empowered Federal Energy Regulatory Commission (FERC), which regulates natural gas and hydroelectric power projects as well as the interstate transmission of natural gas, oil, and electricity [19]. With authority granted by FERC, the North American Electric Reliability Corporation (NERC), aims to assure the effective and efficient reduction of risks to the reliability and security of the BES [44]. NERC also develops and enforces reliability standards and provides training to industry personnel. Under FERC and NERC, exist a collection of regional transmission organizations (RTOs), independent service operators (ISOs), balancing authorities (BAs) and utilities. All entities have a specific purpose and area of operation. This research focuses on BA action. In general, BAs are responsible for balancing supply and demand in defined areas of a power system while adhering to federal standards [9].

In the most basic physical sense, a power system includes a source of electric generation connected to some kind of electric consumption, or load. Modern alternating current (AC) power systems often resemble Figure 1.




Figure 1: General form of a modern power system [30].

Power system loads are generally located wherever people feel the need to use electricity.

Generation is often placed in areas that have convenient natural resources nearby. This typically means that generation is built many miles away from large cities. Transformers and high-voltage transmission lines are used for efficient transfer of electric power over long distances. Figure 2 shows the location and relative size of electric generation in the US as of July 2019.




Figure 2: Location and size of US electric generation [10].

As expected, the northwest has large amounts of hydroelectric generation along major rivers. Solar generation is primarily located in southern states such as California and North Carolina. Wind generation can be found in and north of Texas towards the Great Lakes. Natural gas and coal are widely available in the eastern US. For interested Montanans, the four coal burning, steam generating, units at Colstrip are the large grey dot in the southeast corner of the state representing a nameplate capacity of 2,094 MW [14].

To help maintain stability, the North American grid is separated into interconnections,

which can be thought of as relative frequency zones. This means that the system frequency and phase can be different between two interconnections, but must be synchronous inside the interconnection. Figure 3 depicts the Western, Eastern, and Electric Reliability Counsel of Texas (ERCOT) interconnections that make up the US grid.




Figure 3: US Interconnections modified from [45].

The three main US interconnections are separated and distinguished by AC-DC-AC ties. The AC-DC-AC ties allow for a separation of frequency between interconnections. This is accomplished through a rectification and inverting process. Frequency content is removed when an AC signal is rectified into a DC signal. A new AC signal with any frequency and phase may be created through the inverting process. This rectification and inversion process allows power to be transported between the interconnections with acceptable losses.

The western interconnect, which includes most of Montana, has reliability standards that are created, monitored, and enforced by the Western Electricity Coordinating Council (WECC). A computer model of western interconnect, often referred to as the WECC, has been in use for over 20 years. As with any digital document that has been around for such a period of time, the model has become very large and some might say ‘cluttered’. The WECC model contains various unused, or outdated, information which makes use of the model difficult. Further details on the WECC model are presented in Section 4.4.5.

In any operational power system, electric demand is always met. However, demand is always changing. To this end, automatic controls have been developed to better manage certain aspects of the grid. Electrical frequency, synonymous with generator speed, is often used as an input to such automatic controls. There is a direct correlation between frequency and the balance of supply and demand. As Figure 4 so artfully depicts, if supply and demand are balanced, frequency remains static. If there is more demand than supply, frequency decreases. If the opposite is true, more supply than demand, frequency increases. Figure 4 illustrates that generated power must equal not only load, but also account for losses and any inter-regional interchange that may occur.




Figure 4: Frequency relation to electric supply and demand [51].

Most automatic control types within this thesis are distinguished by the time frame in which they operate. Figure 5 provides a classic frequency response to a loss of generation event with time scale classifications of automatic control responses.

The first automatic control, referred to as primary control, responds immediately after an event or perturbation and operates for tens of seconds. Primary control consists of turbine speed governors that act on deviations in system frequency from the nominal operating condition to stop frequency decline. Primary control occurs mostly during the arresting and rebound periods shown in Figure 5. Secondary control acts over tens of minutes during the recovery period. Secondary control is referred to as automatic generation control (AGC) or load frequency control




Figure 5: Classic frequency and automatic control response [6].

(LFC). AGC and LFC are often used interchangeably throughout the literature. This thesis uses AGC to refer to secondary control. AGC is configured by a BA to manage its area control error (ACE) which is a combination of interchange and frequency error. More information on AGC is presented in Sections 2.5 and 5.3.3. Additional operator defined automatic controls, such as re-laying, tap changing, and plant level control, may be classified into either time category based on defined settings.

System stability and reliability are of utmost importance in the electric power game. Most Americans rely on electricity for daily activities of widely varying consequence. In the simple economic view, if an electric system does not work, customers can not buy electricity, and there is absolutely no chance to make a profit. Power outages, or other system mis-operations, can be quite costly not only in a monetary sense, but can also result in the loss of life [26], [36]–[38], [61]. As such, simulation of a power system is required for planning additions or alterations. Simulations can be used to test and fine tune operational procedures like AGC settings or shunt switching schemes to ensure safe, economic, reliable, and correct operation. Power system simulation can also be used to explore events that may not be fully understood or occur rarely, but still require planned control measures.

2.2. Power Flow

The International System of Units (SI) measure for electric power is the watt W which has units of Joules/Second (J/s). Watts can be thought of as the rate at which electrical work is performed, or the instantaneous rate of energy transfer. Utility companies often charge for electric power by the amount of kW used per hour, or kilowatt hour kW h (3.6×10^6 J). For example, operating a 650 W computer power supply for one hour would require 0.65 kW h (2.34×10^3 J).

Most electric customers are only responsible for real, or active, power usage and are unaware of reactive power entirely. To simply state the difference between real power and reactive power: real power can be thought of as energy that does actual work, such as moving a conveyor belt, crushing rocks, or heating an element; reactive power can be thought of as exchange of energy to create and maintain electric and/or magnetic fields. In large power systems, supply and demand is often reported in terms of megawatts MW for real power P, and MVAR for reactive power Q.

In an AC system, the quantity of power flowing on a line (also referred to as a branch), between two buses can be found by first calculating the line current. Equation 1 shows that the line impedance $R+jX$, voltage magnitude V_x , and voltage angle δ_x of two connected buses are required to calculate line current I. For example, if a system has any two buses that can be related to Figure 6, the equations to calculate current, real power, and reactive power flow between them is shown in Equations 1-3 respectively.




Figure 6: Two buses with power flow between them.

$$I = \frac{V_S e^{j\delta_S} - V_R e^{j\delta_R}}{\sqrt{3}(R + jX)} \quad (1)$$

$$P = \sqrt{3}V_S|I| \cos(\delta_S - \angle I) \quad (2)$$

$$Q = \sqrt{3}V_S|I| \sin(\delta_S - \angle I) \quad (3)$$

It should be noted that the above equations are per-unit (PU). In practice, and thus simulation, all calculated values may prove useful. Megawatts on a line is a common way to describe real power flow, transmission lines and other equipment may be rated in current, and MVAR flow can be useful in shunt switching schemes to control bus voltage.

In reality, power flow is determined by physics of a system and measured with physical devices. In simulation, system characteristics are modeled and certain bus values are calculated using a power-flow computer program. The results from such a program, referred to as a power-flow solution, provide a steady state system operating condition based on certain known values. There are many methods to solve a power flow as [25] and [35] show, but detailed explanation is beyond the scope of this thesis. Suffice it to say that the power-flow problem involves system of non-linear equations that compute the voltage magnitude and phase angle at each bus in a power system under balanced three-phase steady state conditions [25]. Solutions often involve iteration until a set of tolerances, or ‘mis-match’, from an expected value is reached. Once a power-flow solution is achieved, Equations 1-3 can be used to find equipment loadings and line power flow anywhere in a system.

2.3. The Swing Equation

The swing equation is the basis of generator speed dynamics and is derived using Newton's second law. The equation got its name because it describes the swing in rotor angle during a disturbance [35]. Generator speed can be described by changes in rotor angle from a known reference. In the case of electric generators, frequency is directly related to turbine speed and either word is often used interchangeably in the time frame associated with long-term dynamics.

The PU swing equation, Equation 4, shows how acceleration of generator frequency $\dot{\omega}$ is directly related to the balance between mechanical power P_{mech} supplied by a generator, and electrical power P_{elec} required by a load.

$$\dot{\omega} = \frac{1}{2H} \left(\frac{P_{mech} - P_{elec}}{\omega} - D\Delta\omega \right) \quad (4)$$

It can be seen that machine inertia H has an inverse relationship to the magnitude of $\dot{\omega}$. The D term may be used to represent damping forces any time a generator deviates from synchronous speed [25] however, it is often assumed to be zero. Per-unit speed deviation,

$$\Delta\omega = \omega_{rated} - \omega, \quad (5)$$

is a simple calculation used to scale the damping term and used in other to-be-described applications. The nature of PU equations dictate that rated speed be equal to one. Historically, the current frequency ω was often ignored, or assumed to be equal to one. This decision was to make calculations easier since speed deviation in PU is often very small. Modern usage of the swing equation typically accounts for frequency effects.

In a steady state operating condition, P_{mech} is equal to P_{elec} and angular acceleration $\dot{\omega}$ is equal to zero. If there is an increase in required P_{elec} , then $\dot{\omega}$ is negative and rotor angle (generator frequency) declines. If P_{mech} is larger than P_{elec} , $\dot{\omega}$ is positive and frequency increases. Detailed derivations and discussions on the swing equation can be found in [2], [25], [35] or most any decent book related to power system dynamics.

2.4. Turbine Speed Governors

Turbine speed governors, often just governors, act to arrest frequency change by adjusting a generator's power reference setting. Governors are classified as primary control because of their typically fast response. While many detailed models of governors exist, almost all include a permanent droop or regulation constant R . The droop constant is a ratio of change in frequency to change in power. R is often written in percent or a decimal representing a percent and assumed to be negative. Figure 7 shows how R , the slope of the diagonal line, affects the resulting $\Delta\omega$ caused by change in power ΔP .




Figure 7: Ideal governor droop action [35].

Droop is a PU value so if a generator has a droop of 0.05, or 5%, then a 5% change in frequency would cause a 100% change in mechanical power output. Governor settings are dictated by FERC while NERC offers interconnection suggestions. The most common R is 5% for nearly all types of generators [52].

The input to a turbine speed governor is system frequency measured in Hertz Hz and reference power set point in MW. The output can be thought of as supplied mechanical power in MW. To prevent unnecessary control action, inputs to governors often have deadbands and may be delayed or filtered. Additional information on governor control is presented in Section 5.3.

2.5. Automatic Generation Control

Automatic generation control (AGC) is a form of secondary control that works to correct system frequency and area interchange error. AGC does this by calculating an area control error (ACE) that is then distributed to generation units under AGC control. The received AGC signals are used to adjust the generators mechanical power reference point. How AGC is distributed varies according to operator discretion so that operating or economic requirements are met.

NERC standards related to the management of ACE and requires ACE to be reported in a specific way [50]. As shown in Equation 6, reporting ACE (RACE) is composed of a variety of terms that may be relevant to electric operators.

$$RACE = (NI_A - NI_S) - 10B(F_A - F_S) - I_{ME} + I_{ATEC} \quad (6)$$

The difference between scheduled net interchange NI_S and actual net interchange NI_A is measured in MW. I_{ME} and I_{ATEC} , representing interchange meter error and area time error correction respectively, are also measured in MW. The difference between actual frequency F_A and scheduled frequency F_S is scaled by a frequency bias term $10B$ so that the result is also in MW. The 10 is required because B has units of MW/0.1Hz. By convention, positive $RACE$ indicates a general over-generation condition and negative $RACE$ is representative of an under-generation situation. Section 5.3.3 provides more details on AGC action.

For clarification, frequency bias B is not the same as area frequency response β [51]. B is an approximation of β used in ACE calculations and AGC action, while β is used to predict an area's response to perturbances. Equation 7 shows how β for an area may be calculated with N generators under droop control, where R_i is the droop of the i th generator [25].

$$\beta = \sum_i^N \frac{1}{R_i} \quad (7)$$

2.6. Reactive Power and Voltage Control

While AGC handles frequency and area interchange control, system voltage and reactive power must also be controlled. Various objectives must be met to maintain an efficient and reliable power system [35]. Bus voltage must be held near a known scheduled value so that system components operate in a predictable and safe way. Reactive power flow should be minimized to reduce reactive losses. Depending on loading conditions and generator VAR output, bus voltages and reactive power flow vary. A lack of available reactive power in a system can lead to lower bus voltages. Unchecked, declining voltages may lead to voltage collapse which can then lead to chain reactions of automatic tripping.

Voltage, unlike system frequency, is a local issue and must be resolved using local power system devices. Low voltage situations may be resolved by the addition of capacitive VARs and high voltage situations call for the removal of capacitive VARs. Alternatively, Inductive VARs may be used in the opposite manner. Generators whose primary purpose is to produce reactive power are called synchronous condensers. Due to the nature of some renewable energies, areas with large amounts of renewable generation may not be able to produce adequate VARs for voltage control. Thus, to meet operational objectives, synchronous generator and switchable shunt control becomes an important consideration in modern automatic control configurations.

3. Software Background

3.1. Classical Transient Stability Simulation

Classical transient stability (CTS) simulation is a simulation approach commonly used to test a power system's ability to remain stable after a large step perturbation such as a generator trip. The time frame CTS focuses on is milliseconds to tens of seconds, and as such, requires time steps of milliseconds. While this is an appropriate approach for relatively short periods of time, complicated modeling issues may lead to questionable results over the course of longer simulations.

General Electric's (GE's) Positive Sequence Load Flow (PSLF) is an industry standard power-flow solver and CTS simulation program. The continued development of PSLF has produced a large library of dynamic models and components for use in CTS simulation. PSLFs dynamic library has enabled a wide variety of system models to be created. For example, multiple full WECC base cases have been modeled in PSLF over the past 20 years and are continuously being updated. Certain versions of PSLF offer a Python 3 application programming interface (API) and a .NET API. Despite each API being at various levels of development and functionality, both offer a modern way to communicate with PSLF.

3.2. Python

Python is an interpreted high-level general purpose programming language that utilizes object oriented techniques and emphasizes code readability [34]. Guido Van Rossum first implemented a version of Python in December of 1989 [57]. Python is freely available and distributable for multiple computing platforms [54].

3.2.1. Python Packages

Software modules that expand the functionality of Python are referred to as packages and are freely available from the Python Package Index (PyPI). This work utilizes multiple packages to varying degrees, though SciPy and Pika are among the most heavily used. SciPy is a collection of packages that include NumPy for numerical computing and Matplotlib for MATLAB

style plotting [60]. Additionally, `scipy.signal.lsim` was used to solve state-space equations that are common in electrical engineering dynamics. To avoid rewriting well known integration routines, `scipy.integrate.solve_ivp` was used to perform Runge-Kutta integration of the swing equation to find system frequency. The Python implementation of the advanced message queuing protocol (AMQP) used for this project was Pika [20].

3.2.2. Varieties of Python

Python has gone through numerous versions over the course of development and has been ported and adapted according to need. IronPython (IPY) is an open-source .NET compatible version of Python written in C# [1] and is able to use the common language runtime (CLR) package required for properly interacting with the GE PSLF .NET library. As such IPY, more specifically 32-bit IPY, is used to interface with the PSLF .NET library. However, the most current stable IPY release is based off of Python 2.x and can only use Python packages compatible with 2.x. Python 3 (PY3) is ‘the future of Python’ and has many more maintained and useful community created packages. Some packages area available for both Python version 2 and 3, but many are not. As of this writing, the current version of Python is 3.8. A majority of project code was written using Python 3.7, but should continue to be compatible with future versions of PY3.

3.2.3. Python Specific Data Types

Python has various common data types found in other programming languages such as integer, string, list, and float. Python also has some unique data types. One unique data type is called a *dictionary* which is a collection of key value pairs. Dictionary keys are strings, and the value can be any other data type, including a dictionary. A benefit of using a dictionary is that it doesn’t matter ‘where’ in an object a certain data point is located, only that it exists somewhere in the object. The key value pair eliminates the need to focus on indexing lists or arrays as other programming languages may require. Additionally, native python methods allow for simple searching and iteration of dictionaries.

Another somewhat unique python data type is a tuple. Tuples are essentially the same as

lists, except defined using parenthesis instead of brackets and the data inside can not be changed in any way. While this may seem like a hindrance, it creates peace of mind when using tuples for important data references.

A powerful characteristic of Python is that everything is an object, and variables act as references, or pointers, to data. These Pythonic points were relied upon heavily during software development to make large collections of objects and references.

3.3. Advanced Message Queueing Protocol

Advanced message queueing protocol (AMQP) is a software messaging protocol that can be used for interprocess communication (IPC). The specific application of AMQP in this case was to enable a PY3 process to communicate with an IPY process on a Windows based machine. The idea behind AMQP is that of a virtual 'broker' which receives messages from various processes and places them into specific named queues. The named queues are accessed by other processes that check for, and receive, any queued messages.

It should be noted that Erlang was required to allow use of RabbitMQ, and the PY3 and IPY Pika packages were required so that Python could use AMQP. While detailed descriptions of these softwares is beyond the scope of this research: Erlang is an open source programming language and runtime environment, RabbitMQ is an open source AMQP broker software, and Pika is a Python package that works with RabbitMQ. The correct installation of these software packages is necessary for the created research software to function.

3.4. Agent Based Modeling

Agent Based Modeling (ABM), or Agent Based Simulation (ABS), is oriented around the idea that any situation can be described by agents in an environment, and a definition of agent-to-agent and agent-to-environment interactions [55]. The ABM coding style lends itself towards modular coding and natural expandability as each agent class may have inherited methods and variable characteristics. As an example, [3] used an ABM approach to test the efficiency of differing airplane boarding methods. Passengers were treated as agents interacting with each

other and the airplane environment. Each passenger agent may have had different characteristics, but performed a similar actions each simulation time step. ABM is applied to the coding of this project in that a power system acts as the environment, and all power system objects, such as buses, loads, and generators, are treated as agents.

Each time step, agents may perform their *step* method that executes code unique to the specific agent, but generally the same among agent types. For example, a timer agent step method may include checking a specified value and incrementing an accumulator according to a logic operation. If the accumulator becomes larger than a set threshold value, the timer may raise an activation flag. Agent action is meant to be direct and generic so that agents can be reused and nested inside other agents. Continuing the example, the timer agent may be nested inside another agent that checks the timers activation flags each step and takes action depending on the returned status. Actions can be arranged into a sequence of agent steps in a discrete time simulation, and then repeated ad infinitum. The idea of sequencing agent steps can be applied to systems of nearly any size and composition as long as agents have a step function and can reference other agents inside the environment.

4. Software Tool

The newly created software tool for this research was named PSLTDSim (Power System Long-Term Dynamic Simulator). Python was the code language of choice, and both PY3 and IPY processes are created during simulation. PSLF and AMQP also play integral roles in PSLTDSim. The basic idea behind PSLTDSim is to use time-sequenced power flows and external dynamic calculations to simulate long-term dynamic (LTD) power system behavior. Various engineering simplifications and assumptions are employed by PSLTDSim.

This chapter describes what time-sequenced power flows are, what PSLTDSim assumes or simplifies, and what PSLTDSim actually does. Software validations using PSLF simulation output as a reference are presented and discussed at the end of this chapter.

4.1. Time-Sequenced Power Flows

The left side of Figure 8 is a visual representation of a single power-flow solution. The power-flow solution can be thought of as a snapshot of steady state system operation. A period of steady state system operation could be imagined by repeating this single power-flow solution in a time sequence. Dynamic system behavior could be realized if small changes are made to the power-flow problem inputs and the ensuing power-flow solution converges. The right side of Figure 8 illustrates the idea of time-sequenced power flow (TSPF) as a collection of slightly changing power-flow solutions. The TSPF method for dynamic simulation involves performing dynamic modeling calculations outside of, or inbetween, each power-flow solution.




Figure 8: Time-sequenced power flows visualized.

Differences between TSPF and CTS simulation techniques stem from the time frame of

simulation focus and differing dynamic calculations. TSPF is focused on long-term events that take place over the course of minutes to hours. CTS simulation focuses on events that are tens of seconds in duration. This difference in focus leads to each method utilizing a different appropriate time step. A TSPF time step may be 0.5 to 1 seconds while CTS uses sub-cycle time-steps in the millisecond range.

Calculations of CTS simulation include generator dynamics that are aggregated and simplified in TSPF. Each method starts with a power-flow solution, but CTS simulation performs back calculations to set initial states of various dynamic models. Future CTS states, and resulting system behaviors, are dictated by dynamic model interactions which may go unstable. TSPF also uses dynamic models, but updated values are sent to a power-flow solver; and the power-flow solution provides new steady state system values. These differences create output data that is of different resolutions and captures slightly different system characteristics. Figure 9 shows a comparison of CTS and TSPF data.




Figure 9: CTS and TSPF data output comparison.

The circles represent data from a TSPF simulation while dots show down-sampled data from PSLFs dynamic subsystem (PSDS) simulation. The two data sets are not the same during oscillatory behavior, but seem to match at steady state conditions. In the provided plot, TSPF data seems to follow the center of oscillation from the CTS simulation. This ‘oscillation averaging’ behavior was found to be common in TSPF results.

4.2. Simulation Assumptions and Simplifications

Numerous assumptions and simplifications were made due to fundamental differences between TSPF and CTS simulation. This section details such assumptions and simplifications and provides key TSPF equations.

4.2.1. General Assumptions and Simplifications

The focus of PSLTDSim is on the long-term operation of power systems. Since a power-flow solution is a stable steady state operating condition, it is assumed that the system of study is stable in the transient stability sense, and remains stable, for the entirety of the simulation. Other software packages should be used if transient stability is in question.

In general, system responses to large step type contingencies are not the focus of PSLTDSim. Instead, a more suitable event type is in the form of ramps, or repeated small step perturbances. Because of the more ‘gentle’ system scenarios involved with ramps, power system stabilizers (PSS) were not modeled. Further, it is assumed that PSS time constants are too small to be adequately represented given the time step associated with TSPF.

Further assumptions include ideal generator excitors that can always maintain a given generator reference voltage. Modern excitors are assumed to be fast enough to hold reference voltages to small perturbances in the long-term. Despite the ideal reference voltage assumption, machine VAR limits **are** enforced according to model parameters. Should the need arise, future work can be done to incorporate any additional, or alternative modeling.

4.2.2. Time Step Assumptions and Simplifications

Multiple assumptions can be made concerning power system behavior when a time step of one second is used. The order of magnitude time step difference between CTS and TSPF allows models created for CTS simulations to be simplified for use in TSPF. Intermachine oscillations were ignored since subsynchronous resonances are sub-second and the time resolution of TSPF is not great enough to capture these phenomena. Additionally, in the long-term, these effects are minor when the system is stable. Without the need for subsynchronous characteristics,

generator modeling was greatly simplified. The only details required for a machine model are MW cap, machine MVA base, and machine inertia.

To further simplify generator modeling, all machines share a single system frequency that is calculated by a combined swing equation. The following two Sections explain how the combined swing equation is used in PSLTDSim. Governor models were also simplified. Section 4.2.5 explains the how PSLTDSim models governors.

4.2.3. Combined System Frequency

Instead of a frequency being calculated for each generator or bus, a single combined swing equation is used to model only one combined system frequency. This technique requires a known total system inertia H_{sys} and the total system acceleration power $P_{acc,sys}$. In a system with N generators, H_{sys} is calculated from each individual machine's inertia as

$$H_{sys} = \sum_{i=1}^N H_{PU,i} M_{base,i}. \quad (8)$$

In a system with N generators, total system accelerating power is calculated as

$$P_{acc,sys} = \sum_{i=1}^N P_{m,i} - \sum_{i=1}^N P_{e,i} - \sum \Delta P_{pert}, \quad (9)$$

where $P_{m,i}$ is mechanical power and $P_{e,i}$ is electrical power of the i th generator and any system power injections, or perturbances, are accounted for in the $\sum \Delta P_{pert}$ term.

The combined swing equation, shown in Equation 10, uses $P_{acc,sys}$ and H_{sys} to calculate $\dot{\omega}_{sys}$. For completeness, a damping term $D_{sys}\Delta\omega$ is included in Equation 10, but as Equation 4, D_{sys} is often set to zero while $\Delta\omega_{sys}$ is calculated using Equation 5 with ω_{sys} replacing ω . Equation 11 shows that after integrating with time step t_s , $\dot{\omega}_{sys}$ leads to system frequency ω_{sys} .

$$\dot{\omega}_{sys} = \frac{1}{2H_{sys}} \left(\frac{P_{acc,sys}}{\omega_{sys}} - D_{sys}\Delta\omega_{sys} \right) \quad (10)$$

$$\omega_{sys} = \int_0^{t_s} \dot{\omega}_{sys} \quad (11)$$

4.2.4. Distribution of Accelerating Power

While system frequency can be calculated using total system accelerating power, to properly ‘seed’ the next power flow, each generator participating in the system inertial response must account for a portion of accelerating power absorption. The specific amount each generator absorbs is based on machine inertia. Equation 12 shows how the next electric power estimate $P_{e,EST,i}$ is created for generator i .

$$P_{e,EST,i} = P_{e,i} - P_{acc,sys} \left(\frac{H_i}{H_{sys}} \right) \quad (12)$$

Once all accelerating power is distributed to inertial responding generators, the new $P_{e,EST}$ value for each generator is used to seed a power flow. If the MW difference between resulting power supplied by the slack generator and estimated power output is larger than the set slack tolerance, the difference is redistributed as $P_{acc,sys}$ according to Equation 12 until slack tolerance is met, or a maximum number of iterations take place. Once the slack tolerance is met, the power-flow solution is accepted as the current state of the system under study.

This method of reallocation ensures the validity of a generation dispatch because in a power-flow solver such as PSLF, any difference between the dispatched MW of generation, and the aggregate MW consumption of all loads and losses is allocated to the designated slack generator. Therefore, if the slack generator responds as predicted, it is assumed all other generators have also responded as predicted.

4.2.5. Governor models

Long-term dynamic models do not require the detail of a full transient simulation model. For software validation purposes, a *tgov1* governor model was created as it appears in the PSLF documentation. This particular governor model was selected due to simplicity, and was later expanded upon to include an optional deadband and filtered input delay. The block diagram for the modified *tgov1* governor is shown in Figure 10. Blocks with a * next to them indicate they are optional, and only inserted into the model if user defined.




Figure 10: Block diagram of modified tgov1 model.

A slightly more generic governor was created based off the governor model used in Power System Toolbox (PST). This generic model, referred to as *genericGov*, is shown in Figure 11. The genericGov follows the time constant naming convention of the PST governor and includes the same optional blocks added to the modified tgov1 model.




Figure 11: Block diagram of genericGov model.

4.2.5.1. Casting Process for genericGov

Modeling all PSDS governors would be a rather large task. Un-modeled governors encountered in the PSDS dynamic parameters file, referred to as a dyd file, were cast to a generic-Gov model based on assumed governor type. Table I shows the relation of PSDS model types to assumed governor setting type.

Table I: Generic governor model casting between LTD and PSDS.

genericGov	Steam	Hydro	Gas
PSDS	ccbt1	g2wscc	ggov1
	gast	hyg3	ggov3
	w2301	hygov4	gpwsc
	ieeeg3	hygov	
	ieeeg1	hygovr	
		pidgov	

Universal governor settings, such as permanent droop and MW cap values are collected from the dyd file and used as R and MW_{cap} respectively. The particular time constants for each model were selected according to typical settings associated with prime mover type that a PSDS model is assumed to represent. Table II lists the time constants used for each genericGov model type.

Table II: Generic governor model parameters.

Parameter	Steam	Hydro	Gas
Ts	0.04	0.40	0.50
Tc	0.20	45.00	10.00
T3	0.00	5.00	4.00
T4	1.50	-1.00	0.00
T5	5.00	0.50	1.00

4.3. General Software Explanation

This section provides an explanation of the Power System Long-Term Dynamic Simulator (PSLTDSim). A flow chart showing a general overview of simulation action is shown in Figure 12. A simulation begins with user input of simulation specifications to PSLTDSim. The user input is then used to initialize the required simulation environment by PSLTDSim. The general simulation loop includes performing dynamic calculations and executing any perturbances which are then transferred to PSLF. A power-flow solution is then calculated by PSLF and relevant data sent back to PSLTDSim for logging. Various simulation variables are then checked to verify if the simulation loop is to continue or end. Once the simulation is complete, data is output and plots may be generated for the user to analyze.




Figure 12: High level software flow chart.

4.3.1. Interprocess Communication

A process is another name for an instance of a running computer program. It is common for a computer program to run as a single process, however this is not always the case and not how PSLTDSim operates. Since processes are independent from each other, they do not share a memory space [22]. This effectively means that for two processes to share data, some kind of interprocess communication (IPC) must be utilized.

Due to the current state of the GE Python 3 API, Ironpython (IPY) was required for functional PSLF software communication. Unfortunately, IPY is based on Python 2 and does not have packages necessary for numerical computation that Python 3 (PY3) possesses. The solution to these issues was to create a software that has an IPY process and PY3 process that communicate to each other via AMQP. The IPY process acts as a ‘middle man’ between PY3 and PSLF. Newly calculated dynamic values from PY3 must be sent to PSLF via IPY, and after each new power-flow solution, PSLF values must be sent to PY3. This cycle continues as long as simulation is required. While the described AMQP solution has been shown to work, it is worth noting that message handling typically accounts for about one half of all simulation time, and sometimes more in larger cases.

4.3.2. Simulation Inputs

As with any simulation software, PSLTDSim requires specific inputs to operate correctly. Some required input is the same as that used by PSLF, while other input is Python based. Both types of inputs are described in this subsection.

4.3.2.1. PSLF Compatible Input

The power system model input used by PSLTDSim is the same binary file used by, and generated from, PSLF. The system model file, referred to as a sav file, contains topological and parametric data required to execute a power-flow solution. The use of this input file is due to the reliance of PSLTDSim on the power-flow solver included with PSLF. Python system dynamics are created based on the .dyd text files also used by PSLF. Information on creating .sav or .dyd

files is beyond the scope of this text, but may be found in [23].

4.3.2.2. Simulation Parameter Input (.py)

Simulation parameter input is entered in a standard python .py file. Most simulation parameter input is collected in a Python dictionary named simParams. An example of the simParams dictionary defined inside the .py file is shown in Figure 13.

```

1  simParams = {
2      'timeStep': 1.0, # seconds
3      'endTime': 60.0*8, # seconds
4      'slackTol': 1, # MW
5      'PY3msgGroup' : 3, # number of Agent msgs per AMQP msg
6      'IPYmsgGroup' : 60, # number of Agent msgs per AMQP msg
7      'Hinput' : 0.0, # MW*sec of entire system, if !> 0.0, will be calculated in code
8      'Dsys' : 0.0, # Damping
9      'fBase' : 60.0, # System F base in Hertz
10     'freqEffects' : True, # w in swing equation will not be assumed 1 if true
11     'assumedV' : 'Vsched', # assumed voltage - either Vsched or Vinit
12     # Mathematical Options
13     'integrationMethod' : 'rk45',
14     # Data Export Parameters
15     'fileDirectory' : "\\\delme\\\200109-delayScenario1\\", # relative path from cwd
16     'fileName' : 'SixMachineDelayStep1', # Case name in plots
17     'exportFinalMirror': 1, # Export mirror with all data
18     'exportMat': 1, # if IPY: requires exportDict == 1 to work
19     'exportDict' : 0, # when using python 3 no need to export dicts.
20     'logBranch' : True,
21 }
```

Figure 13: An example of a simParams dictionary.

The simParams dictionary contains information required for the simulation to operate, such as time step, end time, base frequency, and slack tolerance. There are also parameters that alter how the simulation operates, such as integration method, inclusion of frequency effects, and how system inertia is calculated. Information related to data collection or export is also included in the simParams dictionary such as whether to log branch information or where the resultant data will be placed and what it will be named. Examples of valid dictionary keys, types of data,

units of input, and a brief explanation is shown in Table XVII located in Appendix 11.

In addition to the simParams dictionary, simulation notes, absolute file paths to the desired .sav and .ltd.py file are also defined in this .py file. Dynamic input in the form of .dyd files are defined in a list to allow for using more than one .dyd file. The dynamic model overwriting that this feature was meant to incorporate has not been fully implemented as of this writing. An example of a valid simulation parameter input .py is shown in Appendix 10 as Figure 186.

4.3.2.3. Long-Term Dynamic Input (.ltd.py)

The required .ltd.py file contains user defined objects related specifically to simulated events and control action. Further, this file is the ideal place for adding additional user input if the need should arise in future software development. Code in the .ltd.py file is standard Python and involves initializing objects attached to a *mirror* object. The mirror object is what PSLTD-Sim calls the total power system model. A description of the various objects that can be attached to the mirror is presented in the following sections. Most topics introduced are described completely, however, some options are more complex and described in later sections.

4.3.2.3.1. Perturbance List

The only list defined in the .ltd.py file is for entering simulation perturbances (often also referred to as contingencies or events). The list of single quoted strings describing system perturbances is defined as `mirror.sysPerturbances`. Common perturbances are changes in operating state and power, however, any value in the target agents current value dictionary may be changed. The format of the string is specific to agent type and perturbation, but strings follow the general format of 'Agent Identification : Perturbation Description'. Table III shows the format for the agent identification part of the perturbation string. Optional parameters are shown in brackets. If no ID is specified the first agent found with matching bus values will be chosen.

Table III: Perturbation agent identification options.

Agent Type	Identification Parameters	
load	Bus Number	[ID]
shunt	Bus Number	[ID]
gen	Bus Number	[ID]
branch	From Bus Number	To Bus Number [Circuit ID]

Table IV describes the various parameters used to specify the action of the perturbation agent in the 'Pertrubance Description'. The three valid options for the 'Step Type' and 'Ramp Type' field are `abs`, `rel`, and `per`. To make an absolute change to the new value, the `abs` type should be selected. To alter the target parameter by a relative value, the `rel` option should be used. If a percent change is desired, the `per` type should be used.

Table IV: Perturbation agent action options.

Type	Settings			
step	Target Parameter	Action Time	New Value	Step Type
ramp	Target Parameter	Start Time	Ramp Duration	New Value
				Ramp Type

Figure 14 shows various examples of valid perturbation agent definitions. Double quoted strings may be used to clarify perturbation descriptions. It should be noted that the target parameter is case sensitive. Additionally, if stepping a governed generator, both the mechanical power and power reference variables should be changed as shown in line 8 and 9 of Figure 14.

```

1 # Perturbation Examples
2 mirror.sysPerturbances = [
3     'gen 27 : step St 2 0',           # Set gen 27 status to 0 at t=2
4     'branch 7 8 2 : step St 10 0 abs', # Trip branch between bus 7 and 8 with ckID=2
5     'load 26 : ramp P 2 40 400 rel',   # ramp load 26 P up 400MW over t=2-42 seconds
6     'load 9 : "Type" ramp "Target" P "startTime" 2 "RAtime" 40 "RAval" -5 "RAtype" per',
7     'shunt 9 4 : step St 32 1',       # Step shunt id 4 on bus 9 on at t=32
8     'gen 62 : step Pm 2 -1500 rel',   # Step gen Pm down 1500 MW at t=2
9     'gen 62 : step Pref 2 -1500 rel', # Step gen Pref down 1500 MW at t=2
10    ]

```

Figure 14: Perturbation agent examples.

4.3.2.3.2. Noise Agent Attribute

A random noise agent was created to add random noise to all system loads. The noise agent may be useful for Monte Carlo studies, or for studies involving nonlinearities such as dead-bands. The noise agent is created in the .ltd.py file by defining the `mirror.NoiseAgent` attribute with the associated agent. Figure 15 shows an example of a noise agent being attached to a system mirror. The input arguments are: system mirror reference, percent noise to be added, a boolean value dictating random walk behavior, delay before noise is added, and the random number generator seed value.

```

1 # Noise Agent Creation
2 mirror.NoiseAgent = ltd.perturbation.LoadNoiseAgent(mirror, 0.05, walk=True, delay=0,
→ damping=0, seed=11)

```

Figure 15: Noise agent creation example.

If a noise agent is defined, noise is injected at every time step into each load $P_{L,i}$ in the system according to

$$P_{L,i}(t) = P_{L,i}(t-1)[1 \pm N_Z Rand_i + D_{nz} \Delta \omega] \quad (13)$$

where N_Z represents the maximum amount of random noise to inject as a percent, $Rand_i$ is a randomly generated number between 0 and 1 inclusive, D_{nz} is the user input damping value, and $\Delta\omega$ is calculated according to Equation 5. The decision to add or subtract noise is chosen by a unique randomly generated number. As described in [63], Equation 13 creates random walk behavior in load that is representative of real power systems. If random walk behavior is not desired, the walk input argument may be set to False and the scheduled load value is always used as $P_{L,i}(t - 1)$. Only mirror reference and percent of desired noise is required for noise agent creation. If no additional arguments are provided, default values for walk, delay, damping and seed are set to False, 0, 0, and 42 respectively.

4.3.2.3.3. Balancing Authority Dictionary

The mirror.sysBA dictionary is defined in the .ltd.py file and is used to configure BA agents. Individual BA dictionaries are nested inside the mirror.sysBA dictionary. The information entered in each nested dictionary describes how that particular BA acts on the specified area. Additional information on BA AGC options and action is presented in Section 5.3.3. Examples of BA parameterization are shown in Figures 188 and 189 of Appendix 10. A description of each possible field is described in Table XVI located in Appendix 11.

4.3.2.3.4. Load Control Dictionary

To simplify changing all area loads according to a known demand schedule, a load control agent may be defined in the .ltd.py file. Similar to the balancing authority dictionary, each agent is defined as a named dictionary inside a the mirror.sysLoadControl dictionary. The load control agent requires area number, start time, time scale, and a list of tuples for demand information. Specific BA demand data can easily be acquired via the United States Energy Information Administration (EIA) website and saved as a .csv file. A script was written to parse and display demand changes over time as a relative percent change so that real load patterns could be applied to test systems of differing scale. An example of a single area load control agent is shown in Figure 16.

```

1 mirror.sysLoadControl = {
2     'testSystem' : {
3         'Area': 2,
4         'startTime' : 2,
5         'timeScale' : 10,
6         'rampType' : 'per', # relative percent change
7         # Data from: 12/11/2019 PACE
8         'demand' : [
9             #(time , Percent change from previous value)
10            (0, 0.000),
11            (1, 3.675),
12            (2, 6.474),
13            (3, 3.770),
14        ] , # end of demand tuple list
15    },# end of testSystem definition
16 }# end of sysLoadControl dictionary

```

Figure 16: Load control agent dictionary definition example.

The list of tuples named ‘demand’ defines the desired load change over time. The first value in each tuple is assumed to be a time value and the second number is a percent change value. The entered time value is scaled by the ‘timeScale’ value. It is assumed that both values in the first entry are always zero since there can be no relative change from negative time.

Relative percent ramps are used to alter load value between each entry. For example, if the load control agent shown in Figure 16 was used in a simulation, ramps would be created for each load in area 2 that increases load by 3.675% between time 2 and 10, 6.474% between time 10 and 20, and 3.770% between time 20 and 30. In total, a 100 MW load would be 114.548 MW after all ramps executed. The relative percent is based off the value of each load at start of each ramp. This method of relative percent changing allows for other perturbances, such as noise, to be applied to the same load without control conflicts. Alternative ramp types may be employed by changing the ’rampType’ parameter, but are not created as of this writing. It should be noted that the first ramp starts at ‘startTime’, but all other ramps begin according to the calculated scaled time schedule. Additionally, loads that are off at system initialization (status 0 at time 0)

are ignored.

4.3.2.3.5. Generation Control Dictionary

To manipulate generation in the same way a load control agent manipulates load, a generation control agent may be defined in the .ltd.py file. The definition of a generation control agent is very similar to the definition of a load control agent by design, however, differences do exist. Generation control agents are defined in the dictionary named mirror.sysGenerationControl, have a list of strings detailing control generators, and have a time value tuple list named ‘forcast’. While the forecast misspelling was unintentional, and can be changed, time has proven it to be a minor detail. Other parameters inside the generation control agent definition (such as area, start time, time scale, and ramp type) function exactly the same as the load control agent. Forecast data is again collected from the EIA website and parsed in the same manner as demand data. Figure 17 shows an example of a generation control agent definition.

```

1 mirror.sysGenerationControl = {
2     'testSystem' : {
3         'Area': 2,
4         'startTime' : 2,
5         'timeScale' : 10,
6         'rampType' : 'per', # relative percent change
7         'CtrlGens': [
8             "gen 3 : 0.25",
9             "gen 4 : 0.75",
10            ],
11        # Data from: 12/11/2019 PACE
12        'forcast' : [
13            #(time , Precent change from previous value)
14            (0, 0.000),
15            (1, 5.137),
16            (2, 6.098),
17            (3, 4.471),
18            ],# end of forcast tuple list
19        }, #end of testSystem def
20    }# end of sysLoadControl dictionary

```

Figure 17: Generation control agent dictionary definition example.

The main difference between load and generation control agents is the addition of the ‘CtrlGens’ list of strings. While the load control agent distributes any changes to all loads equally, a generation control agent dispatches a specific portion of MW change to specific generators. The ‘CtrlGens’ list dictates which generators receive how much of a dispatch. Each string inside the ‘CtrlGens’ list is of the form: ”gen BusNumber ID : Participation Factor” where ID is optional. If ID is not defined, as shown in Figure 17, the first generator on the given bus will be controlled. The participation factor is used to distribute the total requested MW change.

For example, if an area is generating 100 MW at time 0, the total requested area generation change by time 10 would be 5.137 MW. The generator on bus 3 would increase 1.28 MW while the generator on bus 4 would increase 3.85 MW. If a controlled generator has a governor, governor reference will be adjusted instead of mechanical power. The participation factor for all listed generators should always sum to 1.0 or improper distribution **will** occur. It should be noted that not all generation must be controlled for proper percent change of total area output power, however, if a controlled machine hits a generation limit, excess changes are ignored.

Relative percent ramps are used to control generators in the same way as load so that a BA can also act on generators under generation control, however, this functionality is untested as of this writing.

4.3.2.3.6. Governor Input Delay and Filtering Dictionary

The inputs to modeled governors may be delayed, filtered, and gained using the Laplace domain block shown in Figure 18. If delay is not divisible by the simulation time step, rounding will occur.




Figure 18: Block diagram of delay block.

To modify a governor model with a delay block, parameters may be entered in the governor delay dictionary `mirror.govDelay`. Like previously described dictionaries, this is located in

the .ltd.py file. Figure 19 shows an example of a valid delay dictionary that affects the governor of the generator on bus 3. Note that while genId is optional, if not specified, the first generator found on the specified bus is used.

```

1 mirror.govDelay ={
2     'delaygen3' : {
3         'genBus' : 3,
4         'genID' : None, # optional
5         # (delay parameter, filter time constant, optional gain)
6         'wDelay' : (40,30),
7         'PrefDelay' : (10, 0),
8     }, # end of 'delaygen3' definition
9 }# end of govDelay dictionary

```

Figure 19: Governor delay dictionary definition example.

Tuples are used to enter delay block parameters. Using Figure 10 as reference, the ‘wDelay’ tuple contains settings for D_A , T_A , and K_A respectively. Likewise, the ‘PrefDelay’ tuple contains D_B , T_B , and K_B . If the tuple contains three entries, the third is assigned to the optional gain associated with each block, otherwise K_x is one.

4.3.2.3.7. Governor Deadband Dictionary

A BA agent may be used to set area wide deadbands, but it is also possible to specify a single deadband for any governed generator. Individual governor deadband dictionaries are defined inside the mirror.govDeadBand dictionary in the .ltd.py file. Settings in each governor deadband dictionary will override any deadband settings specified by the BA dictionary. Figure 20 shows three examples of valid governor deadband definitions.

```

1 mirror.govDeadBand ={  

2     'gen3DB' : {  

3         'genBus' : 3,  

4         'genId' : None, # optional  

5         'GovDeadbandType' : 'ramp', # step, ramp, nldroop  

6         'GovDeadband' : 0.036, # Hz  

7     },  

8     'gen1DB' : {  

9         'genBus' : 1,  

10        'genId' : None, # optional  

11        'GovDeadbandType' : 'nldroop', # step, ramp, nldroop  

12        'GovAlpha' : 0.016, # Hz, used for nldroop  

13        'GovBeta' : 0.036, # Hz, used for nldroop  

14    },  

15     'gen4DB' : {  

16         'genBus' : 4,  

17         'genId' : None, # optional  

18         'GovDeadbandType' : 'step', # step, ramp, nldroop  

19         'GovDeadband' : 0.036, # Hz  

20         'GovAlpha' : 0.016, # Hz, used for nldroop  

21         'GovBeta' : 0.036, # Hz, used for nldroop  

22     },  

23 }# end of govDelay dictionary

```

Figure 20: Governor deadband dictionary definition example.

Entering ‘step’ or ‘ramp’ as a value for the ‘GovDeadbandType’ will create a step or ramp deadband at the given ‘GovDeadband’. A non-linear droop governor deadband may be configured by setting the ‘GovDeadbandType’ to ‘NLDrop’ and entering desired ‘GovAlpha’ and ‘GovBeta’ values. Deadband types are fully explained in Section 5.3.1.

4.3.2.3.8. Definite Time Controller Dictionary

During long simulations, system loading may change from initial values by more than $\pm 20\%$. Such changes can cause voltage issues that require the setting or un-setting of components contributing to available system reactive power. This can be accomplished by defining a definite time controller (DTC) agent in the mirror.DTCdict dictionary. Other general programmable logic operations may also be accomplished using a DTC agent. Figure 21 shows an example of a

valid DTC definition where a shunt is actuated by changes in bus voltage or branch MVAR flow. It should be noted that instead of using a specific ‘tarX’ in a timers ‘act’ field, operations on any off or on target can be accomplished by using ‘anyOFFtar’ or ‘anyONtar’ respectively.

```

1 mirror.DTCdict = {
2     'ExampleDTC' : {
3         'RefAgents' : {
4             'ra1' : 'bus 8 : Vm',
5             'ra2' : 'branch 8 9 1 : Qbr', # branches defined from, to, ckID
6         },# end Reference Agents
7         'TarAgents' : {
8             'tar1' : 'shunt 8 2 : St',
9             'tar2' : 'shunt 8 3 : St',
10        }, # end Target Agents
11         'Timers' : {
12             'set' :{
13                 'logic' : "(ra1 < 1.0) or (ra2 < -15)",
14                 'actTime' : 30, # seconds of true logic before act
15                 'act' : "tar1 = 1",
16             },# end set
17             'reset' :{
18                 'logic' : "(ra1 > 1.04) or (ra2 > 15)",
19                 'actTime' : 30, # seconds of true logic before act
20                 'act' : "tar1 = 0",
21             },# end reset
22             'hold' : 60, # minimum time between actions
23         }, # end timers
24     },# end ExampleDTC definition
25 }# end DTCdict

```

Figure 21: Definite time controller dictionary definition example.

Each DTC employs a set and a reset timer and may have a hold timer if hold time is set larger than zero. Multiple references and targets can be associated with a DTC, however, as of this writing only one action can be associated with each timer. Any logic string entered in a timer uses the given key names for each reference or target and is evaluated using standard Python logic conventions.

4.3.3. Simulation Initialization

To clarify the explanation of simulation initialization, the entire process can be broken into three parts: process creation, mirror initialization, and dynamic initialization pre-simulation loop. The first part (process creation) involves creating and configuring various software processes that enable the simulation to run. The majority of part two (mirror initialization) revolves around collecting data from PSLF to create a Python duplicate, or mirror, of the power system model. The last part of simulation initialization (dynamic initialization pre-simulation loop) handles user input and creates PY3 dynamics before entering the simulation loop.

4.3.3.1. Process Creation

System initialization begins in PY3 with package imports and creation of truly global variables before user input from the .py file is handled. The .py file includes debug flags, simulation notes, simulation parameters, and file locations of the .sav, .dyd, and .ltd.py files. If all file locations are valid, PY3 initializes AMQP queues, sends appropriate initialization information to the IPY queue, starts the IPY_PSLTDSim process, and then waits for an IPY response message.

The IPY process begins by also importing required packages and setting references to certain imported packages as truly global variables. An IPY AMQP agent is created and linked to the AMQP host generated by the PY3 process. This allows the IPY process to receive initialization information from the PY3 AMQP message sent before the IPY process was evoked. IPY uses the received initialization information to load the GE Python API which is then used to load the .sav and .dyd into PSLF. Upon successful file loading in PSLF, a global reference to the object is created.

4.3.3.2. Mirror Initialization

Once the PSLF specific files are loaded into the GE software, initialization of the Python environment, or system model, may begin. The system model, referred to as the system mirror, or just mirror, is a single object that almost all other Python objects are created inside. The mirror is a single system object with a recursive data structure that allows any object the ability to ref-

erence any other object as long as they both share a reference to the mirror, and are themselves referenced by the mirror. While the previous sentence may seem overly complicated, the use of such a linking technique eliminated the need for global variables outside of imported packages and also allowed for a single file containing **all** simulation data to be easily exported at the end of a simulation.

The system mirror begins its initialization by creating placeholder variables for simulation parameters, counters, and future agent collections. Specific case parameters, such as the number of buses or generators, are collected from PSLF to be used later in model verification processes.

Before any specific power system object data is collected, an initial power flow is performed to ensure that the loaded .sav is solvable, and to establish a steady state system operating point. System agents, representing power system objects like buses and loads, are then added to the mirror. The adding process queries PSLF for any buses in a specific area, checks each found bus for any connected system components, and creates Python agents for relevant objects. The querying and adding process continues until all system buses are accounted for. Each type of found object is added to a running tally so that it can be compared with the expected values collected earlier. Once all system buses have been found or accounted for, any created agents that are intended to log data are collected into a list for simpler group stepping.

Each area tally of found agents is checked for coherency with expected values. Any inconsistencies between the amount of found and expected objects will trigger warnings, but the simulation will not stop if this occurs. This choice is due to differences between what is counted in PSLF as a valid area object and PSLTDSim, which has the option to ignore islanded objects.

Dynamic model information from the specified .dyd file is then parsed. Collected machine or governor parameters are used to create PSLF model information objects (PMIOs) inside the mirror. These PMIOs collect inertia H and MW cap for each machine as well as turbine type, governor MW cap, and permanent droop R from governors. Other information, such as MVA base, is also collected for both types of model. This process is required as the .dyd values for certain parameters overwrite pre-existing values that may be saved inside the .sav file.

Once the .dyd file is parsed and all PMIOs are created, the combined system inertia is calculated. For each found generator PMIO, the associated mirror agent is located and updated so that H and Mbase values match those found in the .dyd. The total system inertia is calculated according to Equation 8 and user input settings are interpreted so that any requested changes, such as scaling or alternative system inertia inputs, are handled correctly.

Mirror search dictionaries are then created to simplify and speed up agent searches and the global slack generator is identified. The global slack generator is important to locate as its variance from an expected value dictates accelerating power re-distribution and power-flow solution iterations during the simulation loop. Once search dictionaries are created, the IPY model is fully initialized. The mirror is then saved to disk and an AMQP message is sent to PY3 with the mirror location.

4.3.3.3. Dynamic Initialization Pre-Simulation Loop

After the handoff AMQP message is sent to PY3, IPY initializes values required for simulation and awaits an AMQP message from PY3 before entering its simulation loop.

PY3 uses the information received from IPY to load the newly created system mirror so that PY3 can perform further initializations such as creating any dynamic agents (e.g. governors), calculating area frequency characteristics and maximum capacities, executing any .ltd code, and creating the associated agents from the .ltd input.

PY3 dynamics are initialized to ensure R is on the correct PU base and any MW caps from dyd parsing is applied. Additionally, any limiting values for governor output are accounted for, and any deadbands or delays are created. Before entering the PY3 simulation loop, agents that are designed to log values initialize blank lists for expected values.

4.3.4. Simulation Loop

Once simulation initialization is complete, and the system mirror is initialized, the simulation loop is executed. Figure 22 shows the major actions that are processed each time step, but does not include details concerning AMQP communication. AMQP messages are sent and received during the ‘Update’ blocks and the system mirrors are checked for coherency at these times as well.

The simulation loop can be viewed as starting with the increment of simulation time followed by the stepping of any dynamic agents. These dynamic agents calculate the new system frequency and perform any required governor responses. Generator electrical power is then set equal to generator mechanical power. This step is the beginning of forming the next power-flow solution initial conditions.

Perturbation agents are then stepped. This means that any steps, ramps, or noise type events are performed, agents in both system mirrors are updated, and any related system value is changed accordingly. For example, the tripping of a generator requires the system inertia to change as well as the amount of power in the system. The variable ΔP_{pert} is used to keep track of system power changes. Additionally, BA action takes place at this time.

After all perturbation related actions are executed, accelerating power is calculated and distributed to the system according to generator inertia. The PSLF system is updated with any required values and a power-flow solution is attempted. If the solution diverges the simulation ends and any collected data is output. If the solution does not diverge, the magnitude of any slack error is checked against the slack error tolerance. If the slack error is larger than the slack tolerance, the error is redistributed to the system until the resulting error is within tolerance or the solution diverges. If the power-flow solution diverges during accelerating power redistribution the simulation ends and any collected data is output.

Once the system has converged to a point where the slack error is less than the slack tolerance, PSLF values for generator real and reactive power and bus voltage and angle are used to update the PY3 mirror. The electric power output of the system is summed for use in calculating




Figure 22: Simulation time step flowchart.

system accelerating power in the next time step. Any logging agents are then stepped and data for that particular simulation time step are recorded. Finally, system time is checked and if the simulation is complete, any collected data is output. If the simulation is not complete, the simulation time is incremented by the time step and the cycle repeats itself again.

4.3.5. Simulation Outputs

Pre-defined data is collected by any agent with logging ability. Current agents with this ability are machines, loads, shunts, branches, transformers, areas, balancing authorities, and the system mirror itself. When a simulation is complete, the final system mirror is exported via the Python package `shelve` and options exist to export some data as a MATLAB .mat file. The .mat output is accomplished by combining various agent log dictionaries into a single dictionary. As such, only data deemed useful for validating the software is included.

It should be noted that numerous plot functions were created to easier visualize and validate python mirror data. Python plot functions are located in the PSLTDSim package plot folder, while the MATLAB validation plots are located in the GitHub repository only.

4.4. Software Validation

PSLTDSim was validated by comparing results from identical simulation scenarios performed in PSDS and PSLTDSim. For clarification, data from PSLTDSim, or simulations performed in PSLTDSim, are described as LTD data or simulations, respectively. Compared values of interest include: system frequency, generator mechanical power, generator real power, bus voltage magnitude, bus voltage angle, generator reactive power, branch current, branch real power flow, and branch reactive power flow. The following sections describe the plots used for validation, present results from various scenarios, and provide a validation summary.

4.4.1. Validation Plots Explained

Plots were used to present simulation validation data. Due to the volume of information, various types of plots were created. Figure 23 shows the three types of plots used for the validation process. Because of the different time steps used in PSDS and LTD, when computing difference data between the two simulations, the same LTD value was held for multiple comparisons. For example, any PSDS($t = 2.x$) data was compared to the corresponding LTD($t = 2$) data point.




Figure 23: Validation plot examples.

4.4.1.1. Comparison Plot

The most basic plot is a comparison plot that simply puts data from one simulation environment on top of another. Two examples of a comparison plot are shown in Figure 24 where LTD data is shown using open circles and PSDS data plotted as filled dots.




Figure 24: Comparison plot examples.

While comparison plots are useful for quick validation, they do not provide substantive quantitative data. Additionally, when comparing many values, plots become difficult to interpret. As a result, comparison plots are typically only used for showing frequency.

4.4.1.2. Difference Plot

To allow for more easily compared values and provide quantitative data, a difference plot was created. Figure 25 provides an example of a difference plot. Since individual comparisons seemed less important, all data comparisons were plotted in grey with an absolute average plotted in black.




Figure 25: Difference plot example.

Equation 14 describes the difference calculation between PSDS and LTD variables.

$$\text{Difference}_{data} = \text{PSDS}_{data} - \text{LTD}_{data} \quad (14)$$

The absolute average was calculated using Equation 15 where $data_i$ represents a time series of difference data for a particular value of interest and n is the total number of comparisons made.

$$\text{Average}_{abs} = \frac{\sum_i^n |data_i|}{n} \quad (15)$$

While difference plots are more quantitative than comparison plots, there is no sense of scale when comparing two values. As power systems can greatly vary in size, a subjectively insignificant difference in one system may be very significant in another system.

4.4.1.3. Percent Difference Plot

To account for the wide variety of data magnitudes being compared, a percent difference plot was created. Figure 26 shows two examples of a percent difference plot.




Figure 26: Percent difference plot examples.

Similar to the difference plot, individual comparisons were not deemed as important a cumulative comparison, so the same plotting scheme is repeated. The percent difference was calculated according to Equation 16.

$$\%_{diff} = \frac{|\text{PSDS}_{data} - \text{LTD}_{data}|}{\frac{\text{PSDS}_{data} + \text{LTD}_{data}}{2}} \times 100\% \quad (16)$$

When using percent difference, it should be noted that if one value is positive, and the other negative, results may be misleading. More specifically, as the average of the two numbers being compared approaches zero, so does the denominator of Equation 16. Such a situation may lead to a divide by zero error or, more likely, a very large percent difference. To alleviate such data obfuscation, the y-axis was scaled if the average absolute percent difference was over 150% and the maximum and minimum percent differences are listed in the legend. This is shown in the right hand plot of Figure 26.

4.4.1.4. Weighted Frequency Plot

Frequency comparisons were used to validate the single system frequency assumption calculated by PSLTDSim. Comparison of frequency data from PSDS to LTD was simplified by calculating a single weighted PSDS frequency f_w based on generator inertia. In a system with N generators

$$f_w = \sum_{i=1}^N f_i \frac{H_{PU,i} M_{base,i}}{H_{sys}} \quad (17)$$

where f_i is a full time series of machine i 's frequency, and H_{sys} is calculated according to Equation 8.

Figure 27 shows all bus frequencies plotted in grey, the calculated weighted frequency in black, and the single system frequency calculated by PSLTDSim in magenta. It is worth pointing out that non-generator bus frequencies are ignored in the weighted system frequency because they lack inertia.




Figure 27: Frequency comparison plot example.

4.4.2. Six Machine System

A two area six machine system used for validation is shown in Figure 28. The system is based off the Kundur four machine system presented in [35] with a some modifications.




Figure 28: Six machine system.

The most noticeable difference is the addition of two generators and switchable shunts on bus 8 and 9. The generators were added to test power plant style AGC dispatching and multiple generators per bus. While placing multiple generators per bus is not a standard or recommended modeling technique, it is present in the full WECC PSLF model and as such, should be validated in PSLTDSim. Detailed six machine system model specifications are presented in Appendix 9.

4.4.2.1. Simulated Scenario Descriptions

A load step, a load ramp, and a generator trip were simulated using the six machine model. The simplest validation test, a stepping of load, occurred at $t = 2$ when the load on bus 9 was increased by 75 MW. To test longer perturbances, a 40 second 75 MW load ramp of the load on bus 9 was simulated. Due to the LTD one second time step, the ramp is equivalent to forty 1.875 MW steps taking place every second from $t = 2$ to $t = 42$. Finally, to test the handling of inertia and a slightly larger step perturbation, generator 5, which was initially generating 90 MW, was tripped at $t = 2$.

4.4.2.2. Frequency Results

System frequency comparison results are presented for each simulated scenario in Figures 29, 30, and 31. The load step results show a maximum 18 mHz difference that is reduced below 2.5 mHz by $t = 25$. The system frequency difference during the ramp test never exceeds more than 1.4 mHz with peaks at the start and end of the ramp event. Similar to the load step result, the generator trip event had a maximum difference of 30 mHz that was reduced below 2.5 mHz by $t = 25$ and essentially matched the PSDS frequency. The larger frequency peak difference is due to the generator trip perturbation being 15 MW larger than the load step perturbation.




Figure 29: Six machine load step system frequency comparison.




Figure 30: Six machine load ramp system frequency comparison.




Figure 31: Six machine generator trip system frequency comparison.

4.4.2.3. Generator Mechanical Power Results

Generator mechanical power comparison results are presented for each simulated scenario in Figures 32, 33, and 34. It should be noted that only generators equipped with governors are compared in this section as machines without governors are not modeled to have any changes in mechanical power. Similar to frequency results, the ramp event had the smallest difference from PSDS never exceeding 0.5 MW, or 0.2% difference. Unlike the frequency results, most ramp mechanical power differences happen during the ramp with no large peaks at the beginning or end of the event. Further, there is a small steady state error present after the ramp is complete. Both step type events have an immediate peak difference of 5 to 7 MW (2.5 to 3.5 percent difference) that is reduced to roughly zero after 20 seconds.




Figure 32: Six machine load step mechanical power comparison.




Figure 33: Six machine load ramp mechanical power comparison.




Figure 34: Six machine generator trip mechanical power comparison.

4.4.2.4. Generator Real Power Results

Generator real power comparison results are presented for each simulated scenario in Figures 35, 36, and 37. All six generators are compared in this section as real power is calculated via the power-flow solution and can change every step. Averaged results are very similar to the mechanical power results though slightly more transient. In the step type events, individual difference peaks are nearly double the mechanical power peak differences. In all cases, the difference approaches zero approximately 20 seconds after each perturbation is complete. The PSDS simulation shows a strange peak of activity during the ramp event near $t = 110$.




Figure 35: Six machine load step real power comparison.




Figure 36: Six machine load ramp real power comparison.




Figure 37: Six machine generator trip real power comparison.

4.4.2.5. Voltage Magnitude Results

Bus voltage magnitude comparison results are presented for each simulated scenario in Figures 38, 39, and 40. Since voltage is presented in PU, percent difference plots appear as a

scaled absolute version of the difference plots. The largest bus voltage difference, of approximately 1.5%, occurred during the generator trip test. As with the load step test, simulation results converge after $t = 20$. Voltages gradually drift during the ramp event, but stop once the event is over. The gradual voltage change is believed to be due to the difference in exciter modeling between PSDS and PSLTDSim.




Figure 38: Six machine load step voltage comparison.




Figure 39: Six machine load ramp voltage comparison.




Figure 40: Six machine generator trip voltage comparison.

4.4.2.6. Voltage Angle Results

Bus voltage angle comparison results are presented for each simulated scenario in Figures 41, 42, and 43. The step type perturbances caused larger oscillatory differences than the load ramp event, but steady state angle differences converge near zero. Maximum percent difference during the generator trip reached nearly 20% while the load step and ramp had maximums of approximately 7.0% and 0.6% respectively.




Figure 41: Six machine load step voltage angle comparison.




Figure 42: Six machine load ramp voltage angle comparison.




Figure 43: Six machine generator trip voltage angle comparison.

4.4.2.7. Generator Reactive Power Results

Generator reactive power comparison results are presented for each simulated scenario in Figures 44, 45, and 46. Maximum reactive power percent differences for the generator trip, load step, and ramp events were 8.0%, 5.0%, and 0.8% respectively. As in previous comparisons, the step events had large oscillatory differences immediately following the event, but have very low steady state error by $t = 20$. The ramp event had less than 1.0% differences during the event and less than 0.2% difference in the steady state.




Figure 44: Six machine load step reactive power comparison.




Figure 45: Six machine load ramp reactive power comparison.




Figure 46: Six machine generator trip reactive power comparison.

4.4.2.8. Branch Current Results

Branch current comparison results are presented for each simulated scenario in Figures 47, 48, and 49. Maximum branch current percent differences for the generator trip, load step, and

ramp events were 8.5%, 7.0%, and 1.2% respectively. Again, largest differences occur immediately following the event while steady state differences are near zero.




Figure 47: Six machine load step branch current flow comparison.




Figure 48: Six machine load ramp branch current flow comparison.




Figure 49: Six machine generator trip branch current flow comparison.

4.4.2.9. Branch Real Power Flow Results

Branch real power flow comparison results are presented for each simulated scenario in Figures 50, 51, and 52. With results very similar to branch current flow, branch real power flow percent difference maximums for the generator trip, load step, and ramp events were 8.5%, 7.0%, and 1.2% respectively. Differences in the steady state are near zero.




Figure 50: Six machine load step branch real power flow comparison.




Figure 51: Six machine load ramp branch real power flow comparison.




Figure 52: Six machine generator trip branch real power flow comparison.

4.4.2.10. Branch Reactive Power Flow Results

Branch reactive power flow comparison results are presented for each simulated scenario in Figures 53, 54, and 55. While the timing of value differences in branch reactive power flow is similar to current and real power flow, the magnitude of difference is not. Maximum branch reactive power flow percent differences for the generator trip, load step, and ramp events were 45.0%, 45.0%, and 5.0% respectively. These large differences may be due to the size of the system and actual MVAR flow on lines being low. Despite the large peak differences, steady state values from step events approaches zero while the ramp event had steady state differences of nearly $\pm 2.0\%$.




Figure 53: Six machine load step branch reactive power flow comparison.




Figure 54: Six machine load ramp branch reactive power flow comparison.




Figure 55: Six machine generator trip branch reactive power flow comparison.

4.4.2.11. Six Machine Result Summary

Nearly all percent differences were less than 10.0% and approached zero in the long-term. Calculated system frequency never exceeded a ± 3.0 mHz difference from the PSDS weighted frequency. Smaller perturbances, such as the ramp event, match PSDS results better than the large step event of a generator trip. Reactive power flow differences for step type events had the largest peak differences from PSDS simulation. Minor variations in voltage magnitude and angle caused by ideal exciter assumptions are believed to be the main contributer to reactive power flow difference.

4.4.3. Mini WECC System

A larger system model was used to test the scaling ability of PSLTDSim . The ‘mini WECC’, shown in Figure 56, is a 120 bus 34 generator system model created in PSLF. Total generation of 102,050 MW supplies 100,685 MW of load over 104 branch sections. All governors in the miniWECC were modeled with the tgov1. Further details about the creation and use of the miniWECC may be found in [58], [64], and [28].

The mini WECC was modified from the original configuration to include three areas. The importance of these area definitions becomes more clear in Section 5.4.1. Additionally, since the mini WECC was designed to test heavy loading and transient type events, all loads were reduced by 5%. To keep the voltage profile similar to the original design, reactive shunts were also reduced by 5%.

4.4.3.1. Simulated Scenario Descriptions

Similar to the six machine tests, a load step, load ramp, and generator trip were simulated. At $t = 2$ the loads on buses 16, 21, and 26 were each increased by 400 MW. The ramp perturbation acts on these same loads a total of 400 MW, but over 40 seconds. The ramp is equivalent to forty 30 MW steps taking place every second from $t = 2$ to $t = 42$. Initially generating ≈ 200 MW, generator 27 was tripped at $t = 2$. Unlike the six machine scenario, in which the generator trip was ‘larger’ than the load step; the mini WECC load step is double the magnitude of the simulated generator trip.




Figure 56: Mini WECC system adapted from [28].

4.4.3.2. Frequency Results

System frequency comparison results are presented for each simulated scenario in Figures 57, 58, and 59. The simulated step events caused the PSDS frequencies to oscillate. The generator trip oscillations appear damped while the load step oscillations do not. The weighted system frequency of PSDS appears to follow the center of individual frequency oscillation. Similar to six machine results, the ramp event most closely tracks PSDS behavior. For all cases, absolute frequency difference maximums never exceed 10.0 mHz and are less than 1.0 mHz in the long-term.




Figure 57: Mini WECC load step system frequency comparison.




Figure 58: Mini WECC load ramp system frequency comparison.




Figure 59: Mini WECC generator trip system frequency comparison.

4.4.3.3. Generator Mechanical Power Results

Generator mechanical power comparison results are presented for each simulated scenario in Figures 60, 61, and 62. The ramp and generator trip events both had MW differences of less than 10 MW (1.0% difference), with averages approaching zero in the long-term. The larger load step caused a MW difference of approximately 70 MW (5.0% difference). In both the step type events, the system starts to swing and doesn't completely come to rest by the end of simulated time.




Figure 60: Mini WECC load step mechanical power comparison.




Figure 61: Mini WECC load ramp mechanical power comparison.




Figure 62: Mini WECC generator trip mechanical power comparison.

4.4.3.4. Generator Real Power Results

Generator real power comparison results are presented for each simulated scenario in Figures 63, 64, and 65. The swinging system causes large differences in real power for both step type events, however both absolute average percent differences is less than 5.0%. The ramp event, which differs less than 1.2%, matches PSDS data well. In all scenarios, long-term behavior averages approach zero, or accounting for system swing, approach the center of oscillation.




Figure 63: Mini WECC load step real power comparison.




Figure 64: Mini WECC load ramp real power comparison.




Figure 65: Mini WECC generator trip real power comparison.

4.4.3.5. Voltage Magnitude Results

Bus voltage magnitude comparison results are presented for each simulated scenario in Figures 66, 67, and 68. In the load step case, voltage magnitude oscillations appear to be getting larger as simulated time increases. The generator trip case has damped voltage oscillation behav-

ior. Despite these oscillations, maximum voltage percent difference for either step type event is less than 2.0%. The ramp event has an absolute average percent difference of less than 0.05% for the entire simulation.




Figure 66: Mini WECC load step voltage comparison.




Figure 67: Mini WECC load ramp voltage comparison.




Figure 68: Mini WECC generator trip voltage comparison.

4.4.3.6. Voltage Angle Results

Bus voltage angle comparison results are presented for each simulated scenario in Figures 69, 70, and 71. Actual angle differences of less than 10 degrees result in very large percent differences in the load step case. Angle oscillations appear to be damped in the generator trip case and slowly growing in the load step case. The load ramp angle difference magnitude is below 0.3 degrees for the entire simulation. Generally, it can be seen that when the system swing behavior is damped, long-term values from both simulation methods appear to converge.




Figure 69: Mini WECC load step voltage angle comparison.




Figure 70: Mini WECC load ramp voltage angle comparison.




Figure 71: Mini WECC generator trip voltage angle comparison.

4.4.3.7. Generator Reactive Power Results

Generator reactive power comparison results are presented for each simulated scenario in Figures 72, 73, and 74. Percent difference plots for both step perturbances oscillate and have multiple large peaks. The ramp case has relatively small MVAR differences and large percent difference spikes at the start and end of the event.




Figure 72: Mini WECC load step reactive power comparison.




Figure 73: Mini WECC load ramp reactive power comparison.




Figure 74: Mini WECC generator trip reactive power comparison.

4.4.3.8. Branch Current Results

Branch current comparison results are presented for each simulated scenario in Figures 75, 76, and 77. The ramp scenario has the smallest absolute average percent difference of less than 1.0%. Both step events have relatively low average differences, but fast oscillations are not captured in LTD simulation. Simulations from the generator trip case, which had damped oscillations, appeared to converge in the long-term.




Figure 75: Mini WECC load step branch current flow comparison.




Figure 76: Mini WECC load ramp branch current flow comparison.




Figure 77: Mini WECC generator trip branch current flow comparison.

4.4.3.9. Branch Real Power Flow Results

Branch real power flow comparison results are presented for each simulated scenario in Figures 78, 79, and 80. The load step case results show large peak differences of nearly ± 100 MW that may be too large for useful simulation analysis. Despite long-term behavior, repeated

oscillations present in the generator trip case of over 60% difference may also be too large to be considered acceptable. Ramp results are much more similar to PSDS output with average absolute difference of less than 2 MW.




Figure 78: Mini WECC load step branch real power flow comparison.




Figure 79: Mini WECC load ramp branch real power flow comparison.




Figure 80: Mini WECC generator trip branch real power flow comparison.

4.4.3.10. Branch Reactive Power Flow Results

Branch reactive power flow comparison results are presented for each simulated scenario in Figures 81, 82, and 83. Reactive power flow results all show large percent difference peaks. The load step scenario has growing oscillatory behavior while the generator trip exhibits damped characteristics. Load ramp results differ by only ± 4 MVAR but have a large percent difference.




Figure 81: Mini WECC load step branch reactive power flow comparison.




Figure 82: Mini WECC load ramp branch reactive power flow comparison.




Figure 83: Mini WECC generator trip branch reactive power flow comparison.

4.4.3.11. Mini WECC Result Summary

While PSLTDSim assumes a stable system, and a ‘swinging’ system could be thought of as stable, simulation results show large differences in such cases. Power system oscillations are a manifestation of inter-generator energy exchange represented in CTS simulation as a set of coupled swing equations. PSLTDSim ignores these electro-mechanical oscillations as individual machine speed dynamics are represented in an aggregated swing equation. The mini WECC was designed to represent a marginally stable operating point, and therefore electro-mechanical dynamics dominate the response to abrupt changes in accelerating power. As such, transient simulations may be a good tool to help decide if a particular scenario is suitable for PSLTDSim.

For the mini WECC system, the most suitable event appears to be the load ramp. Undamped voltage oscillations seen in the load step test may indicate that the perturbation was too large for adequate LTD simulation. This hypothesis is further backed up by large differences seen in other results from that particular scenario. Many percent difference plots have very large maximum and minimum peak values. The nature of the percent difference calculation is believed to cause these misleading values during data oscillation, or when compared values are small.

4.4.4. Mini WECC with PSS System

The mini WECC, previously shown in Figure 56, was originally created with power system stabilizers (PSS) enabled. To limit the amount of initial modeling differences, and thus assumptions made by PSLTDSim, PSS was removed for initial validation testing. However, step type event results may have been too oscillatory for suitable LTD simulation. Since PSS acts to damp power system oscillations [35], PSS was enabled in PSDS for the following validation tests.

4.4.4.1. Simulated Scenario Descriptions

The same mini WECC simulations from the previous section were conducted to observe PSS behavior and resulting LTD differences. PSDS pss2a models were added to generators on bus 1, 30, 32, 41, and 118. For completeness, perturbances are described again. At $t = 2$ the loads on buses 16, 21, and 26 were each increased by 400 MW. The ramp perturbation acts on these same loads a total of 400 MW, but over 40 seconds. The ramp is equivalent to forty 30 MW steps taking place every second from $t = 2$ to $t = 42$. Generator 27 was tripped at $t = 2$ and was initially generating ≈ 200 MW.

4.4.4.2. Frequency Results

System frequency comparison results are presented for each simulated scenario in Figures 84, 85, and 86. The use of PSS creates a non-steady state operating condition at $t = 0$. This is indicated by the frequency changes that start immediately in all PSDS simulations. Unlike the previous mini WECC load step case, frequency oscillations are damped. General frequency differences are similar to the non-PSS scenario, but ≈ 1.0 mHz larger in each case.




Figure 84: Mini WECC with PSS load step system frequency comparison.




Figure 85: Mini WECC with PSS load ramp system frequency comparison.




Figure 86: Mini WECC with PSS generator trip system frequency comparison.

4.4.4.3. Generator Mechanical Power Results

Generator mechanical power comparison results are presented for each simulated scenario in Figures 87, 88, and 89. Results from the PSS and non-PSS case were mostly the same, but slightly different. The ramp event had smaller oscillatory differences, but larger steady state

differences. The generator trip case also had slightly larger oscillating steady state differences.




Figure 87: Mini WECC with PSS load step mechanical power comparison.




Figure 88: Mini WECC with PSS load ramp mechanical power comparison.




Figure 89: Mini WECC with PSS generator trip mechanical power comparison.

4.4.4.4. Generator Real Power Results

Generator real power comparison results are presented for each simulated scenario in Figures 90, 91, and 92. PSS action reduces system oscillation in both step perturbation cases. Peak percent differences are slightly increased from non-PSS results. The ramp validation results appear slightly worse when using PSS because of relatively large initial differences caused by a non-steady state starting condition.




Figure 90: Mini WECC with PSS load step real power comparison.




Figure 91: Mini WECC with PSS load ramp real power comparison.




Figure 92: Mini WECC with PSS generator trip real power comparison.

4.4.4.5. Voltage Magnitude Results

Bus voltage magnitude comparison results are presented for each simulated scenario in Figures 93, 94, and 95. Long-term voltage magnitudes do not match between simulations. Generally, percent differences peak slightly below 4.0% and do not converge towards zero for all cases. Absolute average percent difference for all cases was slightly below 1.0% for all simulated time.




Figure 93: Mini WECC with PSS load step voltage comparison.




Figure 94: Mini WECC with PSS load ramp voltage comparison.




Figure 95: Mini WECC with PSS generator trip voltage comparison.

4.4.4.6. Voltage Angle Results

Bus voltage angle comparison results are presented for each simulated scenario in Figures 96, 97, and 98. Step type perturbances with PSS are very similar to non-PSS results. Ramp results show slightly larger angle difference when PSS is used in PSDS.




Figure 96: Mini WECC with PSS load step voltage angle comparison.




Figure 97: Mini WECC with PSS load ramp voltage angle comparison.




Figure 98: Mini WECC with PSS generator trip voltage angle comparison.

4.4.4.7. Generator Reactive Power Results

Generator reactive power comparison results are presented for each simulated scenario in Figures 99, 100, and 101. Using PSS creates large modeling differences in reactive power output. All test cases have an average absolute difference of 50.0% or larger.




Figure 99: Mini WECC with PSS load step reactive power comparison.




Figure 100: Mini WECC with PSS load ramp reactive power comparison.




Figure 101: Mini WECC with PSS generator trip reactive power comparison.

4.4.4.8. Branch Current Results

Branch current comparison results are presented for each simulated scenario in Figures 102, 103, and 104. Load step results have a damped behavior when PSS is enabled and slightly smaller peak differences compared to the non-PSS mini WECC results. Absolute percent differ-

ences appear similar for all cases. When using PSS, branch current variances during the ramp event increase peak percent differences by nearly five times compared to the non-PSS results.




Figure 102: Mini WECC with PSS load step branch current flow comparison.




Figure 103: Mini WECC with PSS load ramp branch current flow comparison.




Figure 104: Mini WECC with PSS generator trip branch current flow comparison.

4.4.4.9. Branch Real Power Flow Results

Branch real power flow comparison results are presented for each simulated scenario in Figures 105, 106, and 107. With the exception of damped load step behavior, similar results are produced in the step events when PSS is not used. Ramp results appear to have more differences near the beginning of the simulation, but differing scales make further comparisons difficult.




Figure 105: Mini WECC with PSS load step branch real power flow comparison.




Figure 106: Mini WECC with PSS load ramp branch real power flow comparison.




Figure 107: Mini WECC with PSS generator trip branch real power flow comparison.

4.4.4.10. Branch Reactive Power Flow Results

Branch reactive power flow comparison results are presented for each simulated scenario in Figures 108, 109, and 110. As should be assumed from the previously noted reactive power differences, reactive power flows also differ by over 50.0% from non-PSS results.




Figure 108: Mini WECC with PSS load step branch reactive power flow comparison.




Figure 110: Mini WECC with PSS generator trip branch reactive power flow comparison.




Figure 109: Mini WECC with PSS load ramp branch reactive power flow comparison.

4.4.4.11. Mini WECC with PSS Result Summary

The addition of PSS accomplishes the desired goal of stabilizing a power system. However, the additional modeling differences between PSDS and PSLTDSim create more differences in output data. Larger transient differences are seen in most cases as PSS acts to stabilize the system. The pss2a model output is a generator voltage in PSDS which in turn affects steady state voltage magnitudes and branch flow results. Further, initial conditions for all simulations are not the same between PSDS and PSLTDSim as PSS begins to act immediately.

4.4.5. Full WECC System

To test the scalability of PSLTDSim, a full WECC system model was simulated. The full WECC model used is representative of the western United States interconnect during a heavy spring of 2018. The main island consists of 22 areas with a total 21,528 buses and has 3,330 generators operating near an average of 59.3% capacity to supply 140,189 MW of real power to 11,018 loads. A count of modeled generators is shown in Table V. As a reminder, only MW cap, machine base, and machine inertia H are collected from the PSDS model for use in PSLTDSim.

Table V: WECC machine model count and capacity.

Model	Count	Capacity [MW]
gentpj	1,541	96,559.72
genrou	1,277	128,990.75
gentpf	476	17,707.11
motor1	34	717.89
genwri	2	191.00
Total	3,330	244,166.46

The generic governor is used almost exclusively for long-term simulation due to the system model using a wide variety of governor models that are not presently available in PSLTDSim. Table VI shows the total number of PSDS governor models and their respective capacity while Table VII shows the resulting generic model casting performed for long-term simulation in PSLTDSim. It should be noted that about 0.89% of governor models (representing $\approx 0.56\%$ of governed capacity) have the same governor model and time constants as those in PSLTDSim and PSDS due to the generic casting process.

Table VI: WECC governor models used in PSDS.

Model	Count	Capacity [MW]
ggov1	1,006	74,804.11
hyg3	315	28,755.47
hygov	196	8,883.36
ieeeeg1	191	49,022.45
hygov4	167	8,044.68
ieeeeg3	133	9,174.48
gpwscc	56	3,028.33
pidgov	56	8,034.54
gast	29	1,162.56
ggov3	28	5,010.32
hygovr	25	6,249.37
tgov1	20	1,140.45
g2wscc	18	818.95
ccbt1	3	32.53
Total	2,243	204,161.59

Table VII: WECC governor models used in PSLTDSim.

Model	Count	Capacity [MW]
gas	1,090	82,842.76
hydro	777	60,786.37
steam	356	59,392.02
tgov1	20	1,140.45
Total	2,243	204,161.59

4.4.5.1. Load Step

For the WECC system model, only frequency response to a load step is presented as the number of assumptions and sheer volume of data make other comparisons difficult with mostly inconclusive results. The perturbation is a step of three loads up 100 MW at $t = 2$. Figure 111 shows frequency of all PSDS generator bus frequencies in grey, an average PSDS generator frequency in black, and the LTD system frequency in magenta.




Figure 111: Full WECC frequency comparison.

It can be seen that the average PSDS frequency is similar to the LTD frequency immediately after the perturbation. This indicates that the inertial response from the two simulations is similar. However, once governor action becomes more predominate, the two data sets begin to diverge. While the LTD system frequency over estimates the frequency nadir, steady state response is within 2 mHz.

Figure 112 shows the absolute frequency difference between PSDS and LTD simulations. Despite governor dynamics being greatly estimated, absolute frequency difference never exceeds 10 mHz. It should be noted that with a perturbation this size, 10 mHz is actually rather large since steady state frequency is about 59.99 Hz.




Figure 112: Full WECC absolute frequency difference.

4.4.6. Validation Summary

The purpose of PSLTDSim is long-term dynamic simulation. True validation must be against measured system response. In the absence of measured data, validating against industry standard transient stability software was chosen.

Smaller systems, such as the six machine system, that required less modeling assumptions had generally small differences from PSDS in output data. However, exciter assumptions and the combination of voltage magnitude and angle caused calculated reactive power flow to largely differ from PSDS values during step type events. Oscillations, such as those in found voltage angle, are not well represented in TSPF due to time step resolution.

Larger systems, such as the two WECC models, employ more simplifications in PSLTDSim, and thus have more differences. Large differences are shown in bus voltages and the resulting power flow calculations. Ramp events are typically simulated more accurately than step type perturbances. When PSS is used, more generator voltage behavior is ignored and larger differences are seen in steady-state data. Generic governor casting employed in the full WECC case produced similar steady state behavior, but fairly different dynamic response. System damping, described in Section 5.8, could be used to more accurately match the frequency behavior seen in PSDS.

Overall, PSLTDSim can simulate small or gradual perturbances with acceptable dynamic accuracy when compared to PSDS. System frequency response and real power flow results are typically better than voltage and reactive power data. This is due to the various model simplifications and assumptions in PSLTDSim. Despite transient differences, simulated long-term system behavior in PSLTDSim tends to converge to PSDS values. As such, PSLTDSim simulation was deemed to be validated for the purpose of long-term simulation.

5. Engineering Applications

PSLTDSim may be used to study numerous engineering issues related to power system planning and operation. Due to time and data availability constraints, specific software applications to engineering problems are presented, but specific solutions are not. This chapter contains descriptions of various events of engineering interest that PSLTDSim can simulate, relevant NERC standards for long-term simulation, simulated control options not previously expanded upon, and engineering application studies and results.

5.1. Simulated Events of Interest

The initial focus of PSLTDSim was to study governor and AGC interaction. Reasoning behind this decision was that observed primary response has declined [16], or become slower, while technological advances have enabled AGC action to become faster. The gradual shifting, and resulting overlap, of operation time involved with automatic controls seemed like a good application for LTD simulation. To refine the focus of study, a goal of minimizing system effort while maximizing system stability was developed.

Historically, the number of control pulse signals was used to judge the efficiency of an AGC scheme [7]. Modern control can not be accurately assessed in such a general way. To more reasonably gauge system effort, a metric of governor valve travel was suggested. Valve travel can be greatly affected by various settings such as deadbands and delays. Examples of cumulative valve travel in response to random noise were simulated in PSLTDSim to investigate the effect of certain parameters.

In practice, AGC actions can vary greatly. PSLTDSim offers a BA agent that includes some common AGC control techniques. To configure, or tune, an AGC routine requires long-term simulation as gradual system recovery is beyond the transient stability time frame. AGC action in one area affects all connected areas and conflicting control schemes may increase system recovery time. An example of AGC tuning is presented and conditional AGC action examined.

To show the ability of PSLTDSim to handle long-term events, a four hour morning peak

scenario and a two hour virtual wind ramp were simulated. Generation and load controller agents in PSLTDSim were used to program long duration ramps of system generation and load that use real forecast demand data. During initial simulations, it became apparent that voltage management must be accounted for. Realistically, capacitor switching or other schemes are used to managed voltage and reactive power. In PSLTDSim, a DTC agent was programmed to act as a capacitor bank controller.

Finally, the customizability and open-source nature of PSLTDSim allows for other power system phenomena to be studied. An example of governor action modification using a DTC agent to reproduce an undesired response is presented. Frequency response effects due to system damping and system inertia modification are also demonstrated.

5.2. Relevant NERC Standards

As alluded to earlier, the BES is not operated in any old higgledy-piggledy fashion. NERC has various mandatory standards subject to enforcement in the US that are continuously modified and updated. Standards starting with BAL are related to resource and demand balancing. BAL standards that are applicable to LTD simulation are described in this section. As time clicks forward, and NERC standards change, presented information is predicted to become out of date.

The most up-to-date mandatory standards can be viewed on the NERC website [44].

5.2.1. BAL-001-2

NERC standard BAL-001-2 has two requirements. The first requirement deals with a monthly calculation that is out of the scope of PSLTDSim. The second requirement specifies RACE should not exceed its clock-minute balancing authority ACE limit (BAAL) for more than 30 consecutive clock minutes [43]. This requirement is important as PSLTDSim can simulate longer than 30 minutes. NERC has provided the following equations describing how to calculate BAAL.

$$BAAL = -10B(FTL - F_s) \frac{FTL - F_S}{F_A - F_S} \quad (18)$$

Where the frequency trigger limit (FTL) is defined as

$$FTL = F_S \pm 3\epsilon. \quad (19)$$

If actual system frequency F_A is above the scheduled frequency F_S , then the \pm in equation 19 is a $+$. If the opposite is true ($F_A < F_S$), then the \pm is a $-$. NERC provides fixed values for each interconnection to use for ϵ . In the WECC, NERC defines ϵ as 0.0228 Hz. Note that minute average frequency is used for F_A in Equation 18. Figure 113 visualizes the NERC equations for various settings of B. When frequency is at its nominal value, ACE is unlimited. Larger values of B equate to larger values of BAAL. The logical statement shown in Equation 20 will be true if BAAL has been exceeded.




Figure 113: Balancing authority ACE limit for different values of B.

$$BAAL_{exceeded} = \begin{cases} (BAAL > 0) \text{ AND } (RACE > BAAL) \\ (BAAL < 0) \text{ AND } (RACE < BAAL) \end{cases} \quad (20)$$

5.2.2. BAL-002-3

NERC standard BAL-002-3 requires a BA to return reporting ACE to zero if pre-contingency ACE was positive or zero, or the pre-contingency value if ACE was negative within the contin-

gency event recovery period. The NERC definition for contingency event recovery period is 15 minutes after the start of a contingency [46].

5.2.3. BAL-003-1.1

NERC standard BAL-003-1.1 deals with the frequency bias setting used by a BA. While realistic frequency bias B is calculated based on real system values and recorded responses, this doesn't apply to theoretical models. For simplicity, a setting of 0.9% maximum generation capacity will be used for the minimum fixed value of B . This setting is in line with recommendations made in [42].

5.2.4. NERC Standard Summary

To follow NERC recommendations, a minimum frequency bias B of 0.9% maximum generation capacity will be used for all BAs RACE calculation. RACE must return to zero or the pre-contingency level within 15 minutes of a contingency. Since simulated systems start from a steady state, this could be interpreted as frequency crossing zero at least once every 15 minutes. Finally, any control that allows for more than 30 consecutive minutes of RACE exceeding the BAAL will not be acceptable.

5.3. Simulated Balancing Authority Controls

Simulated balancing authority controls affect governor response and AGC operation.

These controls are defined in the sysBA dictionary in the .ltd.py file. Figure 114 shows an example of a BA parameter dictionary as it would appear in a .ltd.py file. A complete list of BA agent options is shown in Table XVI in Appendix 11. The following sections detail most sysBA dictionary keys.

```

1  # Balancing Authority Definition
2  mirror.sysBA = {
3      'BA1':{
4          'Area': 1,
5          'B': "0.9 : permax", # MW/0.1 Hz
6          'AGCActionTime': 30.00, # seconds
7          'ACEgain' : 1.0,
8          'AGCType':'TLB : 4', # Tie-Line Bias
9          'UseAreaDroop' : False,
10         'AreaDroop' : 0.05,
11         'IncludeIACE' : True,
12         'IACEconditional': True,
13         'IACEwindow' : 30, # seconds - size of window - 0 for non window
14         'IACEScale' : 1/5,
15         'IACEdeadband' : 0, # Hz
16         'ACEFiltering': 'PI : 0.04 0.0001',
17         'AGCDeadband' : None, # MW? -> not implemented
18         'GovDeadbandType' : 'nldroop', # step, None, ramp, nldroop
19         'GovDeadband' : .036, # Hz
20         'GovAlpha' : 0.016, # Hz - for nldroop
21         'GovBeta' : 0.036, # Hz - for nldroop
22         'CtrlGens': ['gen 1 : 0.5 : rampA',
23                      'gen 2 1 : 0.5 : rampA',
24                      ],
25     }
26 }
```

Figure 114: Single sysBA dictionary definition.

5.3.1. Governor Deadbands

Modeling governor deadbands has become increasingly important to dynamic simulation [33], [48], [49]. The maximum recommended deadband is 36 mHz[18]. However, the execution of a governor deadband is not explicitly detailed and left to generator operators to configure. PSLTDSim offers a deadband agent that can apply various deadbands to the $\Delta\omega$ input of governors. Figure 115 graphically depicts how the various available deadband options differ.




Figure 115: Examples of available deadband action.

A step deadband simply nullifies any $\Delta\omega$ whose absolute value is less than the prescribed deadband. A no-step, or ramp, deadband removes the step characteristic by essentially pushing the original droop curve out to deadband thresholds. While the no-step deadband has no abrupt changes, the actual governor response will always be below the ideal droop response. To eliminate this oversight, a non-linear droop option was created that ramps from a set Hz deadband to the ideal droop curve.

Configuring a deadband is done via the sysBA parameter dictionary or the governor deadband dictionary in a .ltd.py file. The dictionary keys are the same in the sysBA dictionary as the govDeadBand dictionary. Details about creating deadbands using a governor deadband dictionary is presented in Section 4.3.2.3.7.

5.3.2. Area Wide Governor Droops

The typically recommended FERC droop is 5%[18]. Area wide governor droops can be specified in the sysBA dictionary that overwrite any droop setting previously read from a .dyd. All active governors in an area will use the specified ‘AreaDroop’ value if ‘UseAreaDroop’ is True. This setting allows for fast and easy configuration of simulations aimed at exploring droop settings.

5.3.3. Automatic Generation Control

A block diagram of the AGC model employed by PSLTDSim is shown in Figure 116. Simulation settings related to frequency bias, ACE integrating and filtering, conditional summing, and generation participation are explained in the following sections.




Figure 116: Block diagram of ACE calculation and manipulation.

5.3.3.1. Frequency Bias

Choosing a desired frequency bias B can be accomplished in a number of different ways. All methods are configured by the string entered as the ‘B’ value in the sysBA dictionary. The format of the ‘B’ string is ”Float Value : B type”. The available B types are scalebeta, perload, permax, and abs.

The scalebeta type will scale the automatically calculated area frequency response characteristic β by the given float value. The perload type will set B equal to the current area load times the given float value. The permax type will set B equal to the maximum area capacity times the given float value. The abs type will set B equal to the given float value. Note that the units on B are MW/0.1 Hz and, despite B being a negative number, is entered as a positive value.

A variable frequency bias may be used in distributed ACE signals. If the ‘BVgain’ dictionary entry is a non-zero value, a variable frequency bias B_V is calculated as

$$B_V = B_F (1 + K_B |\Delta\omega|) \quad (21)$$

where B_F is the fixed bias value, and K_B is the user entered value for ‘BVgain’. It should be noted that $\Delta\omega$ is calculated according to Equation 5 and is a PU value. This leads to seemingly large required values of ‘BVgain’ before effects are noticeable. To clarify, B_V is only used in ACE calculations that are meant to be distributed to the generation fleet, RACE is always calculated using B_F .

5.3.3.2. Integral of Area Control Error

As previously shown in Figure 116, ACE may be integrated and fed back into the conditional summing block. The default signal sent to the integrator is RACE as AGC is meant to drive RACE to zero. Settings related to this process are configured in the sysBA dictionary. Integral of ACE (IACE) parameters are ‘IACEwindow’, ‘IACEScale’, and ‘IACEDeadband’. IACEwindow defines the length in seconds of the moving window integrator. If IACEwindow is set to zero, integration will be continuous (i.e. for all time). IACEScale acts as a gain of the output integral value. IACEDeadband specifies the frequency deviation in Hz between which integration values will stop being added into the conditional summing block. IACEDeadband functionality was meant to alleviate frequency hunting.

5.3.3.3. Conditional Area Control Error Summing


Depending on the type of AGC agent chosen, ACE is calculated in different ways. The Tie-Line Bias (TLB) agent has multiple types of conditional ACE calculations. All conditionals involve comparing the sign of a value to the sign of frequency deviation. The main idea behind this conditional summing is to ensure that only events occurring inside an area will receive an AGC response. Options are available to allow for continued frequency response as well. Table VIII shows the conditional summations and associated TLB type.

Table VIII: Tie-line bias AGC type ACE calculations.

TLB Type	ACE Calculation
0	$ACE_{FB} + ACE_{TL}$
1	$ACE_{FB} + ACE_{TL} * [\text{sgn}(\Delta\omega) == \text{sgn}(ACE_{TL})]$
2	$ACE_{FB} + ACE_{TL} * [\text{sgn}(\Delta\omega) == \text{sgn}(ACE_{FB} + ACE_{TL})]$
3	$ACE_{FB} * [\text{sgn}(\Delta\omega) == \text{sgn}(ACE_{FB})] + ACE_{TL} * [\text{sgn}(\Delta\omega) == \text{sgn}(ACE_{TL})]$
4	$[ACE_{FB} + ACE_{TL}] * [\text{sgn}(\Delta\omega) == \text{sgn}(ACE_{FB} + ACE_{TL})]$

5.3.3.4. Area Control Error Filtering

The calculated ACE can be put through a filter, or smoothed, to become smoothed ACE (SACE). The three basic filters created were low pass, integral, and proportional and integral (PI). Block diagrams of these filters are shown in Figure 117.

**Figure 117: Block diagrams of optional ACE filters.**

The selection and configuration of a filter is done in the BA parameter dictionary via the ‘ACEFiltering’ key value. The format of the string input to the ‘ACEFiltering’ key is ”type : val1 val2”. Valid filter types are lowpass, integrator, and pi. The low pass and integrator take only one value while the PI filter takes two. In the case of the low pass filter, the passed in value is set as the low pass time constant. The value passed in with an integrator filter is simply a gain. The first PI value is used as a proportional gain value K_p and the second value describes the ratio between integral and proportional gain a .

5.3.3.5. Controlled Generators and Participation Factors

Each BA is configured with a list of controlled generators that receive AGC signals. These generators, or power plants, are given a participation factor between 1.0 and zero. The participation factor dictates the percent of ACE signal each agent receives. A check is done to ensure each BA has a total participation factor of one, however, if the sum of participation factors is not one, only a warning is issued. It is up to the user to enter reasonable values. Additionally, each list value of the ‘CtrlGens’ key describes if the signal should be applied as a step or a ramp. Ramps are best when single units are receiving ACE, while steps are useful for power plants that are intended to handle distribution of ACE independently.

5.4. Governor Deadband Effect on Valve Travel

Initial research goals included maximizing system stability while minimizing machine effort. The decided upon metric for machine effort was valve travel. As governor deadbands directly affect valve travel, a study into deadbands was conducted using PSLTDSim.

5.4.1. Governor Deadband Simulation Configuration

To assess long-term impacts of governor deadbands, thirty minutes of random load noise was applied to the mini WECC. All governors had identical deadband settings and PSLTDSim was used to set all governor droops to 5%. Some governors were removed from the system so that only $\approx 20\%$ of generation capacity in each area had governor control. Each type of deadband shown in Figure 115 was simulated. No-step and non-linear droop deadbands had a threshold of 16 mHz while the step deadband used a 36 mHz deadband. Noise agent N_Z was set to 0.03 for all simulations with random walk behavior enabled. The change in system loading caused by the noise agent is shown in Figure 118.




Figure 118: Cumulative system change in load for governor deadband simulation.

Another experiment was conducted to explore a non-homogeneous deadband scenario where all deadbands were of the no-step type, but some had different mHz deadbands. Although PSLTDSim can model AGC, it was not enabled for these deadband simulations.

5.4.2. Governor Deadband Simulation Results

Figure 119 shows the resulting system frequency for each type of deadband. The step deadband holds frequency almost exactly on the set deadband except when system loading decreases during minutes 7-11. The other deadband options maintain system frequency near their respective mHz setting until loading increases beyond a point near minute 17.




Figure 119: System frequency comparison of different deadband scenarios.

The first three minutes of a single generator's valve travel are shown in Figure 120 to compare how different deadbands affect valve movement. The step type deadband results in pulse train-esque control signals being sent when system frequency is oscillating near the deadband.




Figure 120: Detail comparison of initial valve movement.

With all governors using a no-step type deadband, two of the three areas mHz deadband was set to 16.6 mHz, while the third was set to 36 mHz. The left plot of figure 121 shows average valve travel over time in a homogeneous deadband system while the right plot shows non-homogeneous valve travel results. In the homogeneous case, all areas have equal valve travel. In

the non-homogeneous case, the larger deadband used in area 3 prevents governor response until minute 18.




Figure 121: Area valve travel for homogeneous and non-homogeneous scenarios.

Complete valve travel result plots are presented in Appendix 12. A tabular summary of valve travel is shown in Table IX. Repeated control pulses associated with a step type deadband greatly increase valve travel over the more linear deadband options. Simulation results reinforce NERC recommendations that step deadbands not be used [18]. When a variety of deadband thresholds are employed, total valve travel may decrease while certain individual movement increases.

Table IX: Total valve travel for various deadband scenarios.

Generator	Valve Travel [PU]					
	No DB	Step	No-Step	N-L Droop	No-Step Non-H	
17	0.16	7.48	0.15	0.23	0.19	
23	0.16	7.48	0.15	0.23	0.19	
30	0.16	7.48	0.15	0.23	0.19	
32	0.16	7.54	0.15	0.23	0.19	
107	0.16	7.54	0.15	0.23	0.19	
41	0.15	6.44	0.14	0.23	0.06	
45	0.15	6.44	0.14	0.23	0.06	
53	0.16	7.54	0.15	0.23	0.06	
59	0.15	6.44	0.14	0.23	0.06	
Total:	1.41	64.38	1.32	2.07	1.19	

5.5. Automatic Generation Control Tuning

After a contingency, AGC acts to restore nominal operating conditions. Long-term simulation is required to simulate AGC action as gentle system recovery takes multiple minutes. According to [31], AGC should respond only to internal events or to correct frequency. PLSTDSim simulations using conditional AGC provide results that show conflicting AGC action extends recovery time and increases machine effort.

5.5.1. AGC Simulation Configuration

Using the two area six machine system, a 150 MW loss of generation event in each area was used to tune AGC response to a large contingency. AGC settings were manipulated until an individual BA could restore system frequency in less than 10 minutes. The effect of noise and non-linear governor deadbands was also simulated. Random noise added to each simulation is shown in Figure 122. Conditional ACE was used to show conflicting control effort when a BA responds to out-of-area events.




Figure 122: Random noise added to AGC simulations.

Full code for simulating an external area event with tuned conditional AGC is shown in Figures 187 and 188 in Appendix 10.

5.5.2. AGC Simulation Results

5.5.2.1. Base Case Results

Using the two area six machine system, a -150 MW step in generator power was simulated. Figure 123 shows the system frequency response with primary control only.




Figure 123: Frequency response to generation loss event in area 1.

Calculated BA values such as, reporting ACE (RACE) and interconnection (IC) error, will be different depending on where the system loss occurs. Specifically, which area the event occurs in dictates BA values. Figures 124 and 125 show BA values for the -150 MW generation step event in area 1 and area 2 respectively.




Figure 124: Calculated BA values during generation loss event in area 1.




Figure 125: Calculated values during generation loss event in area 2.

In a two area system, IC error is symmetric and the scaling of RACE by frequency bias can be clearly seen. The odd transient behavior observed in BA2 RACE when the event occurs in area 1 is not fully understood. It may be due to the multiple generators per bus. When a step in P_m occurs to a single bus generator, as Figure 125 shows, the odd RACE behavior is not replicated. To observe system response without any AGC action, AGC gain was set to zero for both areas causing distributed ACE (DACE) to also be zero.

5.5.2.2. AGC Tuning Results

The AGC tuning process and results from both areas were similar. Area 1 results and discussion are presented in this section and area 2 results are included in Appendix 13. The BA controlling area 1 was equipped with an AGC routine that included a scaled window integrator, PI smoothed ACE, and an action time of 30 seconds. Resulting frequency response is shown in Figure 126. Calculated RACE, IC error, and DACE are shown in Figure 124.




Figure 126: AGC Frequency response to area 1 base case scenario.




Figure 127: Calculated BA values during area 1 AGC tuning.

Figures 128 and 129 show governor power output and power reference set point responses for each area. During AGC tuning, ACE gain was set to zero for the BA routine not being tuned. As such, area 2 has no P_{ref} changes while area 1 adjusts its controlled governors to return RACE to zero. The effect of AGC on P_{ref} for generator 1 and generator 2 1 is identical.




Figure 128: Area 1 controlled generation response during AGC tuning.




Figure 129: Area 2 controlled generation response during AGC tuning.

5.5.2.3. Noise and Deadband Simulation Results

To add slightly more realism to the event, noise and governor deadbands were added to the simulation. Noise was set to 0.05% with random walk enabled. All AGC controlled governors were of the non-linear droop variety with an α of 16 mHz and a β of 36 mHz. Resulting frequency is shown in Figure 130. System frequency oscillations between governor deadbands occurs from roughly minute 6 onwards.




Figure 130: AGC frequency response with noise and deadbands.

Figures 131, 132, and 133 show calculated BA values and individual area controlled machine responses respectively. Despite the addition of noise and governor deadbands, system recovery is similar to ideal simulation conditions.




Figure 131: Calculated BA values with noise and deadbands.




Figure 132: Area 1 controlled generation response to noise and deadbands.




Figure 133: Area 2 controlled generation response to noise and deadbands.

5.5.2.4. Conditional ACE Results

After tuning for both BA AGC routines was complete, conditional ACE could be tested.

Comparing TLB type 0, which is non-conditional, and conditional TLB type 4 involved enabling AGC action for both areas and simulating an in-area, and out-of-area event. Figure 134 shows that system frequency does not return to the nominal operating point in 10 minutes when TLB 0 is used. Figure 135 shows that BA2 DACE acts opposite BA1 DACE.




Figure 134: Frequency response to event using TLB 0.




Figure 135: Calculated BA values during an event using TLB 0.

To more clearly show conflicting control action, Figures 136 and 137 provide individual area control responses. While BA1 acts to restore frequency by increasing generator output, BA2 acts to restore area interchange by reducing generator output. These control actions are opposite and thus prolong system recovery.




Figure 136: Area 1 controlled generation response to internal area event using TLB 0.




Figure 137: Area 2 controlled generation response to external area event using TLB 0.

Figure 138 shows system frequency response when each BA is set to send conditional

ACE according to TLB type 4 rules. Similar behavior to the noise and deadband only scenario is reproduced. Calculated BA values in Figure 139 show that BA2 DACE is zero for the event. As the event is external to area 2, it does not require a response from BA2.




Figure 138: Frequency response to event using TLB 4.




Figure 139: Calculated BA values during an event using TLB 4.

Figures 140 and 141 show that controlled machine response is similar to tuned conditions when using TLB type 4. The P_{ref} AGC response in area 2 near minute 7 is believed to be due to a combination of random load changes affecting area interchange and frequency oscillations caused by governor deadbands.




Figure 140: Area 1 controlled generation response to internal area event using TLB 4.




Figure 141: Area 1 controlled generation response to external area event using TLB 4.

While an internal event to area 1 is external to area 2, and vice versa, to thoroughly test conditional AGC behavior, an event was simulated in area 2 using both TLB 0 and TLB 4. Results were similar to previously conducted conditional AGC tests. For completeness, plotted results are presented in Appendix 13.

5.5.2.5. BAAL Results

Even though this scenario is not longer than 30 minutes, an introduction to the plots used to check for control adherence to BAL-001-2 is worthwhile. As a reminder, BAL-001-2 deals with BAAL, which is calculated using Equation 18 and a minute averaged frequency.

The slowest AGC recovery case, which used non-conditional AGC, was chosen for study into BAAL. Figure 142 shows RACE exceeded the BAAL for nearly 4 minutes in area 1 during the simulated event. Area 2 BAAL, shown in Figure 143, was exceeded immediately following the perturbation again and briefly near minute 3. In both areas, AGC action reduced RACE to

acceptable levels before any NERC violations occurred.




Figure 142: Area 1 BAAL during internal area event using TLB 0.




Figure 143: Area 2 BAAL during external area event using TLB 0.

5.5.3. AGC Result Summary

In general, simulations show governor deadbands may lead to frequency oscillation between response thresholds and conditional AGC can be used to avoid unnecessary and contradictory recovery action between areas. While BAAL was exceeded, AGC action resolved any excess before a violation occurred.

5.6. Long-Term Simulation with Shunt Control

Long-term simulations of interest required shunt control to manage voltage. Without voltage control, load changes eventually caused the power-flow solution to diverge. Scenarios chosen for simulation were a four hour morning peak and a two hour virtual wind ramp.

5.6.1. Morning Peak Forecast Demand Simulation

The same six machine two area system and tuned AGC controllers from the previous section were used for long-term simulations. Definite time controllers (DTCs) were used to switch shunts according to bus voltage. Publicly available EIA data was parsed and used to parameterize hourly forecast and demand agents. Data was selected from the morning peak on December 11, 2019 starting at 5:00 AM as reported by the Bonneville Power Administration and California ISO BAs. Normalized reported BA area power changes are shown in Figure 144. Simulated BA1 followed Bonneville data while BA2 adhered to California data. The selected forecast scenario was simulated under ideal conditions and then with the inclusion governor deadbands and load noise. Figure 145 shows the random noise added to area 2 caused load value to decrease much more than area 1. The .ltd.py file used for the forecast demand scenario with noise and deadbands is shown in Appendix 10 as Figure 189.




Figure 144: Normalized forecast and demand of parsed EIA data.




Figure 145: Changes in load caused by noise agent action during morning peak.

5.6.1.1. Morning Peak Forecast Demand Results

Figures 146 and 147 show the gradual increase of area real power load P , and generated electrical power P_e . Near constant differences between generation and load is maintained by AGC action throughout the entire simulation. The decreased load due to random noise in area 2 is somewhat apparent in Figure 147.




Figure 146: Morning peak area P_e and Load.




Figure 147: Morning peak area P_e and Load with noise and governor deadbands.

AGC action maintained system frequency near the nominal values. Figure 148 shows that system frequency response without the addition of deadbands or noise varied less than 1.5 mHz. Figure 149 shows that when deadbands and noise are included, frequency tended to oscillate between governor deadbands. A detail view of system frequency, shown in Figure 150, revealed the oscillation to have a rate of approximately 4 mHz.




Figure 148: Morning peak system Frequency.




Figure 149: Morning peak system frequency with noise and governor deadbands.




Figure 150: Detail morning peak system frequency with noise and governor deadbands.

Figure 151 shows calculated BA values during an ideal scenario never exceeded a magnitude of 1 MW. Calculated values when noise is included became more busy, but generally oscillated between ± 10 MW. Figure 153 shows a clearer correlation between RACE and system frequency.




Figure 151: Morning peak calculated BA values.




Figure 152: Morning peak calculated BA values with noise and governor deadbands.




Figure 153: Detail morning peak calculated BA values with noise and governor deadbands.

Figures 154 and 155 show the BAAL from each scenario was never exceeded. Results from the BA in area 2 were similar and are presented in Appendix 14. As BAAL gets very large when frequency is near its nominal value, plot y-axes were scaled to 1.25 minimum and maximum RACE values.




Figure 154: BAAL of area 1 during morning peak.




Figure 155: BAAL of area 2 during morning with noise and governor deadbands.

While AGC handles the balancing of generation to load, and thus frequency, voltage must be handled via DTC action. Figures 156 and 157 show shunt bus voltage under ideal conditions and with load noise and governor deadbands, respectively. As load increased, bus voltage declined. The steps in voltage were caused by capacitive shunts being switched into the system according to programmed DTC parameters. The random noise added generally reduced load, so shunt switching is slightly delayed when noise is applied compared to the ideal scenario.




Figure 156: Morning peak system shunt bus voltage.




Figure 157: Morning peak system shunt bus voltage with noise and governor deadbands.

Figures 158 and 159 show the active capacitive load on system bus 8 and 9. DTC action switches capacitors on as voltage drops according to user input logic. Bus 8 has faster acting shunts and thus switches all available caps on before any on bus 9 can respond. Again, the random noise causes a delay in voltage drop and shunt switching as the random noise acts to generally reduce load.




Figure 158: Morning peak system shunt bus MVAR.




Figure 159: Morning peak system shunt bus MVAR with noise and governor deadbands.

5.6.2. Morning Peak Forecast Demand Result Summary

The tuned AGC routines adequately manage frequency and interchange during the event. DTC action functioned to manage bus voltage as desired. Declining voltages at the end of the simulation was due to the system not having any more shunts to switch on. Therefore, if this event were real, the addition of more switchable capacitive shunts might be suggested.

5.6.3. Virtual Wind Ramp Simulation

A virtual wind ramp similar to the one created in [29] was simulated using PSLTDSim. Two ungoverned generators were ramped up, held, and then ramped down. More specifically, using the six machine system, generator 2 2 in area 1 was altered 150 MW while generator 5 in area 2 was changed 300 MW. The generation ramps were 45 minute in duration. The first ramp began at $t = 300$, or 5 minutes into the simulation. A pause of 20 minutes is included between the end of the ramp up and beginning of ramp down. The wind ramp is finished by minute 115, but the simulation continued for another 20 minutes so system recovery could be observed. AGC settings for area 2 were modified from the forecast demand case to include generator 4 receiving 30.0% of AGC signals. This was required as AGC would force generator 3 to supply 0 MW otherwise. Random noise injections into the system loads shown in Figure 160 acted to generally reduce load in area 2.




Figure 160: Changes in load caused by noise agent action during virtual wind ramp.

5.6.3.1. Virtual Wind Ramp Results

Figures 161 and 162 show the ramping up behavior of generators 2 2 and 5 as well as the AGC effect on controlled generators. General behavior observed with added load noise and governor deadbands was similar to the ideal case.




Figure 161: Virtual wind ramp P_e distribution under ideal conditions.




Figure 162: Virtual wind ramp P_e distribution with noise and governor deadbands.

Figures 163 and 164 show system frequency response to the wind ramp under ideal conditions and with governor deadbands and load noise included respectively. In both cases, AGC was not able to achieve nominal system frequency during ramp events. Because the ramps are 45 minutes, this maintained frequency deviation is in violation of interpreted NERC mandate BAL-002-3. When noise and deadbands were included, and no ramp event was taking place, system frequency oscillated between deadband thresholds.




Figure 163: Virtual wind ramp system frequency under ideal conditions.




Figure 164: Virtual wind ramp system frequency with noise and governor deadbands.

Figure 165 shows calculated BA values during the virtual wind ramp under ideal conditions. It can be seen that DACE did not match RACE values during ramp events and that IC error was symmetric. Figure 166 shows that calculated BA values when noise and deadbands are included was slightly larger in magnitude than the ideal case. In both either case, maximum RACE does not exceed ± 15 MW.




Figure 165: Virtual wind ramp calculated BA values under ideal conditions.




Figure 166: Virtual wind ramp calculated BA values with noise and governor deadbands.

Figure 167 shows that AGC did a good job of maintaining near constant generator output P_e and that load does not change during the ideal scenario. Figure 168 shows similar AGC action despite added noise decreasing area 2 loading.




Figure 167: Virtual wind ramp area P_e and P_{load} under ideal conditions.




Figure 168: Virtual wind ramp area P_e and P_{load} with noise and governor deadbands.

Figures 169 and 169 show the BAAL from each scenario was never exceeded. Results from the BA in area 2 were to area 1 and are presented in Appendix 14. Plot y-axes were again scaled to 1.25 minimum and maximum RACE values.




Figure 169: Virtual wind ramp BAAL under ideal conditions.




Figure 170: Virtual wind ramp BAAL with noise and governor deadbands.

Figures 171 and 172 show that bus voltage between the two scenarios was fairly similar. As the ‘wind’ ramped up, bus voltage dropped and switched shunts stepped on to increase voltage. When the wind ramped down, bus voltage increased and controlled shunts were switched off. The decreased load caused by random noise triggers an additional capacitor to be switched off near minute 115.




Figure 171: Virtual wind ramp shunt bus voltage under ideal conditions.




Figure 172: Virtual wind ramp shunt bus voltage with noise and governor deadbands.

Figure 173 shows the MVAR injections caused by switched shunts under ideal conditions. As bus 8 has a ‘faster’ DTC routine, all available capacitors are turned on before bus 9 shunts activated during the ramp up event. The same is true when the wind ramped down; which left bus 9 shunts on. Figure 174 shows that added noise created a lower voltage on bus 9 and enabled a bus 9 shunt to switch on before all bus 8 capacitors were deployed. The additional bus 8 cap removal near time 115 was caused by random noise, but is obscured by the plot legend.




Figure 173: Virtual wind ramp shunt bus MVAR under ideal conditions.




Figure 174: Virtual wind ramp shunt bus MVAR with noise and governor deadbands.

5.6.4. Long-Term Simulation with Shunt Control Result Summary

In general, configured AGC handled area interchange and BAAL well, but may require further tuning to adequately automatically handle frequency during long ramps. However, this simulation did not account for tertiary action (people in the loop), and it is reasonable to assume a frequency deviation lasting over 15 minutes may be noticed and corrected. Simulated governor deadbands introduced system frequency oscillation between deadband thresholds. Bus voltage reference signals were used to effectively manage switched shunt operation. Addition of random noise caused very slight differences that had noticeable effects on automatic system response.

5.7. Feed-Forward Governor Action

PSLTDSim can be used to recreate system behavior. Interested parties expressed a concern with an undesirable governor response believed to be caused by feed-forward characteristics. The provided model of governors in question was described as a single block with no further information. Figure 175 is a plot of simulated and recorded generator power output that was provided as an example of undesirable behavior. A similar governor response was created using a DTC and governor input manipulation.




Figure 175: Provided information of undesired governor response.

5.7.1. Feed-Forward Governor Simulation Configuration

Using the six machine system with 0.5 second time step, a method of stepping governor P_{ref} while also gaining input $\Delta\omega_{PU}$ produced a similar undesirable response. Code used to define system generation step, governor delay, and DTC action is shown in Figure 176. In practice, this code would be user defined in the simulation .ltd.py file.

The perturbation list in Figure 176 specifies an ungoverned generator on bus 5 with a mechanical power step down of 100 MW at $t=20$. This was meant to simulate the tripping of a generator in an aggregated generator model. The governor delay dictionary was used to gain the $\Delta\omega$ input by 0.5. This was required so that steady state frequency did not over account for differences of $\Delta\omega$. The DTC action was defined to occur every 24 seconds and sets $P_{ref} = P_{ref0} + \frac{\Delta\omega}{R} M_{base} * 0.5$. While not truly a feed-forward control response, the stepping of P_{ref} was predicted to produce a similar result. Action time of 24 seconds was chosen so the first DTC response is near the simulated frequency nadir.

```

1  # Perturbances
2  mirror.sysPerturbances = [
3      'gen 5 : step Pm 20 -100 rel', # Step no-gov generator down
4  ]
5
6  # Delay block used as delta_w gain
7  mirror.govDelay ={
8      'delaygen2' : {
9          'genBus' : 2,
10         'genId' : '1', # optional
11         'wDelay' : (0, 0, .5), # gain of input w
12         'PrefDelay' : (0, 0)
13     },
14     #end of defined governor delays
15 }
16
17 # Definite Time Controller Definitions
18 mirror.DTCdict = {
19     'ffGovTest' : {
20         'RefAgents' : {
21             'ra1' : 'mirror : f',
22             'ra2' : 'gen 2 1 : R',
23             'ra3' : 'gen 2 1 : Pref0',
24             'ra4' : 'gen 2 1 : Mbase',
25         },# end Referenc Agents
26         'TarAgents' : {
27             'tar1' : 'gen 2 1 : Pref',
28         }, # end Target Agents
29         'Timers' : {
30             'set' :{ # set Pref
31                 'logic' : "(ra1 > 0)", # should always eval as true
32                 'actTime' : 24, # seconds of true logic before act
33                 'act' : "tar1 = ra3 + (1-ra1)/(ra2) * ra4 * 0.5 ", # step Pref
34             },# end set
35             'reset' :{ # not used in example
36                 'logic' : "0",
37                 'actTime' : 0, # seconds of true logic before act
38                 'act' : "0", # set any target On target = 0
39             },# end reset
40             'hold' : 0, # minimum time between actions (not used in example)
41         }, # end timers
42     },# end ffGovTest
43 }# end DTCdict

```

Figure 176: Long-term dynamic settings for feed-forward governor simulation.

5.7.2. Feed-Forward Governor Simulation Results

Simulation results for frequency, and generator electrical power are shown in Figures 177 and 178 respectively. The undesired response can be seen when power output is stepped beyond the steady state value.




Figure 177: Feed-forward governor frequency comparison.




Figure 178: Feed-forward governor electric power comparison.

While the produced behavior does resemble observed behavior, it is not an exact match. Scaling and actual response time differences are believed to be caused by differences in model size, governor time constants, and actual feed-forward action. A new governor model with more defined feed-forward capabilities could be created if simulated results on actual system-under-study are unsatisfactory.

5.8. Variable System Damping and Inertia

PSLTDSim can be used to estimate system behavior. To adjust frequency response, system damping and inertia may be manipulated. The trend of increased photo-voltaic penetration can lead to situations where total system inertia may not match what is expected. The single combined system inertia in PSLTDSim can be modified during simulations to enable study into variable inertia system responses.

5.8.1. Damping and Inertia Simulation Configuration

Damping effects were explored by modifying the "Dsys" value in the simParams dictionary of a simulation .py file. System inertia effects were studied by altering the "Hinput" in simParams dictionary and by perturbation agent action. A pulse train of load steps was created to present the ability to vary system inertia during a simulation. System inertia was altered before each positive load step. Code used to define perturbation steps is shown in Figure 179. In practice, this code would be user defined in the simulation .ltd.py file.

```

1 # Perturbances
2 mirror.sysPerturbances = [
3     # Initial system response
4     'load 8 : step P 2 100 rel',
5     'load 8 : step P 22 -100 rel',
6     # decrease of H
7     'mirror : step Hsys 40 -30 per',
8     'load 8 : step P 42 100 rel',
9     'load 8 : step P 62 -100 rel',
10    # decrease of H
11    'mirror : step Hsys 80 -50 per',
12    'load 8 : step P 82 100 rel',
13    'load 8 : step P 102 -100 rel',
14    # Increase of H
15    'mirror : step Hsys 120 30080 abs',
16    'load 8 : step P 122 100 rel',
17    'load 8 : step P 142 -100 rel',
18 ]

```

Figure 179: Long-term dynamic settings for variable system inertia simulation.

The code in Figure 179 steps the load on bus 8 up and down 100 MW every 20 seconds starting at t=2. System inertia is reduced by 30% at t=40, 50% at t=80, and then set to 30,080 MW s at t=120.

5.8.2. Damping and Inertia Simulation Results

System damping effects to a -100 MW generator step are shown in Figure 180. A positive damping value increased system oscillation while a negative damping value decreased oscillations. Altering system damping affected steady state frequency response.




Figure 180: Frequency effects of system damping.

Frequency response to scalings of system inertia are shown in Figure 181. The smH100 case was an un-modified system inertia, while the 90, 80 and 70 case appendings reflected a 90.0%, 80.0%, and 70.0% inertia scaling respectively. A scaling of 60.0% resulted with a power-flow problem that did not converge. As system inertia was decreased, frequency response became faster and frequency nadir increased.




Figure 181: Frequency effects of system inertia.

A single machine's valve response to inertia scalings are shown in Figure 182. Results resemble a reflected frequency response where lower inertia cases have larger and faster valve travel.




Figure 182: Governor response to varied system inertia.

Figure 183 shows the changes in system inertia caused by perturbation actions shown in Figure 179. Figure 184 shows system frequency response to a pulse train of load steps. Again, lower system inertia leads to faster frequency changes and larger frequency nadirs.




Figure 183: Varied system inertia during simulation.




Figure 184: System frequency response to varying system inertia.

Damping altered system frequency dynamic response and affected steady state frequency values. System inertia may be changed before or during a simulation. Noticeable effects of varying inertia were seen during step type contingencies. PSLTDSim is not particularly well suited for large steps, however, results showed that changes in system inertia during simulation were accounted for.

6. Conclusion

This work accomplished all software and engineering simulation goals. Using the ABM approach enabled modular expansion and facilitated large system scaling. Custom procedures may be inserted via the `.ltd.py` file and PSLTDSim models can be modified or created according to need. Multiple complete power system models of vastly different sizes were shown to be compatible with PSLTDSim.

Generated output data was validated against industry standard transient software. Simulation results of ramps or relatively small step perturbances were shown to be reproduced well in PSLTDSim. While differences between PSLTDSim and PSDS were found, many differences were expected and deemed within reason for long-term analysis of control validity and efficiency.

Software capabilities to model AGC, programmable logic controllers as DTCs, and dynamic governor models with optional deadbands, filters, and delays were created. Simulations were conducted of system conditions representing long-term engineering events-of-interest such as: AGC system recovery, daily load pattern recreation, and a virtual wind ramp. Through these scenarios it was shown that PSLTDSim could be used for AGC tuning, switched shunt coordination, and long-term event recreation. Available software capabilities also allowed for experimentation into system responses with random noise, modified system damping, and variable inertia situations.

The conducted engineering studies recreated various known phenomena. As NERC suggests, the use of step governor deadbands should be avoided as they increase valve travel. System frequency was shown to oscillate near or between governor deadbands. Conditional AGC should be employed to avoid conflicting area AGC action that prolongs recovery.

PSLTDSim is open source, available on PyPI, and may be expanded upon by future research. Various courses of action are suggested to allow PSLTDSim to become more useful. The main GitHub repository contains many example scenarios as well as **all** created source and validation code.

7. Future Work

As with any software project, future work revolves around expansion and refinement. The number of dynamic agents, or governor models, could be expanded without bound. Alternatively, a more refined way of casting un-modeled governors could be devised. A process involving automated one machine infinite bus scenarios, step analysis, and 2nd order approximation has been suggested.

Exponential load models and under-load transformer tap changers are things that should be accounted for. Power plant agents that act as plant controllers have been conceptually modeled, but not implemented to their full extent. To better capture voltage changes, and thus reactive power, some form of exciter modeling may be desired, although with the simplification of machine models, this task may prove difficult. Voltage scheduling of generator buses via perturbation agents should be possible, but is untested as of this writing.

PSLTDSim is open-source code that relies on proprietary software for essential functions. To move away from this reliance, a method for creating system models and solving power flows should be created. Any changes would have to be incorporated into the way PSLTDSim creates a system mirror, solves a power flow, and updates the mirror. A semi-clear point to break from PSLF would be when AMQP messages are sent. If PSLTDSim did not rely on PSLF, there would also be no need for AMQP messages to be sent as all code would be PY3. This would not only enable fully open-source simulation, but speed up simulation time and create a more straight forward code flow.

To accommodate for transient, or oscillatory events, PSLTDSim could be coupled with the ideas presented in [62]. This would involve a variable time step and some way to automatically switch between TSPF and CTS simulation.

8. Bibliography

- [1] .NET Foundation. (2018). Ironpython overview, [Online]. Available: <https://ironpython.net/>.
- [2] P. M. Anderson and A. A. Fouad, *Power System Control and Stability*, Second Edition. Wiley-Interscience, 2003.
- [3] J. Audenaert, K. Verbeeck, and G. V. Berghe. (2009). Mult-agent based simulation for boarding, CODeS Research Group, [Online]. Available: <https://www.semanticscholar.org/paper/Multi-Agent-Based-Simulation-for-Boarding-Audenaert-Verbeeck/24ba2c3190de5b7162c37e81581b062cda3e4d54>.
- [4] A. Aziz, A. Mto, and A. Stojsevski, “Automatic generation control of multigeneration power system,” Journal of Power and Energy Engineering, 2014.
- [5] J. Carpentier, “‘To be or not to be modern’ that is the question for automatic generation control (point of view of a utility engineer),” International Journal of Electrical Power & Energy Systems, 1985.
- [6] R. W. Cummings, W. Herbsleb, and S. Niemeyer. (2010). Generator governor and information settings webinar, North American Electric Reliability Corporation, [Online]. Available: <https://www.nerc.com/files/gen-governor-info-093010.pdf>.
- [7] F. P. deMello and R. Mills, “Automatic generation control part II - digital control techniques,” IEEE PES Summer Meeting, 1972.
- [8] DEQ. (2004). Montana electric transmission grid: Operation, congestion, and issues, DEQ, [Online]. Available: https://leg.mt.gov/content/publications/Environmental/2004deq_energy_report/transmission.pdf.
- [9] EIA. (2016). U.s. electric system is made up of interconnections and balancing authorities, [Online]. Available: <https://www.eia.gov/todayinenergy/detail.php?id=27152>.
- [10] EIA. (2019). July2019map.png, U.S. Energy Information Administration, [Online]. Available: <https://www.eia.gov/electricity/data/eia860m/>.
- [11] EIA. (2019). U.s. electric system operating data, U.S. Energy Information Administration, [Online]. Available: https://www.eia.gov/realtime_grid/.
- [12] EIA. (2019). U.s. energy mapping system, U.S. Energy Information Administration, [Online]. Available: <https://www.eia.gov/state/maps.php?v=Electricity>.
- [13] E. Ela and J. Kemper, “Wind plant ramping behavior,” National Renewable Energy Laboratory, 2009.

- [14] M. D. of Environmental Quality. (2020). Colstrip statistics, DEQ, [Online]. Available: <http://deq.mt.gov/DEQAdmin/mfs/AllColstrip/DEQAdmin/mfs>.
- [15] ERCOT. (2017). Ercot-internconnection_branded.jpg, ERCOT, [Online]. Available: <http://www.ercot.com/news/mediakit/maps>.
- [16] J. H. Eto, J. Undrill, C. Roberts, P. Mackin, and J. Ellis, “Frequency control requirements for reliable interconnection frequency response,” Energy Analysis and environmental Impacts Division Lawrence Berkeley National Laboratory, 2018.
- [17] D. Fabozzi and T. Van Cutsem, “Simplified time-domain simulation of detailed long-term dynamic models,” IEEE Xplore, 2009.
- [18] FERC, “Essential reliability services and the evolving bulk-power system–primary frequency response,” Federal Energy Regulatory Commission, Docket No. RM16-6-000 Order No. 842, Feb. 2018.
- [19] FERC. (2019). About ferc, [Online]. Available: <https://www.ferc.gov/about/about.asp>.
- [20] T. Garnock-Jones and G. M. Roy. (2017). Introduction to pika, [Online]. Available: <https://pika.readthedocs.io/en/stable/>.
- [21] GE Energy, *Mechanics of running pslf dynamics*, 2015.
- [22] GeeksforGeeks. (2017). Thread in operating system, GeeksforGeeks, [Online]. Available: <https://www.geeksforgeeks.org/thread-in-operating-system/>.
- [23] General Electric International, Inc, *PSLF User's Manual*, 2016.
- [24] W. B. Gish, “Automatic generation control algorithm - general concepts and application to the watertown energy control center,” Bureau of Reclamation Engineering and Research Center, 1980.
- [25] J. D. Glover, M. S. Sarma, and T. J. Overbye, *Power System Analysis & Design*, 5e. Cengage Learning, 2012.
- [26] R. Gonzales. (2019). Pg&e transmission lines caused california’s deadliest wildfire, state officials say, NPR, [Online]. Available: <https://www.npr.org/2019/05/15/723753237/pg-e-transmission-lines-caused-californias-deadliest-wildfire-state-officials-sa>.
- [27] M. Goossens, F. Mittelbach, and A. Samarin, *The L^TE_X Companion*. Addison-Wesley, 1993.

- [28] R. Hallett, "Improving a transient stability control scheme with wide-area synchrophasors and the microwecc, a reduced-order model of the western interconnect," Master's thesis, Montana Tech, 2018.
- [29] E. Heredia, D. Kosterev, and M. Donnelly, "Wind hub reactive resource coordination and voltage control study by sequence power flow," IEEE, 2013.
- [30] J. JMesserly. (2008). Electricity_grid_simple-_north_america.svg, United States Department of Energy, [Online]. Available: https://commons.wikimedia.org/wiki/File:Electricity_grid_simple-_North_America.svg.
- [31] T. Kennedy, S. M. Hoyt, and C. F. Abell, "Variable, non-linear tie-line frequency bias for interconnected systems control," IEEE Transactions on Power Systems, 1988.
- [32] Y. G. Kim, H. Song, and B. Lee, "Governor-response power flow (grpf) based long-term voltage stability simulation," IEEE T&D Asia, 2009.
- [33] G. Kou, P. Markham, S. Hadley, T. King, and Y. Liu, "Impact of governor deadband on frequency response of u.s. eastern interconnection," IEEE Transactions on Smart Grid, 2016.
- [34] D. Kuhlman, *A Python Book: Beginning Python, Advanced Python, and Python Exercises*. 2009.
- [35] P. Kundur, *Power System Stability and Control*. McGraw-Hill, 1994.
- [36] K. H. LaCommare and J. H. Eto, "Understanding the cost of power interruptions to u.s. electricity consumers," Ernest Orlando Lawrence Berkeley National Laboratory, 2004.
- [37] M. Liedtke. (2020). Court approves pg&e's \$23b bankruptcy financing package, AP News, [Online]. Available: <https://apnews.com/b70582ee8d4bb7f781553215612da993>.
- [38] P. Maloney. (2018). What is the value of electric reliability for your operation? [Online]. Available: <https://microgridknowledge.com/power-outage-costs-electric-reliability/>.
- [39] Y. Mobarak, "Effects of the droop speed governor and automatic generation control agc on generator load sharing of power system," International Journal of Applied Power Engineering, 2015.
- [40] NERC, "Frequency response initiative report," North American Electric Reliability Corporation, 2012.
- [41] NERC, "Procedure for ero support of frequency response and frequency bias setting standard," North American Electric Reliability Corporation, 2012.

- [42] NERC, “Standard bal-003-1.1 — frequency response and frequency bias setting,” North American Electric Reliability Corporation, 2015.
- [43] NERC, “Standard bal-001-2 – real power balancing control performance,” North American Electric Reliability Corporation, 2016.
- [44] NERC. (2017). About nerc, [Online]. Available: <https://www.nerc.com/AboutNERC/Pages/default.aspx>.
- [45] NERC. (2017). Nerc interconnections map, [Online]. Available: <https://www.nerc.com/AboutNERC/keyplayers/PublishingImages/NERC%20Interconnections.pdf>.
- [46] NERC, “Bal-002-3 – disturbance control standard – contingency reserve for recovery from a balancing contingency event,” North American Electric Reliability Corporation, 2018.
- [47] NERC, “Frequency response annual analysis,” North American Electric Reliability Corporation, 2018.
- [48] NERC, “Reliability guideline application guide for modeling turbine-governor and active power-frequency controls in interconnection-wide stability studies,” 2019.
- [49] NERC, “Reliability guideline primary frequency control,” 2019.
- [50] NERC. (2020). Glossary of terms used in nerc reliability standards, NERC, [Online]. Available: https://www.nerc.com/files/glossary_of_terms.pdf.
- [51] NERC Resources Subcommittee, “Balancing and frequency control,” North American Electric Reliability Corporation, 2011.
- [52] NERC Resources Subcommittee, “Bal-001-tre-1 — primary frequency response in the ercot region,” North American Electric Reliability Corporation, 2016.
- [53] P. W. Parfomak, “Physical security of the u.s. power grid: High-voltage transformer substations,” Congressional Research Service, 2014.
- [54] Python Software Foundataion. (2019). About python, [Online]. Available: <https://www.python.org/about/>.
- [55] B. Rand. (2018). Agent-based modeling: What is agent-based modeling? Youtube, [Online]. Available: <https://www.youtube.com/watch?v=FMqQbfsOkGc>.
- [56] C. W. Ross, “Error adaptive control computer for interconnected power systems,” IEEE Transactions on Power Apparatus and Systems, 1966.
- [57] G. van Rossum. (2009). A brief timeline of python, [Online]. Available: <https://python-history.blogspot.com/2009/01/brief-timeline-of-python.html>.

- [58] J. Sanchez-Gasca, M. Donnelly, R. Concepcion, A. Ellis, and R. Elliott, “Dynamic simulation over long time periods with 100% solar generation,” Sandia National Laboratories, SAND2015-11084R, 2015.
- [59] P. W. Sauer, M. A. Pai, and J. H. Chow, *Power System Dynamics and Stability With Synchrophasor Measurement and Power System Toolbox*, Second Edition. John Wiley & Sons Ltd, 2018.
- [60] SciPy developers. (2019). About scipy, [Online]. Available: <https://www.scipy.org/about.html>.
- [61] K. Siegel. (2012). The true cost of power outages, Yale Environment Review, [Online]. Available: <https://environment-review.yale.edu/true-cost-power-outages-0>.
- [62] M. Stajcar, “Power system simulation using an adaptive modeling framework,” Master’s thesis, Montana Tech, 2016.
- [63] C. W. Taylor and R. L. Cresap, “Real-time power system simulation for automatic generation control,” IEEE Transactions on Power Apparatus and Systems, 1976.
- [64] D. Trudnowski, “Properties of the dominant inter-area modes in the wecc interconnect,” Montana Tech, 2012.
- [65] T. Van Cutsem and C. Vournas, *Voltage Stability of Electric Power Systems*, 1st ed. Springer US, 1998.
- [66] WECC. (2015). About wecc, [Online]. Available: <https://www.wecc.org/Pages/AboutWECC.aspx>.

9. Six Machine System Details

Relevant values from PSLF tables describing the six machine system used are presented in this appendix. The ‘busd’ table from PSLF describing system buses is shown in Table X. The ‘secdd’ table from PSLF describing system lines is shown in Table XI. The ‘tran’ table from PSLF describing system transformers is shown in Table XII. The ‘gens’ table from PSLF describing system generators is shown in Table XIII. The ‘load’ table from PSLF describing system loads is shown in Table XIV. The ‘shunt’ table from PSLF describing system shunts is shown in Table XV. The dyd file used for validation is shown in Figure 185.

Table X: Six machine bus table.

BUS-NO	NAME	KV	TP	VSCHED	V-PU	DEG	AREA
6	6	138.00	1	1.00	0.9537	-15.91	1
7	7	138.00	1	1.00	0.9533	-16.07	1
8	8	138.00	1	1.00	0.9532	-16.52	1
9	9	138.00	1	1.00	0.9533	-16.54	2
10	10	138.00	1	1.00	0.9543	-16.14	2
11	11	138.00	1	1.00	0.9549	-15.78	2
1	1	22.00	0	1.00	1.0000	0.00	1
2	2	22.00	2	1.00	1.0000	11.41	1
3	3	22.00	2	1.00	1.0000	1.27	2
4	4	22.00	2	1.00	1.0000	1.27	2
5	5	22.00	2	1.00	1.0000	-10.72	2

Table XI: Six machine line table.

FROM	FNAME	FKV	TO	TNAME	TKV	CK	SE	R-PU	X-PU	B-PU	AF	AT
6	6	138.00	7	7	138.00	1	1	0.0001	0.001	0.0018	1	1
7	7	138.00	8	8	138.00	1	1	0.0001	0.001	0.0018	1	1
8	8	138.00	9	9	138.00	1	1	0.0001	0.001	0.0018	1	2
8	8	138.00	9	9	138.00	2	1	0.0001	0.001	0.0018	1	2
8	8	138.00	9	9	138.00	3	1	0.0001	0.001	0.0018	1	2
11	11	138.00	10	10	138.00	1	1	0.0001	0.001	0.0018	2	2
10	10	138.00	9	9	138.00	1	1	0.0001	0.001	0.0018	2	2

Table XII: Six machine transformer table.

FROM	FNAME	FKV	TO	TNAME	TKV	MVA	VNOMF	VNOMT	R	X	BMAG	AREA
1	1	22.00	6	6	138.00	100.00	22.00	138.00	0.00	0.10	0.00	1
2	2	22.00	7	7	138.00	100.00	22.00	138.00	0.00	0.10	0.00	1
3	3	22.00	11	11	138.00	100.00	22.00	138.00	0.00	0.10	0.00	2
4	4	22.00	11	11	138.00	100.00	22.00	138.00	0.00	0.10	0.00	2
5	5	22.00	10	10	138.00	100.00	22.00	138.00	0.00	0.10	0.00	2

Table XIII: Six machine generator table.

BUS-NO	NAME1	KV1	ID	PGEN	QGEN	IREG	AREA	MBASE	PMAX
1	1	22.00	1	261.40	82.90	1	1	900.00	1000.00
2	2	22.00	1	220.00	77.10	2	1	900.00	1000.00
2	2	22.00	2	220.00	77.10	2	1	900.00	1000.00
3	3	22.00	1	280.00	87.10	3	2	900.00	1000.00
4	4	22.00	1	280.00	87.10	4	2	900.00	1000.00
5	5	22.00	1	90.00	49.90	5	2	900.00	1000.00

Table XIV: Six machine load table.

BUS-NO	NAME	KV	ID	ST	PLOAD	QLOAD	AREA
8	8	138.00	1	1	600.00	100.00	1
9	9	138.00	1	1	750.00	100.00	2

Table XV: Six machine shunt table.

FROM	FNAME	FKV	ID	CK	ST	G-PU	B-PU	AREA
8	8	138.00	1	1	1	0.00	1.00	1
8	8	138.00	2	2	1	0.00	0.50	1
8	8	138.00	3	3	0	0.00	0.50	1
8	8	138.00	4	4	0	0.00	0.50	1
9	9	138.00	1	1	1	0.00	1.00	2
9	9	138.00	2	2	0	0.00	0.50	2
9	9	138.00	3	3	0	0.00	0.50	2
9	9	138.00	4	4	0	0.00	0.50	2

```

1 # Six Machine, all gens and govs the same
2 # exciters default settings
3
4 # Metering of frequency, current, and voltages
5 fmeta 1 "1" 22.00 "1 " : #9 0 1
6 ameta 1 "1" 22.00 "1 " : 0
7 vmeta 1 "1" 22.00 "1 " : 0
8
9 # current meters
10 imetr 6 ! ! ! 7 ! ! ! : #9 0
11 imetr 7 ! ! ! 8 ! ! ! : #9 0
12 imetr 8 ! ! ! 9 ! ! ! : #9 0
13 imetr 11 ! ! ! 10 ! ! ! : #9 0
14 imetr 10 ! ! ! 9 ! ! ! : #9 0
15
16 # loads (Using wlwscc on any load sets the dynamics characteristics of all loads.)
17 wlwscc 9 "9" 138.0 "1 " : #9 0.0 0.0 0.0 0.0 0.0 1.0 1.0 0.0 0.0 0.0 0.0 0.0
18
19 # generators
20 genrou 1 "1" 22.00 "1 " : #9 mva=900.00 "tpdo" 6.50 "tppdo" 0.079 "tpqo" 0.53 "tppqo" 0.072 "h" 4 "d"
  ↳ 0.0000 "ld" 1.24 "lq" 1.22 "lpd" 0.23 "lpq" 0.36000 "lppd" 0.17 "ll" 0.14 "s1" 0.173 "s12" 0.447 "ra"
  ↳ 0.0000 "rcomp" 0.0000 "xcomp" 0.0000 "accel" 1.0
21 genrou 2 "2" 22.00 "1 " : #9 mva=900.00 "tpdo" 6.50 "tppdo" 0.079 "tpqo" 0.53 "tppqo" 0.072 "h" 4 "d"
  ↳ 0.0000 "ld" 1.24 "lq" 1.22 "lpd" 0.23 "lpq" 0.36000 "lppd" 0.17 "ll" 0.14 "s1" 0.173 "s12" 0.447 "ra"
  ↳ 0.0000 "rcomp" 0.0000 "xcomp" 0.0000 "accel" 1.0
22 genrou 2 "2" 22.00 "2 " : #9 mva=900.00 "tpdo" 6.50 "tppdo" 0.079 "tpqo" 0.53 "tppqo" 0.072 "h" 4 "d"
  ↳ 0.0000 "ld" 1.24 "lq" 1.22 "lpd" 0.23 "lpq" 0.36000 "lppd" 0.17 "ll" 0.14 "s1" 0.173 "s12" 0.447 "ra"
  ↳ 0.0000 "rcomp" 0.0000 "xcomp" 0.0000 "accel" 1.0
23 genrou 3 "3" 22.00 "1 " : #9 mva=900.00 "tpdo" 6.50 "tppdo" 0.079 "tpqo" 0.53 "tppqo" 0.072 "h" 4 "d"
  ↳ 0.0000 "ld" 1.24 "lq" 1.22 "lpd" 0.23 "lpq" 0.36000 "lppd" 0.17 "ll" 0.14 "s1" 0.173 "s12" 0.447 "ra"
  ↳ 0.0000 "rcomp" 0.0000 "xcomp" 0.0000 "accel" 1.0
24 genrou 4 "4" 22.00 "1 " : #9 mva=900.00 "tpdo" 6.50 "tppdo" 0.079 "tpqo" 0.53 "tppqo" 0.072 "h" 4 "d"
  ↳ 0.0000 "ld" 1.24 "lq" 1.22 "lpd" 0.23 "lpq" 0.36000 "lppd" 0.17 "ll" 0.14 "s1" 0.173 "s12" 0.447 "ra"
  ↳ 0.0000 "rcomp" 0.0000 "xcomp" 0.0000 "accel" 1.0
25 genrou 5 "5" 22.00 "1 " : #9 mva=900.00 "tpdo" 6.50 "tppdo" 0.079 "tpqo" 0.53 "tppqo" 0.072 "h" 4 "d"
  ↳ 0.0000 "ld" 1.24 "lq" 1.22 "lpd" 0.23 "lpq" 0.36000 "lppd" 0.17 "ll" 0.14 "s1" 0.173 "s12" 0.447 "ra"
  ↳ 0.0000 "rcomp" 0.0000 "xcomp" 0.0000 "accel" 1.0
26
27 # exciters
28 sexs 1 "1" 22.00 "1 " : #1 0.1 10.0 100.0 0.05 -5.0 5.0 0.08 0.0 -5.0 5.0 0.0
29 sexs 2 "2" 22.00 "1 " : #1 0.1 10.0 100.0 0.05 -5.0 5.0 0.08 0.0 -5.0 5.0 0.0
30 sexs 2 "2" 22.00 "2 " : #1 0.1 10.0 100.0 0.05 -5.0 5.0 0.08 0.0 -5.0 5.0 0.0
31 sexs 3 "3" 22.00 "1 " : #1 0.1 10.0 100.0 0.05 -5.0 5.0 0.08 0.0 -5.0 5.0 0.0
32 sexs 4 "4" 22.00 "1 " : #1 0.1 10.0 100.0 0.05 -5.0 5.0 0.08 0.0 -5.0 5.0 0.0
33 sexs 5 "5" 22.00 "1 " : #1 0.1 10.0 100.0 0.05 -5.0 5.0 0.08 0.0 -5.0 5.0 0.0
34
35 # governors
36 tgov1 1 "1" 22.00 "1 " : #1 mwcap=800.0000 0.050000 0.4 1.000000 0.0 3.0000 10.0000 0.0
37 tgov1 2 "2" 22.00 "1 " : #1 mwcap=800.0000 0.050000 0.4 1.000000 0.0 3.0000 10.0000 0.0
38 tgov1 2 "2" 22.00 "2 " : #1 mwcap=800.0000 0.050000 0.4 1.000000 0.0 3.0000 10.0000 0.0
39 tgov1 3 "3" 22.00 "1 " : #1 mwcap=800.0000 0.050000 0.4 1.000000 0.0 3.0000 10.0000 0.0
40 tgov1 4 "4" 22.00 "1 " : #1 mwcap=800.0000 0.050000 0.4 1.000000 0.0 3.0000 10.0000 0.0

```

Figure 185: Dyd file used in six machine validations.

10. Code Examples

This appendix is used to present code examples too large for inclusion in the body of the text. Some examples span multiple pages. To adhere to document format requirements, the description of each code example is presented after the corresponding code figure.

```

1  # Format of required info for batch runs.
2
3  debug = 0
4  AMQPdebug = 0
5  debugTimer = 0
6
7  simNotes = """
8    AGC TUNING (no delay)
9    Delay over response test
10   Loss of generation in area 1 at t=2
11   Delayed action by area 2
12   AGC in both areas
13
14  # Simulation Parameters Dictionary
15  simParams = {
16      'timeStep': 1.0, # seconds
17      'endTime': 60.0*8, # seconds
18      'slackTol': 1, # MW
19      'PY3msgGroup' : 3, # number of Agent msgs per AMQP msg
20      'IPYmsgGroup' : 60, # number of Agent msgs per AMQP msg
21      'Hinput' : 0.0, # MW*sec of entire system, if !> 0.0, will be calculated in code
22      'Dsys' : 0.0, # Damping
23      'fBase' : 60.0, # System F base in Hertz
24      'freqEffects' : True, # w in swing equation will not be assumed 1 if true
25      # Mathematical Options
26      'integrationMethod' : 'rk45',
27      # Data Export Parameters
28      'fileDirectory' : "\\\delme\\\200109-delayScenario1\\", # relative path from cwd
29      'fileName' : 'SixMachineDelayStep1',
30      'exportFinalMirror': 1, # Export mirror with all data
31      'exportMat': 1, # if IPY: requies exportDict == 1 to work
32      'exportDict' : 0, # when using python 3 no need to export dicts.
33      'deleteInit' : 0, # Delete initialized mirror
34      'assumedV' : 'Vsched', # assumed voltage - either Vsched or Vinit
35      'logBranch' : True,
36  }

```

```

37
38 savPath = r"C:\LTD\pslf_systems\sixMachine\sixMachineTrips.sav"
39 dydPath = [r"C:\LTD\pslf_systems\sixMachine\sixMachineDelay.dyd"]
40 ltdPath = r".\testCases\200109-delayScenario1\sixMachineDelayStep1.ltd.py"

```

Figure 186: An example of a full .py simulation file.

```

1 # Format of required info for batch runs.
2 debug = 0
3 AMQPdebug = 0
4 debugTimer = 0
5
6 simNotes = """
7 agc with deadband and nz, area 2 perturbation TLB 4
8 """
9
10 # Simulation Parameters Dictionary
11 simParams = {
12     'timeStep': 1.0,
13     'endTime': 60.0*10,
14     'slackTol': 1,
15     'PY3msgGroup' : 3,
16     'IPYmsgGroup' : 60,
17     'Hinput' : 0.0, # MW*sec of entire system, if !> 0.0, will be calculated in code
18     'Dsys' : 0.0, # Untested
19     'fBase' : 60.0, # System F base in Hertz
20     'freqEffects' : True, # w in swing equation will not be assumed 1 if true
21     # Mathematical Options
22     'integrationMethod' : 'rk45',
23     # Data Export Parameters
24     'fileDirectory' : "\\\delme\\200325-smFinal\\", # relative path from cwd
25     'fileName' : 'smAGCt4Ex1',
26     'exportFinalMirror': 1, # Export mirror with all data
27     'exportMat': 1, # if IPY: requires exportDict == 1 to work
28     'exportDict' : 0, # when using python 3 no need to export dicts.
29     'deleteInit' : 0, # Delete initialized mirror
30     'assumedV' : 'Vsched', # assumed voltage - either Vsched or Vinit
31     'logBranch' : True,
32 }
33
34 savPath = r"C:\LTD\pslf_systems\sixMachine\sixMachineLTD.sav"

```

```

35 dydPath = [r"C:\LTD\pslf_systems\sixMachine\sixMachineLTD.dyd"]
36 ltdPath = r".\testCases\200325-smFinals\smAGCt4Ex1.ltd.py"

```

Figure 187: Required .py file for external AGC event with conditional ACE.

```

1 # Perturbances
2 mirror.sysPerturbances = [
3     'gen 5 : step Pm 2 -150 rel',
4 ]
5
6 mirror.NoiseAgent = ltd.perturbation.LoadNoiseAgent(mirror, 0.05, walk=True, delay=0,
7           damping=0, seed=11)
8
9 # Balancing Authorities
10 mirror.sysBA = {
11     'BA1':{
12         'Area':1,
13         'B': "0.9 : permax", # MW/0.1 Hz
14         'AGCActionTime': 30.00, # seconds
15         'ACEgain' : 1.0,
16         'AGCType':'TLB : 4', # Tie-Line Bias
17         'UseAreaDroop' : False,
18         'AreaDroop' : 0.05,
19         'IncludeIACE' : True,
20         'IACEconditional': True,
21         'IACEwindow' : 30, # seconds - size of window - 0 for non window
22         'IACEScale' : 1/5,
23         'IACEdeadband' : 0, # Hz
24         'ACEFiltering': 'PI : 0.04 0.0001',
25         'AGCDeadband' : None, # MW? -> not implemented
26         'GovDeadbandType' : 'nldroop', # step, None, ramp, nldroop
27         'GovDeadband' : .036, # Hz
28         'GovAlpha' : 0.016, # Hz - for nldroop
29         'GovBeta' : 0.036, # Hz - for nldroop
30         'CtrlGens': ['gen 1 : 0.5 : rampA',
31                      'gen 2 1 : 0.5 : rampA',
32                      ],
33     },
34     'BA2':{
35         'Area':2,
36         'B': "0.9 : permax", # MW/0.1 Hz
37         'AGCActionTime': 45.00, # seconds

```

```

37     'ACEgain' : 1.0,
38     'AGCType':'TLB : 4', # Tie-Line Bias
39     'UseAreaDroop' : False,
40     'AreaDroop' : 0.05,
41     'IncludeIACE' : True,
42     'IACEconditional': True,
43     'IACEwindow' : 45, # seconds - size of window - 0 for non window
44     'IACEscale' : 1/3,
45     'IACEdeadband' : 0, # Hz
46     'ACEFiltering': 'PI : 0.04 0.0001',
47     'AGCDeadband' : None, # MW? -> not implemented
48     'GovDeadbandType' : 'nldroop', # step, None, ramp, nldroop
49     'GovDeadband' : .036, # Hz
50     'GovAlpha' : 0.016, # Hz - for nldroop
51     'GovBeta' : 0.036, # Hz - for nldroop
52     'CtrlGens': ['gen 3 : 1.0 : rampA'],
53   },
54 }
```

Figure 188: Required .ltd file for external AGC event with conditional ACE.

```

1 mirror.NoiseAgent = ltd.perturbation.LoadNoiseAgent(mirror, 0.05, walk=True, delay=0,
2   ↳ damping=0, seed=11)
3
4 # Balancing Authorities
5 mirror.sysBA = {
6   'BA1':{
7     'Area':1,
8     'B': "0.9 : permax", # MW/0.1 Hz
9     'AGCActionTime': 30.00, # seconds
10    'ACEgain' : 1.0,
11    'AGCType':'TLB : 4', # Tie-Line Bias
12    'UseAreaDroop' : False,
13    'AreaDroop' : 0.05,
14    'IncludeIACE' : True,
15    'IACEconditional': True,
16    'IACEwindow' : 30, # seconds - size of window - 0 for non window
17    'IACEscale' : 1/5,
18    'IACEdeadband' : 0, # Hz
19    'ACEFiltering': 'PI : 0.04 0.0001',
20    'AGCDeadband' : None, # MW? -> not implemented
21    'GovDeadbandType' : 'nldroop', # step, None, ramp, nldroop
22  }
23 }
```

```

21     'GovDeadband' : .036, # Hz
22     'GovAlpha' : 0.016, # Hz - for nldroop
23     'GovBeta' : 0.036, # Hz - for nldroop
24     'CtrlGens': ['gen 1 : 0.5 : rampA',
25                   'gen 2 1 : 0.5 : rampA',
26                   ]
27   },
28   'BA2':{
29     'Area':2,
30     'B': "0.9 : permax", # MW/0.1 Hz
31     'AGCActionTime': 45.00, # seconds
32     'ACEgain' : 1.0,
33     'AGCType':'TLB : 4', # Tie-Line Bias
34     'UseAreaDroop' : False,
35     'AreaDroop' : 0.05,
36     'IncludeIACE' : True,
37     'IACEconditional': True,
38     'IACEwindow' : 45, # seconds - size of window - 0 for non window
39     'IACEScale' : 1/3,
40     'IACEdeadband' : 0, # Hz
41     'ACEFiltering': 'PI : 0.04 0.0001',
42     'AGCDeadband' : None, # MW? -> not implemented
43     'GovDeadbandType' : 'nldroop', # step, None, ramp, nldroop
44     'GovDeadband' : .036, # Hz
45     'GovAlpha' : 0.016, # Hz - for nldroop
46     'GovBeta' : 0.036, # Hz - for nldroop
47     'CtrlGens': ['gen 3 : 1.0 : rampA'],
48   },
49 }
50
51 # Load and Generation Cycle Agents
52 mirror.sysGenerationControl = {
53   'BPATDispatch' : {
54     'Area': 1,
55     'startTime' : 2,
56     'timeScale' : CTRLtimeScale,
57     'rampType' : 'per', # relative percent change
58     'CtrlGens': [
59       "gen 1 : 0.5",
60       "gen 2 1 : 0.5",
61     ],
62     # Data from: 12/11/2019 PACE
63     'forecast' : [
64       #(time , Precent change from previous value)

```

```

65     (0, 0.0),
66     (1, 5.8),
67     (2, 8.8),
68     (3, 9.9),
69     (4, 4.0),
70   ],
71 }, #end of generation controller def
72 'CAISODispatch' : {
73   'Area': 2,
74   'startTime' : 2,
75   'timeScale' : CTRLtimeScale,
76   'rampType' : 'per', # relative percent change
77   'CtrlGens': [
78     "gen 4 : 1.0",
79   ],
80   # Data from: 12/11/2019 PACE
81   'forecast' : [
82     #(time , Precent change from previous value)
83     (0, 0.0),
84     (1, 0.7),
85     (2, 7.5),
86     (3, 11.2),
87     (4, 4.4),
88   ],
89 }, #end of generation controller def
90 }
91
92 mirror.sysLoadControl = {
93   'BPATDemand' : {
94     'Area': 1,
95     'startTime' : 2,
96     'timeScale' : CTRLtimeScale,
97     'rampType' : 'per', # relative percent change
98     # Data from: 12/11/2019 BPAT
99     'demand' : [
100       #(time , Precent change from previous value)
101       (0, 0.000),
102       (1, 3.2),
103       (2, 8.2),
104       (3, 9.3),
105       (4, 3.8),
106     ] ,
107   }, # end of demand agent def
108   'CAISODemand' : {

```

```

109     'Area': 2,
110     'startTime' : 2,
111     'timeScale' : CTRLtimeScale,
112     'rampType' : 'per', # relative percent change
113     # Data from: 12/11/2019 CAISO
114     'demand' : [
115         #(time , Precent change from previous value)
116         (0, 0.000),
117         (1, 3.0),
118         (2, 7.0),
119         (3, 10.5),
120         (4, 4.4),
121     ] ,
122 },# end of demand load control definition
123 }# end of loac control definitions
124
125 # Definite Time Controller Definitions
126 mirror.DTCdict = {
127     'bus8caps' : {
128         'RefAgents' : {
129             'ra1' : 'bus 8 : Vm',
130             'ra2' : 'branch 8 9 1 : Qbr', # branches defined from, to, ckID
131         },# end Reference Agents
132         'TarAgents' : {
133             'tar1' : 'shunt 8 2 : St',
134             'tar2' : 'shunt 8 3 : St',
135             'tar3' : 'shunt 8 4 : St',
136             'tar4' : 'shunt 8 5 : St',
137             'tar5' : 'shunt 8 6 : St',
138         }, # end Target Agents
139         'Timers' : {
140             'set' :{ # set shunts
141                 'logic' : "(ra1 < 1.0)", # or (ra2 < -26)",
142                 'actTime' : 30, # seconds of true logic before act
143                 'act' : "anyOFFTar = 1", # set any target off target = 1
144             },# end set
145             'reset' :{ # reset shunts
146                 'logic' : "(ra1 > 1.04)",# or (ra2 > 26)",
147                 'actTime' : 30, # seconds of true logic before act
148                 'act' : "anyONTar = 0", # set any target On target = 0
149             },# end reset
150             'hold' : 90, # minimum time between actions
151         }, # end timers
152     },# end bus8caps

```

```

153 'bus9caps' : {
154     'RefAgents' : {
155         'ra1' : 'bus 9 : Vm',
156         'ra2' : 'branch 8 9 1 : Qbr', # branches defined from, to, ckID
157     }, # end Reference Agents
158     'TarAgents' : {
159         'tar1' : 'shunt 9 2 : St',
160         'tar2' : 'shunt 9 3 : St',
161         'tar3' : 'shunt 9 4 : St',
162         'tar4' : 'shunt 9 5 : St',
163         'tar5' : 'shunt 9 6 : St',
164     }, # end Target Agents
165     'Timers' : {
166         'set' : { # set shunts
167             'logic' : "(ra1 < 1.0)",
168             'actTime' : 45, # seconds of true logic before act
169             'act' : "anyOFFTar = 1", # set any target off target = 1
170         }, # end set
171         'reset' : { # reset shunts
172             'logic' : "(ra1 > 1.04)",
173             'actTime' : 45, # seconds of true logic before act
174             'act' : "anyONTar = 0", # set any target On target = 0
175         }, # end reset
176         'hold' : 120, # minimum time between actions
177     }, # end timers
178 }, # end bus8caps
179 }# end DTCdict

```

Figure 189: Required .ltd file for forecast demand scenario with noise and deadbands.

11. Large Tables

This appendix is used to present large tables too distracting for inclusion in their respective sections.

Table XVI: Balancing authority dictionary input information.

Key	Type	Units	Example	Description
B	String	MW/0.1Hz	"1.0 : permax"	Describes the frequency bias scaling factor B used in the ACE calculation. Various Options exist.
AGCActionTime	Float	Seconds	5	Time between AGC dispatch messages.
AGCType	String	-	"TLB : 2"	Dictates which AGC routine to use and type specific options.
UseAreaDroop	Boolean	-	FALSE	If True, all governed generators under BA control will use the area droop.
AreaDroop	Float	Hz/MW	0.05	Droop value to use if 'UseAreaDroop' is True.
IncludeIACE	Boolean	-	TRUE	If True, include IACE in ACE calculation
IACEconditional	Boolean	-	FALSE	Adds IACE to ACE if signs of deltaraw and IACE match.
IACEwindow	Integer	Seconds	60	Defines the length of moving integration window to use in IACE. If set to 0, integration takes place for all time.
IACEscale	Float	-	0.0167	Value used to scale IACE.
IACEdeadband	Float	Hz	0.036	Absolute value of system frequency where IACE will not be calculated below.
ACEFiltering	String	-	PI : 0.03 0.001'	String used to dictate which filter agent is created and filter specific parameters.
AGCDeadband	Float	MW	1.5	Value of ACE to ignore sending in AGC dispatch. Not implemented as of this writing.
GovDeadbandType	String	-	'step'	Type of deadband to be applied to area governors.
GovDeadband	Float	Hz	0.036	Absolute value of system frequency that governors will not respond below.
GovAlpha	Float	Hz	0.016	Specific to 'NLdroop' type of deadband. Specifies lower bound of non-linear droop.
GovBeta	Float	Hz	0.036	Specific to 'NLdroop' type of deadband. Specifies upper bound of non-linear droop.
CtrlGens	List of Strings	-	-	List of generators, participation factor, and dispatch signal type.

Table XVII: Simulation parameters dictionary input information.

Key	Type	Units	Example	Description
timeStep	float	Seconds	1	Simulated time between power-flow solutions
endTime	float	Seconds	1800	Number of seconds simulation is to run for.
slackTol	float	MW	0.5	MW Value that slack error must be below for returned solution to be accepted.
PY3msgGroup	integer	-	3	Number of messages to combine into one AMQP message for PY3 to IPY communication.
IPYmsgGroup	integer	-	60	Number of messages to combine into one AMQP message for IPY to PY3 communication.
Hinput	float	MW sec	0	Value to use for total system inertia. Units are MW*sec. If set to 0.0, system inertia will be calculated from the given .sav information.
Dsys	float	PU	0	Value of system damping used in swing equation and governor models. While this option is available, it is untested and typically set to 0.0.
fBase	float	Hz	60	Value of base system frequency.
freqEffects	boolean	-	True	If True, the ω used in the swing equation will be the current system frequency. If this is set to False then ω will be set equal to 1 for the swing equation calculation
integrationMethod	string	-	'rk45'	This option defines how the swing equation is integrated to find current frequency. Valid options are 'rk45', 'ab', and 'euler'. The default is the 'euler' method which is a simple forward Euler integration. The 'ab' option uses a two step Adams-Bashforth method and the 'rk45' option uses the scipy solve_ivp function that utilizes an explicit Runge-Kutta 4(5) method.
fileDirectory	string	-	"\\delme\\\"	This is a relative path location from the folder where PSLTDSim is executed in which the output files are saved to.
fileName	string	-	"SimTest"	This is the name used to save files.
exportFinalMirror	int	-	1	If this value is 1 a final system mirror will be exported. If this value is 0 no final mirror will be exported.
exportMat	int	-	1	If this value is 1 a MATLAB .mat file will be exported. If this value is 0 no MATLAB .mat file will be exported.

12. Detailed Valve Travel Results

This appendix is used to present detailed valve travel plots from various deadband scenarios that were used to populate data presented in Table IX.




Figure 190: Area 1 valve travel using no deadband.




Figure 191: Area 2 valve travel using no deadband.




Figure 192: Area 3 valve travel using no deadband.




Figure 193: Area 1 valve travel using a step deadband.




Figure 194: Area 2 valve travel using a step deadband.




Figure 195: Area 3 valve travel using a step deadband.




Figure 196: Area 1 valve travel using a no-step deadband.




Figure 197: Area 2 valve travel using a no-step deadband.




Figure 198: Area 3 valve travel using a no-step deadband.




Figure 199: Area 1 valve travel using a non-linear droop deadband.




Figure 200: Area 2 valve travel using a non-linear droop deadband.




Figure 201: Area 3 valve travel using a non-linear droop deadband.




Figure 202: Area 1 valve travel in a non-homogeneous deadband system.




Figure 203: Area 2 valve travel in a non-homogeneous deadband system.




Figure 204: Area 3 valve travel in a non-homogeneous deadband system.

13. Additional AGC Results

This appendix is used to present figures from AGC base case, tuning, and deadband noise results involving Area 2, which are largely similar to Area 1 results. Conditional AGC response to an area 2 event is also presented.




Figure 205: Frequency response to generation loss event in area 2.




Figure 206: Area 1 controlled generation response to generation loss event in area 2.




Figure 207: Area 2 controlled generation response to generation loss event in area 2 .




Figure 208: AGC frequency response to area 2 base case scenario.




Figure 209: Calculated BA values during area 2 AGC tuning.




Figure 210: Area 1 controlled generation response during area 2 AGC tuning.




Figure 211: Area 2 controlled generation response during area 2 AGC tuning.




Figure 212: AGC frequency response with noise and deadbands.




Figure 213: Calculated BA values with noise and deadbands.




Figure 214: Area 1 controlled generation response to noise and deadbands.




Figure 215: Area 2 controlled generation response to noise and deadbands.




Figure 216: Frequency response to event using TLB 0.




Figure 217: Calculated BA values during an even using TLB 0.




Figure 218: Area 1 controlled generation response to external area event using TLB 0.




Figure 219: Area 2 controlled generation response to internal area event using TLB 0.




Figure 220: Frequency response to event using TLB 4.




Figure 221: Calculated BA values during an event using TLB 4.




Figure 222: Area 1 controlled generation response to external area event using TLB 4.




Figure 223: Area 2 controlled generation response to internal area event using TLB 4.

14. Additional BAAL Results

System frequency minute averages and BAAL values from long-term area 2 scenarios are presented below.




Figure 224: Morning peak minute average frequency.




Figure 225: Morning peak minute average frequency with deadbands and noise.




Figure 226: BAAL of area 2 during morning peak.




Figure 227: BAAL of area 2 during morning with noise and governor deadbands.




Figure 228: Virtual wind ramp minute average frequency.




Figure 229: Virtual wind ramp minute average frequency with deadbands and noise.




Figure 230: Area 2 virtual wind ramp BAAL under ideal conditions.




Figure 231: Area 2 virtual wind ramp BAAL with noise and governor deadbands.