

SOLAR PANEL INSPECTION REPORT

Batch ID: 7 | Date: 2026-05-18 01:11

Summary Statistics:

- Total Panels Scanned: 15
- Defective Panels Found: 2
- Health Rate: 86.67%

Critical Defects List (Action Required):

Panel ID	Defect Type	Efficiency Loss	Image Source
R02_C03	hotspot_single_cell	6.6438%	a.jpg
R01_C03	hotspot_single_cell	18.9664%	a.jpg