

# Multi-actor network repair problems

Brian French

March 26, 2020

## 1 Status Tracker

- Introduction – drafted
- Literature Review - drafted
- Modeling - drafted+1 set of revisions
- Results/conclusions -drafted
- Resilience – started
- Conclusions – thought about

## 2 Introduction and Motivation

Hurricanes are a growing concern in the operation of power grids in coastal areas. This is due partly to the increasing density of cities in coastal areas, but the impacts of climate change are causing both rising sea levels making flooding worse, but also more frequent and more severe hurricanes [Mann and Emanuel, 2006]. This phenomenon suggests that repair procedures and resilience planning will be of increased importance in the coming years.

This thesis explores the gap in existing literature where previous efforts have not explicitly considered how multiple networks depended on each other, especially the post-disaster infrastructure recovery interactions between power grid and road networks. For example, to repair a damaged power grid element, the element must be accessible to the crew attempting to repair it. Moreover, the crew will take time to go from one element to the next to repair, affecting the power grid's performance during recovery. This implies that the road network (how damaged it is and how its recovery is planned) becomes part of the overall recovery efforts. During a hurricane, the road network will sustain substantial

damage from flooding and debris on the road surface, which necessitates road grid repairs/clearance as well. To handle the issues of repairing power grids efficiently, both types of repairs (road network and power grid) should be considered jointly. Previous literature does not study this specific interaction as discussed in the section below.

Understanding of repair efforts on power grids begins with understanding the basics of power grid topology. We divide the power grid into transmission and distribution networks. Transmission consists of generators, buses/substations, and high voltage connecting lines. Because this side of the grid has multiple sources and sinks, flow is not guaranteed to flow in a certain direction. The distribution side of a network begins at the bus/substation level and connects end users of power to the grid as a whole. Because power flows from the substation to the end user in a single source network, these networks are comparatively simpler to model. For the sake of this thesis, we restrict ourselves to just transmission level power grids as distribution grids are simpler at an electrical level as well as being geographically small enough that ignoring routing time costs doesn't stray from optimality very far. In addition, as distribution level damage happens in routine storms, power utilities have a better understanding of how to handle this damage due to experience. In addition to the practical concerns of how these power grid levels differ, the scale of service loss is dramatically different. Loss of distribution power lines can lead to loss of power service to small segments of a neighborhood while loss of a substation or set of transmission lines can knock out power to several neighborhoods or entire towns.

## 3 Literature Review

### 3.1 Hurricane Damage Modeling

When delving into the background literature, no discussion of modeling repair after a hurricane can happen before looking at the literature on damage to power grids from hurricanes. [Guikema et al., 2010] use a model based on negative binomial regression to estimate the number of downed power lines in combination with a classification tree handling flooding and wind speed over/under 100 miles per hour. [Scherb et al., 2015] on the other hand takes an approach more rooted in scenario generation and tries to use the peak windspeed and proximity to the eye wall of a hurricane to construct a loss function for power lines. Both of these papers come to the similar conclusion that damage to 40-70% of power

lines due to wind and thrown debris is common in hurricanes. Damage is geographically distributed based on proximity to the eye-wall of a hurricane, but because hurricanes are frequently hundreds of miles across, damage inside of a single city may appear functionally random.

[Winkler et al., 2010] Provides the most thorough analysis of these 3 papers using real world topographies from various small regions of Texas and coming up with loss functions for both lines and substations. Worth noting in all three of these examples is that lines and substations sustain the most damage, but generators themselves are robust enough that a hurricane is unlikely to damage them. This means they can be ignored in the repair modeling later on. This validated the later modeling of how damage happens to a power grid in the wake of a hurricane that neglects to consider the impact on power generation.

### 3.2 Existing Power Grid Repair Modeling

Power grid repairs in the wake of hurricanes are not an unstudied area of research. [Ang, 2006] solves a scheduling problem of power grid repair in the wake of both hurricanes and terrorist attacks. While they don't consider impacts of roads, they do significant work with how to model a damaged power grid. Along similar lines, [Arab et al., 2015] solve a similar problem under uncertainty by treating the state of each power line and generator as a random Bernoulli variable and solving the ensuing stochastic optimization problem. Though it solves the problem as a two stage stochastic program with recourse, .

[Ouyang and Duenas-Osorio, 2014] Does a statistical analysis of the rate at which damage is recovered in the context of broader power grid resilience. While more descriptive than prescriptive, they do lay out that transmission grid repairs take priority alongside "critical facilities vital to public safety, health, and welfare". Of note in this paper is that they identify that much of the existing literature on repairs to power grid is based on descriptive studies of statistical repair times rather than model-driven optimization models for how to improve that process.

[Golari et al., 2014] Takes a different approach to ensuring power demand satisfaction in the context of a damaged power network by approaching the problem in the lens of construction of sub-grids (termed "islands" in much of the electrical engineering literature) in order to keep demand satisfied in a post-disaster context. Islanding is an active field of study in power grid engineering for generating tools to minimize the impact of disaster damage.

[Panteli et al., 2016] studies disaster damage by constructing islanding plans in a way that would minimize load loss subject to severe weather. Though there is no consideration of repair, their modeling warrants the importance of resilience as an area of study.

### 3.3 Existing Road Grid Repair Modeling

[Pregolato et al., 2017] provides an overview of probability of road damage by location and intensity. They go on to provide a literature review and meta-analysis of existing papers in the subfield. They then go on to summarize a variety of versions of depth-disruption functions for roads based on local rain intensity. Alone this paper doesn't add significant amounts to modeling repair efforts, but it does provide insights into how flooding is addressed at the analysis level.

Looking next at how previous papers have addressed modeling flooding and how to interact with it in a repair context, we start with [Duque et al., 2016]. This paper focuses on distribution of relief supplies, but in the context of the problem of supply distribution they consider repair of flooded or damaged roads. Though solve the problem with dynamic programming, it is from this paper where we take the idea of repair of roads by traversing them at additional cost.

Also of note from the perspective of road repair is [Aksu and Ozdamar, 2014]. Again not a paper focused on direct repair of networks for its own sake, but rather a paper focused on evacuation and accessibility to areas flooded by the a disaster. This provides additional insight and a different treatment of the problem using mixed integer programming rather than the dynamic programming of Duque et al. From this, we draw inspiration for treatment of the road grid in the context of a mixed-integer program.

All three of these papers make similar assumptions to what we make later in that minor damage can be repaired in a time horizon relevant to immediate post-disaster response and not the longer months-long repair process following the disaster.

### 3.4 Resilience

As this thesis deals partly with resilience, we look to resilience literature for how to define resilience in the context of disaster response for power grids. We first look to [Molyneaux et al., 2016] as a multi-disciplinary literature review of power grid resilience. They broadly define resilience as "capacity to cope with

the unexpected”. While they go through multiple measures for resilience they use primarily metrics of price. We then look to [Panteli and Mancarella, 2017] for more specific resilience definitions in the context of disaster response. They focus on both magnitude of drop in service as well as time dependent total loss of power demand satisfied.

Much of the literature on resilience for power grids comes from study of protection from directed attack. Relevant among these is [Deka et al., 2018] which provides a study of not just initial damage but potential damage stemming from cascades and identification of elements crucial to construction of resilient power networks. More relevant to this thesis is [Salmeron et al., 2004] for their work identifying key resilience elements in the context of mixed integer programming using a DC-powerflow based model of power networks. Their approach to identification of key elements is used in the section on applying repair models to resilience in order to identify elements to harden for the sake of generating faster repairs.

## 4 Repair Problem

### 4.1 Overview

To motivate the problem, we see from the literature a gap in looking at power grid repairs in a post-disaster context with consideration of the roads. The Federal Emergency Management Agency’s 2017 post season after action report [FEMA, 2018] and Hurricane Sandy after action report [FEMA, 2013] make note of the need of increased coordination between agencies for the sake of logistics as well as it having been a major short coming in the repair effort.

We know from the earlier referenced literature that road repair is a concern in the wake of a hurricane. We assume for the sake of this thesis that all roads can be cleared. Clearing here represents digging out drainage for minor flooding and clearing debris. Severely damaged roads should be treated as completely impassible and dropped from the graph representation of the network.

We assume also that the resulting road network for the area corresponding to the power network’s service area can be represented with a Watts-Strogatz network, which is a network that connects each node of a graph to the  $k$  nearest neighbors and then has probability  $p$  of connecting any two nodes chosen. These networks exhibit ”small world” property where any two arbitrarily distant nodes can be connected using only a small number of edges. Based on the lit-

erature on statistical analyses of road network topologies [Lämmer et al., 2006] [Chan et al., 2011] this is a serviceable but imperfect assumption. Ideally the real topology of a hurricane struck area should be used, but for a computational and modeling effort to draw insight into joint repair efforts, the contrived Watts-Strogatz based network suffices. We then apply damage to this network to allow for the solution of interacted road and power repair problems to better study the impact of considering these two aspects together.

We model time in discrete shifts here because it allows for mixed-integer programming to be used as a tool to solve both problems. It additionally allows for easier interaction of both sides (Road and Power) of the problem by operating them on the same time chunks.

We also assume that direct current (DC) approximations of power flow can be used to approximate the full alternating current (AC) power flow of a real power grid. We know that representation of DC power flow is more accurate than just a "pipe-flow" representation of a power grid as it captures some of the physics behind electrical flows. DC representation is usually within 5-10% of the AC power flow solutions [Frank and Rebennack, 2016] [Stott et al., 2009] meaning that it suffices for the sake of the power repair problem. As the problem we're considering is one of logistics and not one of power flow management, an approximation in the power flow relaxes numerical accuracy of the power flow but leaves a near optimal schedule that still minimizes load shed over the repair horizon. Because demand at each node/bus is based on pre-hurricane power demand, a somewhat coarse approximation is accurate enough.

With the power grid, we elect to ignore distribution below the substation level. Each substation has a distribution level network that services the local area (e.g plugging the grid into a house), but the wires between substations are considered the transmission level network. Discarding the distribution network in the modeling of repair scheduling stems from two factors. First that it's geographically very co-located damage so that including road networks would provide little benefit, and secondly, flow at the distribution level goes from the substation as a source to the demand sites as a sink. This necessitates different modeling than the transmission grid.

#### **4.1.1 Validating use of DC power flow**

From a review of the literature of earlier power network related operations research problems, many of them relax one step further than DC powerflow all the




Figure 1: Comparison of DC and traditional (pipeflow) network flow

way to traditional network flow that resembles any abstract network. For these problems, DC powerflow models are likely considered to be overkill upon first glance and therefore begs the question of why use it over a traditional network flow model. We define traditional network flow to consist of just flow balance and line limits (analogous to relaxation of constraint (2) in the DCOPF model). To begin with, DC power flow tends to spread power flow out more across lines due to the physics of the grid while a network flow model tends to seek an extreme point solution which leads to fewer lines under use, but heavier loading on those lines. To demonstrate this, we solve DCOPF and it's corresponding relaxation of constraint (2). The results shown below aren't quite as drastic as initially expected, but there is a noticeable difference between flow patterns, and when looking at multiple cases of damage to the power grid, it may become relevant, and as a result is worth including into models.

Further, as we extend this model into resilience, use of pipeflow style network models to handle power flow may over-prioritize the resilience of certain lines as a false conclusion. Since DC powerflow is of low computational cost and low model complexity to add and has upside in some limited cases, we find its inclusion to be warranted.

#### 4.1.2 DCOPF

To begin looking at methods of studying repair of damaged power grids, we first must understand the Direct Current-Optimal Power Flow (DC-OPF) model as

it forms the basis of all more complex power models used in this thesis. The power grid can be represented as a mathematical graph with edges representing power lines and the nodes of the graph corresponding to substations that service a distribution area

We use the following notation for clarity in models

- $o(e)$  is the node at the origin of line  $e$
- $d(e)$  is the node at the destination of line  $e$
- $O(i)$  is the set of lines with origin  $i$
- $D(i)$  is the set of lines with destination  $i$

We define the following parameters and sets

- $i \in N$  is the set and indexer for nodes
- $e \in E$  is the set and indexer for edges
- $C_i$  is the cost of producing one unit of power at node  $i$
- $P_i$  is the maximum power generation for node  $i$ . If there is no generator, maximum production is zero watts.
- $D_i$  is the demand for power at node  $i$
- $B_e$  is the line susceptance for power line  $e$  (susceptance is the measure of ease of power flowing along a line)
- $\underline{L}_e$  is the maximum amount of flow on line  $e$

We also have the following decision variables

- $X_e$  is the power flow on line  $e$  (flow is based on lower indexed node to higher indexed node, so negative flow is allowed and represents flow from the higher indexed node to the lower indexed node)
- $G_i$  is the power generated at node  $i$
- $\theta_i$  is the phase angle for power flow at node  $i$

The model can then be formulated as

$$\text{Minimize } \sum_{i \in N} C_i G_i \tag{1}$$



subject to

$$X_e = B_e(\theta_{o(e)} - \theta_{d(e)}), \quad \forall e \in E \quad (2)$$

$$G_i - \sum_{e \in O(i)} X_e + \sum_{e \in D(i)} X_e = D_i, \quad \forall i \in N \quad (3)$$

$$G_i \leq P_i \quad \forall i \in N \quad (4)$$

$$-\underline{L}_e \leq X_e \leq \underline{L}_e \quad (5)$$

To explain, the problem is how to generate power at the minimum cost in a way that satisfies all of the demand subject to the physics of how power grids operate. As a byproduct, this problem also solves out line flow amounts and phase angles for each node. Constraint 2) is part of the DC approximation to AC power flow where we assume  $\sin(x) = x$  for small values of  $x$  and reduce power flow to just its real component and the aforementioned linear approximation of phase angle. Constraint 3) is a standard flow balance constraint. Constraint 4) restricts generation to the maximum for the generator. Constraint 5) is a flow capacity constraint on each power line. While overall a simple problem, DCOPF serves as the building block for most of the power grid models used for the rest of this thesis as well as being used in practice for controlling power grid generation and dispatch. [Li and Bo, 2007].

## 4.2 Road Repair Problem

When dealing with repairs on the power grid, we need a framework for solving problems based on the damage to the road network. We elect to solve this a problem as a scheduling/routing problem for a crew tasked with clearing debris and/or digging out minor flooding. This takes the form of constructing a series of roads to traverse as tour that begins and ends at a depot.

We model this as per the following:

Parameters and Sets:

- $T$  the set of time periods (shifts) over the time horizon, indexed by  $t$
- $N$  the set of nodes in the graph, representing the intersections of road segments
- $c_{ij}^t$  measure of the value of the road segment from node  $i$  to node  $j$  during period  $t$
- $l_{ij}$  is the transit time of the road segment between nodes  $i$  and  $j$  under nominal conditions
- $r_{ij}$  time to repair the road segment between nodes  $i$  and  $j$  (hours), including travel time
- $s^t$  the length of period  $t$  in time units (hours)
- $o_{ij}$  initial condition of the road segment between nodes  $i$  and  $j$

and Decision Variables

$X_{ij}^t$  binary variable for road segment  $ij$  being operational in time  $t$   
 $K_{ij}^t$  binary variable for travel from  $i$  to  $j$  being in the tour at time  $t$   
 $S_{ij}^t$  length of travel for road segment  $ij$  at time  $t$

$$\min \sum_{t \in T} \sum_{i,j \in N} c_{ij}(1 - X_{ij}^t) \quad (6)$$

subject to:

$$\sum_{i,j \in N} S_{ij}^t K_{ij}^t \leq s^t, \quad \forall t \in T \quad (7)$$

$$S_{ij}^t = \max\{l_{ij}, r_{ij}(1 - X_{ij}^t)\}, \quad \forall t \in T, \quad \forall i, j \in N \quad (8)$$

$$\sum_{j \in N} K_{ij}^t - \sum_{j \in N} K_{ji}^t = 0, \quad \forall t \in T, \quad \forall i \in N \quad (9)$$

$$X_{ij}^t \leq \sum_{t'=0}^{t-1} K_{ij}^{t'} + o_{ij}, \quad \forall t \in T, \quad \forall i, j \in N \quad (10)$$

$$\sum_{i,j \in S; i \neq j} X_{ij}^t \leq |S| - 1, \quad \forall S \subset N, \quad S \neq \emptyset, \quad \forall t \in T. \quad (11)$$

Of note is that constraint 7) is nonlinear as intuitively expressed. We linearize it by rewriting constraints 7) and 8) as the following:

$$\sum_{i,j \in N} S_{ij}^t \leq s^t, \quad \forall t \in T \quad (12)$$

$$S_{ij}^t \leq M * K_{ij}^t \quad \forall t \in T, \quad \forall i, j \in N \quad (13)$$

$$S_{ij}^t \geq l_{ij} K_{ij}^t \quad \forall t \in T, \quad \forall i, j \in N \quad (14)$$

$$S_{ij}^t \geq (1 - X_{ij}^t)r_{ij} - (1 - K_{ij}^t)M \quad \forall t \in T, \quad \forall i, j \in N \quad (15)$$

To explain the modeling, the objective is to minimize the value of out-of-service road. Without loss of generality, this can be substituted with a set of priority weights from another agency that cares about the road network's operation. For example, the value of given road segments to an agency like the Red Cross or FEMA that is tasked with bringing relief supplies in to a disaster-stricken area

Constraint 7) provides a scheduling constraint limiting the tour's length to

the length of the shift. Constraint 8) is a nonlinear but linearizable constraint that sets the length of a road to either its nominal operation time or its repair time depending on whether or not it is marked as working (e.g  $X_{ij}^t = 1$ ). Constraint 9) is a standard path connectivity constraint. Constraint 10) restricts each road segment to only be working if it started working or has been repaired, and Constraint 11) is a standard set of subtour elimination constraints.

### 4.3 Power Grid Repair Problem

When looking at repair of the power grid, we formulate a discrete time mixed integer program that captures both the planning/scheduling/movement of repair crews as well as the DC power flow model. We assume the following:

- Repair of a power line can be started from either end of that power line.
- Minimum spanning tree's lower bound provides a usable approximation for the sake of keeping model runtime down
- Load shedding can be modeled as a continuous loss even though on real power grids it's a series of discrete decisions that allows small increments of load shed, though not truly continuous power shedding.

We pose the model as follows:

$N$	set of nodes, indexed by $i$
$E$	set of power lines, indexed by $e$
$R$	the set of road segments
$T$	the planning horizon, indexed by $t$
$O(i)$	set of lines with origin $i$
$D(i)$	set of lines with destination $i$
$o(e)$	origin node of line $e$
$d(e)$	destination node of line $e$
$\underline{L}_e, \overline{L}_e$	power lower and upper bounds for line $e$
$\Delta_i$	time to repair node $i$
$\delta_e$	time to repair line $e$
$C_{SP(i)}$	length of the shortest path from depot to node $i$
$D_i$	power demand at node $i$ in the pre-disaster state
$P_k$	maximum power generation for generator $k$
$B_e$	line susceptance for power line $e$
$I_e, I_i$	initial condition of line $e$ and node $i$ , respectively
$X_e^t$	power flow on line $e$ at time $t$
$G_k^t$	production from generator $k$ at time $t$
$Y_n^t$	Load shed from bus $n$ at time $t$
$V_i^t$	indicator for node $i$ functioning at time $t$
$W_e^t$	indicator for line $e$ functioning at time $t$
$S_e^t$	indicator for line $e$ serviced at time $t$
$F_i^t$	indicator for node $i$ serviced at time $t$
$\theta_i^t$	phase angle for the power flow at $i$ in time $t$
$MST_t$	length of the tree used for “routing” at $t$
$Z_{ij}^t$	indicator for $ij$ being in the spanning tree at $t$

$$\min \sum_{i \in N} \sum_{t \in T} (1 - V_i^t) D_i \quad (16)$$

subject to:

$$X_e^t = B_e(\theta_{o(e)}^t - \theta_{d(e)}^t), \quad \forall t \in T, \quad \forall e \in E \quad (17)$$

$$G_i^t - \sum_{e \in O(i)} X_e^t + \sum_{e \in D(i)} X_e^t = D_i - Y_i^t, \quad \forall t \in T, \quad \forall i \in N \quad (18)$$

$$G_k^t \leq P_k V_k^t, \quad \forall t \in T, \quad \forall k \in N \quad (19)$$

$$0 \leq S_i^t \leq D_i \quad \forall t \in T, \quad \forall i \in N \quad (20)$$

$$D_i(1 - V_i^t) \leq S_i^t \quad \forall t \in T, \quad \forall i \in N \quad (21)$$

$$\underline{L}_e W_e^t \leq X_e^t \leq \overline{L}_e W_e^t, \quad \forall t \in T, \quad \forall e \in E \quad (22)$$

$$\underline{L}_e V_{o(e)}^t \leq X_e^t \leq \overline{L}_e V_{o(e)}^t, \quad \forall t \in T, \quad \forall e \in E \quad (23)$$

$$\underline{L}_e V_{d(e)}^t \leq X_e^t \leq \overline{L}_e V_{d(e)}^t, \quad \forall t \in T, \quad \forall e \in E \quad (24)$$

$$MST^t = \sum_{i \in N} \sum_{j \in N} SP_{ij}^t Z_{ij}^t, \quad \forall t \in T \quad (25)$$

$$\sum_{i \in N} \sum_{j \in N} Z_{ij}^t = \sum_{i \in N} F_i^t + \sum_{e \in E} S_e^t - \sum_{i \in N} F_i^t \sum_{e \in O(i)} S_e^t - \sum_{i \in N} F_i^t \sum_{e \in D(i)} S_e^t, \quad \forall t \in T \quad (26)$$

$$\sum_{i,j \in S} Z_{ij}^t \leq |S| - 1, \quad S \subset N, \quad S \neq \emptyset, \quad \forall t \in T \quad (27)$$

$$\sum_{j \in N} Z_{ij}^t \leq F_i^t + \sum_{e \in O(i) \cup D(i)} S_e^t, \quad \forall t \in T, \quad \forall i \in N \quad (28)$$

$$\sum_{e \in E} \delta_e S_e^t + \sum_{i \in N} \Delta_i F_i^t + MST_t \leq s^t, \quad \forall t \in T \quad (29)$$

$$V_i^t \leq \sum_{t'=0}^{t-1} F_i^{t'} + I_i, \quad \forall i \in N \quad (30)$$

$$W_e^t \leq \sum_{t'=0}^{t-1} S_e^{t'} + I_e, \quad \forall e \in E \quad (31)$$

Constraint 13) is the same constraint from the DCOPF model above to handle line susceptance and phase angle related power flow. Constraint 14) is the flow balance constraint from DCOPF with the alteration that demand can be switched on and off at penalty to the objective. Constraint 15) is a generation capacity constraint where generation of power can only flow into the grid if the bus that the generator connects to is intact. Constraints 16-17) handle load shedding from each bus. Constraints 18-20) are flow limit constraints subject to functioning of the line and buses on both sides of the corresponding line.

Constraint 21) defines the length of a minimum spanning tree based on what elements are put in. Constraint 22) is a quadratic constraint that counts how

many elements need to be inserted into the minimum spanning tree. As we're modeling that a line can be repaired from either endpoint, we need to account for the cases where a bus and it's attached node are repaired in the same shift. Constraint 23) is a standard subtree elimination constraint. Constraint 24) restricts the inclusion of elements in the tree to only nodes that have a repair at them. Constraint 25) is a scheduling constraint that matches the one seen in the road repair model, and constraints 26-27) are functionality constraints that restrict operation to things that either started working or have been repaired.

Tying the model in to the operation of power grids, we model loss shedding as a continuous loss to capture the ability of a power utility to disconnect portions of the distribution network in order to reduce the demand on the grid to what can be serviced. In practice, it would be a set of discrete decisions about which parts to disconnect, but relaxing to a single continuous variable captures most of that decision making while not complicating the model to an unreasonable degree.

#### 4.4 Justifying the use of a Minimum spanning tree approximation

The minimum spanning tree usage in the above model we discuss the use of the tree to approximate the route of a repair crew to reduce computational time. We demonstrate this by first formulating the routing version of the problem, then running a pair of scenarios to find first if we get the same (or at least a very similar) answer, and secondly to show the difference in runtime.

We begin by defining our sets and variables as above with the addition of  $K_{ij}^t$  to represent the inclusion of path from  $i$  to  $j$  in the tour at time  $t$ . The routing model is then as follows:

$$\min \sum_{i \in N} \sum_{t \in T} (1 - V_i^t) D_i \quad (32)$$

subject to:

$$X_e^t = B_e(\theta_{o(e)}^t - \theta_{d(e)}^t), \quad \forall t \in T, \quad \forall e \in E \quad (33)$$

$$G_i^t - \sum_{e \in O(i)} X_e^t + \sum_{e \in D(i)} X_e^t = D_i - S_i^t, \quad \forall t \in T, \quad \forall i \in N \quad (34)$$

$$G_k^t \leq P_k V_k^t, \quad \forall t \in T, \quad \forall k \in N \quad (35)$$

$$0 \leq S_i^t \leq D_i \quad \forall t \in T, \quad \forall i \in N \quad (36)$$

$$D_i(1 - V_i^t) \leq S_i^t \quad \forall t \in T, \quad \forall i \in N \quad (37)$$

$$\underline{L}_e W_e^t \leq X_e^t \leq \overline{L}_e W_e^t, \quad \forall t \in T, \quad \forall e \in E \quad (38)$$

$$\underline{L}_e V_{o(e)}^t \leq X_e^t \leq \overline{L}_e V_{o(e)}^t, \quad \forall t \in T, \quad \forall e \in E \quad (39)$$

$$\underline{L}_e V_{d(e)}^t \leq X_e^t \leq \overline{L}_e V_{d(e)}^t, \quad \forall t \in T, \quad \forall e \in E \quad (40)$$

$$Route^t = \sum_{i \in N} \sum_{j \in N} SP_{ij}^t K_{ij}^t, \quad \forall t \in T \quad (41)$$

$$\sum_{j \in N} K_{ij}^t \geq F_i^t \quad \forall i \in N \quad \forall t \in T \quad (42)$$

$$\sum_{j \in N} K_{o(e)j}^t + \sum_{j \in N} K_{d(e)j}^t > S_e^t \quad \forall e \in E \quad \forall t \in T \quad (43)$$

$$\sum_{j \in N} K_{ij}^t - \sum_{j \in N} K_{ji}^t = 0 \quad \forall i \in N \quad \forall t \in T \quad (44)$$

$$\sum_{i,j \in S} K_{ij}^t \leq |S| - 1 \quad \forall S \subset N \quad \forall t \in T \quad (45)$$

$$\sum_{j \in N} Z_{ij}^t \leq F_i^t + \sum_{e \in O(i) \cup D(i)} S_e^t, \quad \forall t \in T, \quad \forall i \in N \quad (46)$$

$$\sum_{e \in E} \delta_e S_e^t + \sum_{i \in N} \Delta_i F_i^t + Route^t \leq s^t, \quad \forall t \in T \quad (47)$$

$$V_i^t \leq \sum_{t'=0}^{t-1} F_i^{t'} + I_i, \quad \forall i \in N \quad (48)$$

$$W_e^t \leq \sum_{t'=0}^{t-1} S_e^{t'} + I_e, \quad \forall e \in E \quad (49)$$

We then solve a pair of scenarios that will be discussed more fully later in the thesis to check the validity of the minimum spanning tree assumption. Shown in the table below (Table 1) is objective values and processing times. **Should I put the full schedules in for comparison, or just the summary for justification**

From this, we can see that the minimum spanning tree version of the model runs significantly faster and comes to a similar objective. The difference is from

	MST	Routing
Scenario 1 Objective	345.2	369.6
Scenario 1 Runtime	25 seconds	639 seconds
Scenario 2 Objectives	357.5	406
Scenario 2 Runtimes	15 seconds	488 seconds
Scenario 3 Runtimes (57 bus)	4328 seconds	5400* seconds
Scenario 3 Objectives	2748	No solution due to time limit (22% gap at 90 minutes)

Table 1: Runtime and Objective values for MST and Routing versions of the power repair problem

one or two elements being scheduled for an earlier shift.

#### 4.5 Lower Bounding and Post Processing Heuristic

From the above models, we also recognize that we can generate a lower bound using these models. By setting all road lengths to zero, we can then generate a schedule for repairs that would satisfy flow constraints and minimize shed demand. This can be post processed into a feasible schedule by starting with the lower bound schedule and then repacking it into shifts using the following algorithm:

1. Begin by assigning shift 1 as the current working shift
2. Move any repair that hasn't been done that is on the feasible list onto the priority list
3. Assign any repair from the lower bound's working shift that would occur in the current working shift to the feasible list.
4. starting from the depot as the current node, calculate the time to reach and repair every element on the priority list from the current node.
5. if there are unassigned nodes on the priority list that will fit into the current shift, assign the lowest cost node that will. Update the current node to be that node. Go back to step 4
6. if there are unassigned edges on the priority list that will fit into the current, assign the lowest cost edge, update the current node, then go back to step 4.



7. if there are unassigned nodes on the feasible list that will fit into the current, assign the lowest cost node, update the current node, then go back to step 4.
8. if there are unassigned edges on the feasible list that will fit into the current, assign the lowest cost edge, update the current node, then go back to step 4.
9. If nothing else will fit into the current shift, increment to the next shift and start from step 2.
10. Once every repair has been assigned to a shift, end the algorithm.

This is very similar to most greedy heuristics for knapsack problems just with a linked series of knapsacks. This heuristic runs in polynomial time (for the heuristic itself, the simplified mixed integer program is non-polynomial though fast), and as we show later, it's close to our full solutions in a variety of examples

## 4.6 Framework for interacting

Now that we've established both models to be used to draw insights from this problem, we now outline how we're going to interact them. Since the models are solved independently, we have to choose one of them to be the first mover and one to be the second mover. We therefore lay out the following frameworks:

- **Road First**– To model the problem as if the road grid's actor had priority in the repair effort. This is done by solving the road model, then feeding the solutions into the power model as a time-varying shortest path.
- **Power First** – To model the problem with the power grid as the first mover, we solve the power grid repair problem with the roads at their nominal length and presume that due to coordination effects the power grid actor the road grid repairs will happen before the road is needed to affect power repairs. To account for this delay while waiting for road repair, we introduce a one shift delay before the start of power repairs.
- **Uncoordinated Repairs** – To handle the case where the power agency may have to commence repairs with no prior information about the state of the roads. We model the roads as if they are damaged and their state does not change.

- **Heuristic** – Using the heuristic described above, both road first and power first versions of the problem can be solved to approximation quickly.

## 5 Results on Standard test systems

### 5.1 Introduction to Results

To validate the model outlined as more than just a theoretical exercise in modeling, we engineer test cases based on standard IEEE power grids. We choose to use the 30 bus and 57 bus systems \$CITATION GOES HERE in order to capture things on a large enough scale to demonstrate applications for extension into practical uses later on. To convert these from standard test grids to DC versions for use in this model, reactive/imaginary power flow is dropped leaving only real power flow. We then overlay a Watts-Strogatz graph with connection to the 3 nearest neighbor nodes and .03 global connectivity (i.e each node has a 3% chance of being connected to any other node) as mentioned earlier based on fitting power buses to a grid. The key reason for this is to maintain triangle inequalities where having a network that violates triangle inequalities is both unrealistic to "real world" situation as well as altering the solutions of routing problems [Fleming et al., 2013]. We plan this so that travel time between opposite sides of the network are about 3 hours so that routing times are not trivial compared to repair times. We arbitrarily define repair times to be 5 hours for damaged nodes representing replacement of easy to fix components like breakers and downed lines inside the substation. More severe damage resulting from flooding and/or corrosion can take months to repair \$CITATION and is therefore outside the scope of immediate post-disaster response. We assume lines have a repair time of 1 hour plus a variable amount based on the geographical distance of the line. We acknowledge these times are somewhat arbitrary, but without loss of generality, data from a power utility can be fed in, so these arbitrary repair times suffice to warrant the utility of the underlying model.

To show validity, we first solve out a base damage scenario for both grid topologies, then conduct perturbations of respectively weather damage, road topology, and damage intensity to show that the model is valid for a large variety of inputs.

### 5.1.1 Base Case

Looking at our first case to validate the model, we apply geographically clustered damage to both road and power network. By this, the damage is concentrated where several damaged elements are next to each other in varying locations around the power grid.

For the base case on the 30 bus network, damage is applied to approximately one third of road segments, one sixth of power buses, and one quarter of power lines. The following repair curves are generated from the model as stated earlier.




Figure 2: Load Shed by shift in the 30 bus base scenario

We conclude from this that changes in processing and interaction between models has meaningful impact on outcomes. For this case, we find that solving the roads and then conditioning the power repairs on that road schedule yields the outcome closest to the lower bound. This is predicated on the assumption that the road repair crews would need one full shift to get ahead of what roads are needed. If that delay can be reduced, letting the power utility dictate the road repair schedule may become the best schedule.

### 5.1.2 Varied Damage location

Looking at our next case to validate the mode, we apply randomly distributed damage to both road and power network of similar intensity to the base case.




Figure 3: Load Shed by shift in the 30 bus randomized damage scenario

We can draw comparable conclusions to the the geographically distributed base case, but for this scenario, the post-processing heuristic suggests a lower total load shed. This seems to be due to the

### 5.1.3 Varied Roads

We now perturb the road topology of the network case and solve a slight variation of the base case on the new topology. The base-case road network was constructed with a Watts-Strogatz graph with neighbor connectivity 3 and global connectivity .03 as discussed earlier. To show the model as written is valid for all topologies, we permute the road network while keeping the power grid static. The replacement topology is another Watts-Strogatz graph with neighbor connectivity 2 and global connectivity .015 and distances between nodes increased by 25%. This simulates the effect of the power grid in a more rural area or more distributed population clusters in a hurricane effected area.

The solutions are as follows for first the unperturbed road network and then the perturbed road network.




Figure 4: Load Shed by shift and method in the 30 bus scenario before road perturbation




Figure 5: Load Shed by shift and method in the 30 bus scenario after road perturbation

#### 5.1.4 Varied Damage Intensity

We now perturb the base case for both lower and higher damage scenarios in order to show model effectiveness for varying levels of damage.




Figure 6: Load Shed by shift in the 30 bus scenario with increased damage

We get largely intuitive changes here. Interaction frameworks that are on-face more sensitive to road changes have larger magnitudes of change in performance under perturbation of the road network. When the road network is expanded, the framework where road repair is ignored and the roads are treated as statically damaged performs worse by comparison to other frameworks.

Of note here is that the heuristically solved version of the model without travel time and use of a post-processor performs much better (i.e closer to the lower bound) in the case with the road network perturbed to be more distant. This is likely to be because the heuristic ignores road repair entirely in the name of not having to solve a mixed integer programming model.

## 6 Resilience

### 6.1 Introduction

Given that we've constructed a model for response to a scenario of a hurricane strike on a grid, we can use this to look at how different methods of resilience.

By generating test cases and then making the grid resilient through either traditional hardening or by forming microgrids as has become popular in electrical engineering literature.

## 6.2 Hardening

Hardening is one of the approaches to resilience by fortifying a subset of nodes and edges in a network to make it harder to damage. Traditionally this is looked at in the context of interdiction problems [Church and Scaparra, 2007]. To overview the problem solved in hardening: player 1 operates a network, player 2 attacks the network with the objective of minimizing maximum flow, player 1 hardens the network before the attack under the assumption that it's coming. This serves as a max/min/max tri-layer optimization problem.

A similar approach can be taken with disaster planning. Unlike in multi-actor interdiction, the attack coming from a hurricane is a random process of nature and not a targeted interdiction by an intelligent actor. When solving this problem, finding a fixed quantity of damage equal to the ability to fortify under budget constraints that minimizes maximum flow allows for planning of network hardening. Solving this to optimality with best practices requires a delve into bi-level optimization that is outside the scope of this thesis. **Should I write out the full optimization problem as it's MIP formatting, or would a summary be good enough?** We therefor solve the problem heuristically through the following setup.

1. Solve baseline DC-OPF for the grid
2. identify how many nodes ( $n$ ) and edges ( $e$ ) to be fortified
3. select at least the  $2n$  highest demand nodes and the  $2e$  highest utilization edges
4. for each subset of nodes/edges of the correct size, solve DC-OPF with those elements damaged
5. find the minimum demand satisfied and use those damaged elements as the fortified elements when analyzing resilience

This is heuristic rather than, but in the limit where all possible subsets are considered, this is a full solution of the bilayer optimization problem.

### 6.3 Results

We elect to use the 30 bus network to demonstrate the effectiveness of targeted fortification vs untargeted resilience. We construct a basket of scenarios randomly where each scenario reflects 50% line loss and 25% bus loss in the power grid and a standardized road damage of 50%. Each scenario is then solved thrice. Once with a set of resilient elements as chosen above with the interdiction problem solved, once with fortification chosen based on highest demand buses and highest use edges as a plausible approximation that a power utility would use, and then again without any hardening to provide a base case for comparison.

## 7 Conclusions

### 7.1 Results

### 7.2 Future Research Direction

## 8 Bibliography

### References

- [Aksu and Ozdamar, 2014] Aksu, D. and Ozdamar, L. (2014). A mathematical model for post-disaster road restoration: Enabling accessibility and evacuation. *Transportation Research Part E*, 61:56–67.
- [Ang, 2006] Ang, C. C. (2006). Optimized recovery of damaged electrical power grids. Master’s thesis, Naval Postgraduate School. Found online.
- [Arab et al., 2015] Arab, A., Khodaei, A., Khator, S., Ding, K., Emesih, V., and Han, Z. (2015). Stochastic pre-hurricane restoration planning for electric power systems infrastructure. *IEEE Transactions on Smart Grid*, 6:1046–1054.
- [Chan et al., 2011] Chan, S., Donner, R., and Lammer, S. (2011). Urban road networks – spatial networks with universal geometric features. *European Physics Journal B*, 84:563–577.



- [Church and Scaparra, 2007] Church, R. L. and Scaparra, M. P. (2007). Protecting critical assets: The r-interdiction median problem with fortification. *Geographical Analysis*, 39(2):129–146.
- [Deka et al., 2018] Deka, D., Vishwanath, S., and Baldick, R. (2018). Topological vulnerability of power grids to disasters: Bounds, adversarial attacks and reinforcement. *PLOS ONE*, 13(10):1–18.
- [Duque et al., 2016] Duque, P., Dolinskaya, I., and Sorensen, K. (2016). Network repair crew scheduling and routing for emergency relief distribution problem. *European Journal of Operational Research*, 248:272–285.
- [FEMA, 2013] FEMA (2013). Hurricane sandy after-action report. Technical report.
- [FEMA, 2018] FEMA (2018). 2017 hurricane season after-action report. Technical report.
- [Fleming et al., 2013] Fleming, C. L., Griffis, S. E., and Bell, J. E. (2013). The effects of triangle inequality on the vehicle routing problem. *European Journal of Operational Research*, 224(1):1 – 7.
- [Frank and Rebennack, 2016] Frank, S. and Rebennack, S. (2016). An introduction to optimal power flow: Theory, formulation, and examples. *IEEE Transactions*, 48(12):1172–1197.
- [Golari et al., 2014] Golari, M., Fan, N., and Wang, J. (2014). Two-stage stochastic optimal islanding operations under severe multiple contingencies in power grids. *Electric Power Systems Research*, 114:68–77.
- [Guikema et al., 2010] Guikema, S., Quiring, S., and Han, S.-R. (2010). Prestorm estimation of hurricane damage to electric power distribution systems. *Risk Analysis*, 30:1744–1752.
- [Li and Bo, 2007] Li, F. and Bo, R. (2007). Dcopf-based lmp simulation: Algorithm, comparison with acopf, and sensitivity. *IEEE Transactions on Power Systems*, 22(4):1475–1485.
- [Lämmer et al., 2006] Lämmer, S., Gehlsen, B., and Helbing, D. (2006). Scaling laws in the spatial structure of urban road networks. *Physica A: Statistical Mechanics and its Applications*, 363(1):89 – 95. Information and Material Flows in Complex Networks.

- [Mann and Emanuel, 2006] Mann, M. E. and Emanuel, K. A. (2006). Atlantic hurricane trends linked to climate change. *Eos, Transactions American Geophysical Union*, 87(24):233–241.
- [Molyneaux et al., 2016] Molyneaux, L., Brown, C., Wagner, L., and Foster, J. (2016). Measuring resilience in energy systems: Insights from a range of disciplines. *Renewable and Sustainable Energy Reviews*, 59:1068 – 1079.
- [Ouyang and Duenas-Osorio, 2014] Ouyang, M. and Duenas-Osorio, L. (2014). Multi-dimensional hurricane resilience assessment of electric power systems. *Structural Safety*, 48:15–24.
- [Panteli and Mancarella, 2017] Panteli, M. and Mancarella, P. (2017). Modeling and evaluating the resilience of critical electrical power infrastructure to extreme weather events. *IEEE Systems Journal*, 11(3):1733–1742.
- [Panteli et al., 2016] Panteli, M., Trakas, D. N., Mancarella, P., and Hatziairgiou, N. D. (2016). Boosting the power grid resilience to extreme weather events using defensive islanding. *IEEE Transactions on Smart Grid*, 7(6):2913–2922.
- [Pregolato et al., 2017] Pregolato, M., Ford, A., Wilkinson, S. M., and Dawson, R. J. (2017). The impact of flooding on road transport: A depth-disruption function. *Transportation Research Part D: Transport and Environment*, 55:67 – 81.
- [Salmeron et al., 2004] Salmeron, J., Wood, K., and Baldick, R. (2004). Analysis of electric grid security under terrorist threat. *IEEE Transactions on Power Systems*, 19(2):905–912.
- [Scherb et al., 2015] Scherb, A., Garre, L., and Straub, D. (2015). Probabilistic risk assessment of infrastructure networks subjected to hurricanes. *Proceedings of International Conference on Applications of Statistics in Civil Engineering*, 1:1–9.
- [Stott et al., 2009] Stott, B., Jardim, J., and Alsac, O. (2009). Dc power flow revisited. *IEEE Transactions on Power Systems*, 24(3):1290–1300.
- [Winkler et al., 2010] Winkler, J., Duenas-Osorio, L., Stein, R., and Subramanian, D. (2010). Performance assessment of topologically diverse power systems subjected to hurricane events. *Reliability Engineering and System Safety*, 95:323–336.