

Working Title: Multi-Layer Infrastructure Repairs in a Post-Disaster Context

Brian French and Erhan Kutanoglu
Operations Research and Industrial Engineering Program
The University of Texas at Austin
Austin, TX 78712, USA
BCFrench@utexas.edu, erhank@mail.utexas.edu

Abstract

Keywords

1. Introduction

Hurricanes provide a growing concern in the operation of power grids in coastal areas. This paper was undertaken to address the gap in the literature where previous efforts don't consider how network layers depend on each other. To affect repairs on a damaged power grid element, the element must be accessible to the crew attempting to repair it, which implies that the road grid is a part of the repair efforts. In the process of a hurricane, the road grid will sustain substantial damage from flooding and debris on the road surface, which necessitates road grid repairs as well. To handle the issues of repairing power grids efficiently, consideration for repairs of both aspects should be considered jointly.

1.1 Existing Literature

Damage from hurricanes on infrastructure elements is well studied. All of [11], [10], and [6] have looked at the damage to power grids in varying capacities and methodologies. Damage to the road network is studied more in the context of repairing damage. [1] addresses concerns of accessibility to locations in the wake of road damage. [5] focuses their work on the ability to move disaster supplies around.

In the context of power grid repair, it comes from two major areas: Network interdiction and work similar to this paper. [9] is a paper emblematic of work on interdiction and provide the basis for the linear programming formulation of DC power flow used in this paper. [12] provides further literature review of the interdiction problem. [2] addresses a problem similar to this work, though without addressing travel times at all. [3] and [7] both address repairs to power grids in the context of resilience. Most similar to this paper is [4] in that they consider DC power flow and repair with travel times jointly. The key distinction is that they presume that the road operates under nominal conditions rather than including repair of the road grid into the problem.

2. Model

2.1 Overview

The problem to be addressed is how to handle interactions between road and power networks during disaster response. We choose to do this by solving the problems independently to keep runtime tractable and then testing a variety of post processing methods to handle the interactions. This should allow us to capture which interactions are worth the effort to address and which can be ignored in the name of preserving runtime or simplifying analysis

2.2 Assumptions

While considering coordinated repair using the mixed-integer programs below, we assume complete information about damage to both networks, complete information about repair times, and no variation in repair times. In the course of modeling the problem, we assume that a DC-flow model of power grid operation is close enough to real network behavior to draw useful insights [8]. We also assume in the power grid repair model that a minimum spanning tree can approximate routing elements NEEDS CITATION

2.3 Road Model

To model the road repair aspect of the problem, we choose to treat it as a problem of routing a crew tasked with clearing debris and flooding from roads. This is done by solving a variation of the prize collecting rural postman problem at each time step. The discrete time here is done to match up with both standard shift lengths and the discrete time requirement of the DC power flow based model for the power grid.

Defining Parameters and Sets to begin:

- T the set of time periods (shifts) over the time horizon
- N the set of nodes in the graph
- C_{ij} measure of the value of the road from i to j
- L_{ij} is the length of the road between nodes i and j when everything is working as normal
- R_{ij} time to repair the road between i and j
- I_{ij} initial condition of the road between i and j

We then elect to minimize the length of non functioning road over the repair horizon. Without loss of generality the objective can be replaced with the repair priority weights for an agency of choice.

$$\min \sum_{t \in T} \sum_{i,j \in N} C_{ij} * (1 - X_{ij}^t) \quad (1)$$

Subject To:

$$\sum_{i,j \in N} S_{ij}^t K_{ij}^t \leq 8, \quad \forall t \in T \quad (2)$$

$$S_{ij}^t = \max\{L_{ij}, (1 - X_{ij}^t)R_{ij}\}, \quad \forall t \in T \quad \forall i, j \in N \quad (3)$$

$$\sum_{j \in N} K_{ij}^t - \sum_{j \in N} K_{ji}^t = 0, \quad \forall t \in T \quad \forall i \in N \quad (4)$$

$$X_{ij}^t \leq \sum_{t'=0}^{t-1} K_{ij}^{t'} + I_{ij}, \quad \forall t \in T \quad \forall i, j \in N \quad (5)$$

$$\sum_{i,j \in S; i \neq j} X_{ij}^t \leq |S| - 1 \quad \forall S \subset N; S \neq \emptyset \quad (6)$$

Constraint (2) is a shift scheduling constraint capping the length of each tour. Constraint (3) is a linearizable representation of the length of a road conditional on its repair status. Constraints (4) and (6) are standard routing constraints for subtour elimination and path connectivity. Constraint(5) defines the working of damaged roads.

2.4 Power Model

To model the power repair aspect of the problem, we treat it primarily as a scheduling problem. This repair schedule is subject to travel time and shift length constraints, which complicate things as well as an embedded DC power-flow model to evaluate each shift. Traditional routing problems are computationally intractable with commercial solvers on this scale, so to keep runtime in check, a spanning tree was used instead as it provides a lower bound on routing and therefore captures most of the tradeoffs \$CITATION NEEDED. NEED TO TALK ABOUT DISCRETE TIME ASSUMPTION?

We begin modeling the power half of the problem by defining the relevant parameters, sets, and design variables:

| | | | |
|-----------------------------------|--|--------------|--|
| N | set of nodes, indexed by i | X_e^t | flow on line e at time t |
| E | set of power lines, indexed by e | G_k^t | production from generator k at time t |
| R | the set of road segments | V_i^t | indicator for node i functioning at time t |
| T | the planning horizon, indexed by t | W_e^t | indicator for line e functioning at time t |
| $O(i)$ | set of lines with origin i | S_e^t | indicator for line e serviced at time t |
| $D(i)$ | set of lines with destination i | F_i^t | indicator for node i serviced at time t |
| $o(e)$ | origin node of line e | θ_i^t | hase angle for the power flow at i in time t |
| $d(e)$ | destination node of line e | MST_t | length of the tree used for "routing" at t |
| $\underline{L}_e, \overline{L}_e$ | capacity lower and upper bounds for the power line e | Z_{ij}^t | indicator for i to j in the spanning tree at t |
| Δ_i | time to repair node i | | |
| δ_e | time to repair line e | | |
| $C_{SP(i)}$ | length of the shortest path to node i from the central depot | | |
| D_i | power demand at location i in the pre-disaster steady state | | |
| P_k | maximum power generation for generator k | | |
| B_e | line susceptance for power line e | | |
| I_e, I_i | initial condition of line e and node i , respectively | | |

The model is then as follows

$$\min \sum_{i \in N} \sum_{t \in T} (1 - W_i^t) D_i \quad (7)$$

subject to:

$$X_e^t = B_e * (\theta_{o(e)}^t - \theta_{d(e)}^t), \quad \forall t \in T, \quad \forall e \in E \quad (8)$$

$$G_i^t - \sum_{l \in O(i)} X_l^t + \sum_{l \in D(i)} X_l^t = D_i, \quad \forall t \in T, \quad \forall i \in N \quad (9)$$

$$G_k^t \leq P_k V_k^t, \quad \forall t \in T, \quad \forall k \in N \quad (10)$$

$$\underline{L}_e W_e^t \leq X_e^t \leq \overline{L}_e W_e^t, \quad \forall t \in T, \quad \forall e \in E \quad (11)$$

$$\underline{L}_e V_{o(e)}^t \leq X_e^t \leq \overline{L}_e V_{o(e)}^t, \quad \forall t \in T, \quad \forall e \in E \quad (12)$$

$$\underline{L}_e V_{d(e)}^t \leq X_e^t \leq \overline{L}_e V_{d(e)}^t, \quad \forall t \in T, \quad \forall e \in E \quad (13)$$

$$MST^t = \sum_{i \in N} \sum_{j \in N} SP_{ij}^t * Z_{ij}^t C_{speed} \quad \forall t \in T \quad (14)$$

$$\sum_{i \in N} \sum_{j \in N} Z_{ij}^t = \sum_{i \in N} F_i^t + \sum_{e \in E} S_e^t - \sum_{i \in N} F_i^t \sum_{O(i)} S_e^t - \sum_{i \in N} F_i^t \sum_{D(i)} S_e^t \quad \forall t \in T \quad (15)$$

$$\sum_{i,j \in S} Z_{ij}^t \leq |S| - 1 \quad S \subset N \quad (16)$$

$$\sum_{j \in N} Z_{ij}^t \leq F_i^t + \sum_{e \in O(i) \cup D(i)} S_e^t \quad \forall t \in T \quad \forall i \in N \quad (17)$$

$$\sum_{e \in E} \delta_e S_e^t + \sum_{i \in N} \Delta_i F_i^t + MST_t \leq 8 \quad (18)$$

$$V_i^t \leq \sum_{t'=0}^{t-1} F_i^{t'} + I_i, \quad \forall i \in N \quad (19)$$

$$W_e^t \leq \sum_{t'=0}^{t-1} S_e^{t'} + I_e, \quad \forall e \in E \quad (20)$$

Constraints (2)-(7) define the flow on a damaged power grid with load being either switched on or switched off at a demand node. This is done to account for the last mile distribution lines being damaged at first making partial load shedding unrealistic. Constraints (8)-(11) handle construction of a minimum spanning tree between nodes being repaired during a shift to approximate the routing cost. We assume that a power line can be fixed starting from either of it's endpoints. Constraint (12) defines shift scheduling, and constraints (13) and (14) handle constraining operation to elements that are working.

3. Results

3.1 Methods

To demonstrate both validity and utility of the model, we generate two test cases, one based on the IEEE 30 bus network and a second based on the IEEE 57 bus network. Both power grids were overlaid with a Watts-Strogatz graph to provide an simulation of a road network for the sake of the routing aspects of the problem. \$CITE-HERE. To generate a damage scenario, a subset of geographically co-located nodes, power lines, and road network edges were marked as damaged to have scenarios.

The scenarios were each solved under the following frameworks:

- Solve the road repair problem and use the solution to generate a time varying shortest path matrix for use when solving the power repair problem
- Solve the power repair problem assuming statically damaged roads
- Solve the power repair problem assuming nominal road conditions and add a one-shift delay to account for the road repairs being done before the roads are needed
- Solve the power repair problem without travel time and using the generated schedule, post process it into a feasible repair schedule.

4. Conclusions

References

- [1] Dilek. Aksu and Linet Ozdamar. A mathematical model for post-disaster road restoration: Enabling accessibility and evacuation. *Transportation Research Part E*, 61:56–67, 2014.
- [2] Chee Chien Ang. Optimized recovery of damaged electrical power grids. Master’s thesis, Naval Post-graduate School, 3 2006. Found online.
- [3] Ali. Arab, Amin. Khodaei, Suresh. Khator, Kevin. Ding, Valentine. Emesih, and Zhu Han. Stochastic pre-hurricane restoration planning for electric power systems infrastructure. *IEEE Transactions on Smart Grid*, 6:1046–1054, 2015.
- [4] Russell Bent, Pascal vanHentenryck, and Carelton Coffrin. Vehicle routing for the last mile of power system restoration. pages 1–9.
- [5] Pablo. Duque, Irina. Dolinskaya, and Kenneth Sorensen. Network repair crew scheduling and routing for emergency relief distribution problem. *European Journal of Operational Research*, 248:272–285, 2016.
- [6] Seth. Guikema, Steven. Quiring, and Seung-Ryong Han. Prestorm estimation of hurricane damage to electric power distribution systems. *Risk Analysis*, 30:1744–1752, 2010.
- [7] Saeed. Mousavizadeh, Mahmoud-Reza. Haghifam, and Mohammad-Hossein Shariatkhah. A linear two-stage method for resiliency analysis in distribution systems considering renewable energy and demand response resources. *Applied Energy*, 211:243–460, 2018.
- [8] Y. Qi, D. Shi, and D. Tylavsky. Impact of assumptions on dc power flow model accuracy. In *2012 North American Power Symposium (NAPS)*, pages 1–6, Sep. 2012.
- [9] Javier. Salmeron and Aruna Apte. Stochastic optimization for natural disaster asset prepositioning. *Production and Operations Management*, 19:561–574, 2010.
- [10] Anke. Scherb, Luca. Garre, and Daniel Straub. Probabilistic risk assessment of infrastructure networks subjected to hurricanes. *Proceedings of International Conference on Applications of Statistics in Civil Engineering*, 1:1–9, 2015.

- [11] James. Winkler, Leonardo. Duenas-Osorio, Robert. Stein, and Devika Subramanian. Performance assessment of topologically diverse power systems subjected to hurricane events. *Reliability Engineering and System Safety*, 95:323–336, 2010.
- [12] R. Kevin Wood. *Bilevel Network Interdiction Models: Formulations and Solutions*. American Cancer Society, 2011.