




DEVICE LEGEND	
SYMBOL	DESCRIPTION
Ⓢ	SMOKE DETECTOR
Ⓣ	HEAT DETECTOR
F	MANUAL PULL STATION
DD	DUCT DETECTOR
WF	WATERFLOW SWITCH
TS	TAMPER SWITCH
MM	MONITOR MODULE
CM	CONTROL MODULE
FACP	FIRE ALARM CONTROL PANEL
TRAN	TRANSPONDER PANEL




LEVEL 1



LEVEL 2



N.I.C.E.T.
LEVEL IV
CERTIFICATION
FIRE ALARM SYSTEMS
DONNY SCHULTZ
#104396




NOTE:
NFS DRAWINGS ARE BASED ON THE PROJECT
ARCHITECT/ENGINEER (A/E) PLANS AND SPECIFICATIONS
FURNISHED TO NFS. A/E IS SOLELY RESPONSIBLE
(NOT NFS) FOR THE TYPE, SIZE, LOCATION, AND
SUITABILITY OF ALL FIRE ALARMS, CONTROL PANELS,
AND OTHER DEVICES SHOWN ON THE A/E PLANS.
NFS DRAWINGS ARE TO SHOW ONLY THE WIRING
DIAGRAMS BETWEEN FIRE ALARM DEVICES AND
CONTROL PANELS. NFS IS NOT RESPONSIBLE FOR
THE INFORMATION SHOWN ON THE A/E PLANS.

INTERMOUNTAIN NETWORK SCIENTIFIC CC
UNIVERSITY OF UTAH
SALT LAKE CITY, UTAH 84112
FIRE ALARM SYSTEM


NFS	
NELSON FIRE SYSTEMS	
801-468-8300	
DRAWN BY:	JJG
DESIGNED BY:	XXXX
APPROVED BY:	DPS
DATE:	6/27/13
SCALE:	N.T.S.
PROJECT NO:	XXXX
REV NO:	XXXX
DRAWING NAME:	INSCC 1-2.DWG

FIRE ALARM SYSTEM LEVELS 1 AND 2 ADDRESSABLE DEVICES
--



DEVICE LEGEND	
SYMBOL	DESCRIPTION
Ⓢ	SMOKE DETECTOR
Ⓣ	HEAT DETECTOR
F	MANUAL PULL STATION
DD	DUCT DETECTOR
WF	WATERFLOW SWITCH
TS	TAMPER SWITCH
MM	MONITOR MODULE
CM	CONTROL MODULE
FACP	FIRE ALARM CONTROL PANEL
TRAN	TRANSPONDER PANEL



LEVEL 3



LEVEL 4



NOTE:
NFS DRAWINGS ARE BASED ON THE PROJECT
ARCHITECT/ENGINEER (A/E) PLANS AND SPECIFICATIONS
FURNISHED TO NFS. A/E IS SOLELY RESPONSIBLE
(NOT NFS) FOR THE TYPE, SIZE, LOCATION, AND
SUITABILITY OF ALL FIRE ALARMS, CONTROL PANELS,
AND OTHER DEVICES SHOWN ON THE A/E PLANS.
NFS DRAWINGS ARE TO SHOW ONLY THE WIRING
DIAGRAMS BETWEEN FIRE ALARM DEVICES AND
CONTROL PANELS. NFS IS NOT RESPONSIBLE FOR
THE INFORMATION SHOWN ON THE A/E PLANS.

INTERMOUNTAIN NETWORK SCIENTIFIC CC
UNIVERSITY OF UTAH
SALT LAKE CITY, UTAH 84112
FIRE ALARM SYSTEM

NFS
NELSON FIRE SYSTEMS
801-468-8300

DRAWN BY:	JJG
DESIGNED BY:	XXXX
APPROVED BY:	DPS
DATE:	6/27/13
SCALE:	N.T.S.
PROJECT NO:	XXXX
REV NO:	XXXX
DRAWING NAME:	INSCC 3-4.DWG

FIRE ALARM SYSTEM
LEVELS 3 AND 4
ADDRESSABLE DEVICES