

CODE ANALYSIS — SCHEMATIC (REV C) · P2-A-101 REV I / A-102 REV F · P2-G-003 REV K · D-069 CLOSED

Design basis for the architect of record and the AHJ. Not a code review and no statement of approval: every line needs architect + AHJ confirmation (D-008). Values from KEYSTONE research notes; IBC 2021 text read on UpCodes (Alabama).

1 CODE BASIS + EDITIONS (R-006)

CODE	DESIGNED TO	COUNTY 2018 / STATE
Building	IBC 2021 (ASSUMED, Shane)	IBC 2018 (Madison County, since 2021-01-01)
Fire	IFC 2021 (State Fire Marshal; App. B, C, D)	IFC 2018 (county)
Life safety	not reviewed	NFPA 101 2018 (county); ch. 12 new assembly
Plumbing	IPC 2021 / IBC 2021 ch. 29 (ASSUMED)	IPC 2018; arena row of T2902.1 reads the same (R-009)
Assembly egress	IBC 2021 §1030.x	IBC 2018 §1029.x (same subsections; excerpts only, UNVERIFIED)
Energy / electrical	not checked	IECC 2015 (state) / NEC 2017

STATUS of every edition line: 2021 ASSUMED (Shane) — verify with AHJ (D-008 OPEN). Factors read in the 2021 text only; 2018 / NFPA 101 equivalence NOT verified (R-006.2).

AHJ: Madison County Inspection Department if the parcel is unincorporated (Hazel Green is; R-006.1, MEDIUM). DCM 'schoolhouse' review question OPEN. Assembly building needs a registered architect (Ala. Admin. Code 100-X-4-.03).

2 OCCUPANCY (R-007.1)

SPACE	GROUP	CITE (IBC 2021) / CONFIDENCE
Bowl + event floor	A-4	303.5 ('arenas'); HIGH
S&C, cross-training	A-3 or B	303.4 / 304.1 (training); MEDIUM
Admin, first aid	B	304.1
Storage, equipment, mech	S-1	R-007.1 (likely group)
Locker rooms, event lockers	A-4 or B	R-007.1
Mixed occupancy: nonseparated (508.3.1) with A-4 as the main occupancy, fully sprinklered — KEYSTONE recommendation, architect chooses (accessory 508.2 or separated 508.4 also possible).		

3 CONSTRUCTION TYPE

Construction type TBD (architect). Allowable height / area (IBC Tables 504.3, 504.4, 506.2) NOT checked. Inputs for that check: 2 stories, L2 FF 17'-9" (D-061), arena roof 42' ASSUMED, fully sprinklered. Drawn size (D-057, P2-A-101 Rev I incl. the 2,100 SF storage annex + 1,680 SF restroom bump-out / A-102 Rev F): L1 56,860.6 / L2 28,932.6 / TOTAL 85,793.1 GSF (R-021 method).

4 FIRE PROTECTION + SYSTEMS (ASSUMED)

- Automatic sprinklers throughout (903.3.1.1, ASSUMED): 903.2.1.4 triggers for A-4 — fire area > 12,000 SF, occupant load >= 300, floor other than exit discharge; all three met (R-015.5).
- Emergency voice/alarm (907.2.1.1: Group A, occupant load >= 1,000; 907.5.2.2) ASSUMED (R-015.5).
- Sprinklers + voice alarm allow 0.2 in/occupant for stairs (1005.3.1 exc. 1) and 0.15 in for doors and other components (1005.3.2 exc.) (R-018.2, R-015.6).
- Smoke-protected seating NOT assumed (1030.6.2 needs smoke control per 909 + a life safety evaluation; NFPA 101 not reviewed). If used: 1030.6.2.2 roof >= 15' above the highest aisle (loop 17.75') = 32.75'; arena U/S structure 36' drawn (R-022 §5).
- Group A: post the occupant load (1004.9); fire safety + evacuation plan with a seating plan (IFC 403.2.1); telescopic seating per ICC 300 (1030.1.1) (R-007.2).

5 TRAVEL DISTANCE + COMMON PATH

- Exit access travel (T1017.2, A sprinklered): 250 ft. L2 worst measured ≈ 141 ft (R-018.4, Rev D plan; not re-measured on Rev F). L1 (P2-A-111 Rev C, plan Rev I): event floor centre → V2 → EXIT (E) + core-2 corridor → X7 (moved 30 ft east) ≈ 163 ft ≤ 250 (diagram measurement, UNVERIFIED).
- Common path: seats 30 ft to two directions (1030.8; rows not drawn, TBD). Spaces with one exit: T1006.2.1 Group A 49 occupants / 75 ft — locker rooms (71 each) have 2 exits (X2 / X3 + corridor); event lockers (18 each) one door OK if the common path <= 75 ft (TBD).
- Stepped aisles, handrails, guards (1030.9, 1030.16, 1030.17): TBD with the seating layout (R-018.4-5).

6 OCCUPANT LOAD BY SPACE (IBC 2021 T1004.5 / 1004.6; R-007.2)

SPACE (drawn: A-101 Rev I, A-102 Rev F)	AREA SF	FACTOR	LOAD
LEVEL 1			
Lower tier seats (telescopic)		seats	1,100
Boys locker	3,507	50 gross	71
Girls locker	3,507	50 gross	71
Event lockers 1-4	3,600	50 gross	72
Flex / team assembly	2,008	15 net	134
Flex / storage (SW)	975	300 gross	4
Equipment storage + room	1,000	300 gross	4
Mech / elec (4 rooms)	3,881	300 gross	15
First aid	120	150 gross	1
Concession	275	200 gross	2
Chair / table / stage storage (annex, D-067)	2,100	300 gross	7

L1 without the event floor				1,481
Event floor — DESIGN: chairs only (D-054)	16,416	7 net		2,346
L1 TOTAL, design case (all cases: table 7)				3,827
LEVEL 2				
Upper tier seats (fixed)		seats		1,100
Strength & conditioning	5,124	50 gross		103
Cross-training	3,500	50 gross		70
Admin	470	150 gross		4
L2 BASE				1,277
+ loop counted as exercise (R-018 a)	5,026	50 gross		101
+ standing at the W rail (R-018 b)	420	5 net		84
L2 WORST CASE (design, D-052)				1,462

Not added (same occupants moving through; R-018.1 method): lobby, concourses, athlete corridor / route, vestibule, restrooms, stairs. The AHJ may count waiting / standing space. Telescopic tier: number of seats (1004.6); if benches: 1 per 18 in of seat length (row lengths not drawn — may raise the count). Higher posted load by approval up to 1 per 7 SF with a seating diagram (1004.5.1). Event floor area 114 x 144 ft (R-007.2 / D-054; the locked program value is 16,400 SF, D-030).

7 FLOOR CASES — CHAIRS-ONLY (D-054) · POSTED (1004.9)

CASE (T1004.5)	FLOOR	L1	BLDG	POSTED SIGN
Sports (exercise 50 gross, ASSUMED)	329	1,810	3,272	POST
Tables + chairs (15 net)	1,095	2,576	4,038	POST
Chairs only (7 net)	2,346	3,827	5,289	POST (design)
Standing (5 net)	3,284	4,765	6,227	not a use (exit margin)

D-054 DECIDED (Shane 1:22 PM CT): event floor = CHAIRS-ONLY (7 net): graduations, banquets, expos; no standing-concert design. L1 exits stay as drawn for standing (extra margin, no change). IBC 2021 1004.9: the occupant load of a Group A room or space shall be posted in a conspicuous place near the main exit or exit access doorway; one sign per configuration (D-064 Option 2). Not permitted: standing (not a design use, D-054); anything larger than chairs-only needs temporary restroom units (D-064). L2 at its worst case (1,462, D-052).

8 PLUMBING FIXTURE BASIS (R-009)

IPC 2021 ASSUMED (IBC 2021 T2902.1 assembly — arenas; 50/50 split 2902.1.1; urinals <= 67% of male WC, IPC 424.2). 2018 arena row reads the same (R-009). Fixture loads = P2-G-003 Rev I (seats + event floor at 50 gross).

LEVEL (FIXTURE LOAD)	WC M	WC F	LAV M	LAV F	DF	SS
L1 lobby core (rooms 4 + 5)	10	18	4	5	2	1
L1 core 2, east (incl. 7 urinals)	12	24	5	7	2	1
L1 REQUIRED, chairs (3,446)	22	42	9	12	4	1
L1 DRAWN — MEETS (D-069)	22	42	9	12	4	2
L2 drawn (upper seats 1,100)	8	14	3	4	2	1

D-069 CLOSED = Option 2 (Shane 3:31 PM CT): core 2 in a one-storey 30 x 56 ft bump-out, east wall at V2; SW FLEX unchanged (D-039). East confirmed (D-070). Urinals 7 ≤ 14 (IPC 424.2). Larger events: temporary units (D-064).

9 LEVEL 1 EXIT CAPACITY — E1 BANK 512 in (doors 0.15 in/occ.)

Doors and other components 0.15 in per occupant (1005.3.2 exc.: sprinklers 903.3.1.1 + voice alarm 907.5.2.2). E1 = 8-pair bank, 512 in clear (Option 1 DECIDED, 64 in per pair ASSUMED); X1-X10 = 10 x 64 in. Provided 1,152 in. Stair discharge doors carry the L2 worst case first (54.8 in each).

CHECK (in)	329	1,095	2,346	3,284	PROV.
Total at grade (L1 + L2)	490.8	605.7	793.4	934.0	1,152.0
Main exit E1 >= 1/2 (1030.2)	245.4	302.8	396.7	467.0	512.0
Other L1 exits >= 1/2 L1 (1030.3)	135.8	193.2	287.0	357.4	420.7
Lose E1 >= 50% (1005.5)	245.4	302.8	396.7	467.0	640.0

Design case = chairs (2,346 on the floor; building 5,289): E1 needs 396.7 in vs 512 (PASS). Standing (6,227) is kept as margin only: E1 467.0 in, total 934.0 vs 1,152 in (PASS). Exits stay as drawn (D-054).

10 SCREENING BAY + DISCHARGE (D-065, D-066 DECIDED)

- Screening in a side bay of the lobby (P2-A-101 Rev I): clear lobby beside it 39 ft = 468 in ≥ 396.7 (chairs) and ≥ 467.0 (standing margin): PASS; lanes, tables and queues stay in the bay (1003.6, 1010.5). Accessible screening by wand beside the lanes (WTMD passage 32.3 in x 26 in deep vs ADA 403.5.1).
- Exit discharge (1028.3): walk 40 ft at the doors = 28 ft brick + 2 x 6 ft = 480 in ≥ 467.0; bands pass outside both portal piers (28 + 6 + 6 = 40 ft at the portal). P2-C-101 Rev E; public way TBD (site, D-006).

11 LEVEL 2 EGRESS (R-018, D-052)

Stairs 0.2 in per occupant (1005.3.1 exc. 1): 4 stairs x 76 in = 304 in. Worst 1,462 x 0.2 = 292.4 in → spare 11.6 in. Lose one stair: 228 in ≥ 146.2 in (1005.5). 4 exits (T1006.3.3). Unchanged from Rev A.

12 OPEN ITEMS FOR THE ARCHITECT / AHJ

- Code editions + AHJ (D-008): 2021 vs 2018 / NFPA 101 — pre-application meeting with Madison County.
- Core 2 (D-069 CLOSED): plumbing routing + 16 ft height ASSUMED (MEP); X7 discharge to a public way TBD (1028, D-006); chair layouts keep an aisle to V2.
- Door widths, hardware, main-exit frontage (1030.2: street or 10 ft open space) — architect.
- Construction type + allowable area (ch. 5 / 6) — architect.
- Smoke-protected seating or not (1030.6.2) — architect / AHJ.
- Upper-tier structure 1'-6" ASSUMED (structural engineer): front-row clear is exactly 7'-6" (1003.2), zero margin.
- Seat type on the telescopic tier (benches: 1 per 18 in) and the seating layout (aisles, rails, guards).

PRELIMINARY — CONCEPTUAL DESIGN — NOT FOR CONSTRUCTION

PROJECT	PHASE	SHEET TITLE	SCALE	DATE	REV	DRAWN BY	SHEET
Hazel Green Regional Athletic Complex Trojan Horse Arena · Hazel Green area, Madison County, Alabama (site TBD, D-006)	PHASE 2	CODE ANALYSIS SCHEMATIC	NTS	October 2026	C	Drawn by Claude (AI) for Shane Brazelton	P2-G-002