

1 AREA BY LEVEL — 16,400 SF FLOOR, 2,200 BOWL SEATS, 2 LEVELS, NO SUITES


SPACE	FIXED	TELESCOPIC	BASIS
LEVEL 1 (net SF)			
Event floor (D-030, locked)	16,400	16,400	phase2.yaml · D-030
Lower tier seats (1,100)	6,600	3,719	6.0 / 3.38 SF/seat (R-008)
Boys Locker Room	3,500	3,500	phase2.yaml tag
Girls Locker Room (D-013)	3,503	3,503	phase2.yaml tag; D-013 open
Event / visitor locker rooms	3,600	3,600	4 x (14 wrestlers + 4 staff) x 50 SF
Foyer / trophy lobby (hall of champions)	800	800	200 + 400 + 200 (Loudoun 2014)
Lower concourse	1,375	1,375	25% of seats x 5 SF standing (T1004.5)
Public restrooms L1 (37 fixtures)	1,850	1,850	T2902.1 x 50 SF (R-009)
Concession stand	275	275	Loudoun kitchen proxy; D-011
First aid	120	120	Loudoun 2014; 1 room counted
Equipment storage (mats + floor covers)	700	700	Loudoun gym storage proxy
Equipment room	300	300	Loudoun equip./maint. proxy
Stairs (4) + elevator	890	890	R-015
L1 net	39,913	37,032	
Mechanical (5% of total gross, at grade)	4,047	3,662	R-014 · LOW
L1 GROSS (x 1.25)	54,949	50,868	R-014 gross-up

LEVEL 2 (net SF)			
Upper tier seats (1,100)	6,600	3,719	6.0 / 3.38 SF/seat (R-008)
Strength & Conditioning	6,000	6,000	phase2.yaml tag
Cross-Training Mat Area	4,000	4,000	phase2.yaml tag
Administrative office	470	470	150 + 120 + 200 (Loudoun 2014)
Upper concourse / hall of champions wall	1,375	1,375	same factor, upper seats
Public restrooms L2 (29 fixtures)	1,450	1,450	T2902.1 x 50 SF (R-009)
Stairs (4) + elevator	890	890	R-015
L2 net	20,785	17,904	
L2 GROSS (x 1.25)	25,981	22,380	

FIT CHECK			
Arena volume gross (floor + lower tier, double height)	28,750	25,149	
L1 ring = L1 – arena volume (L2 must sit over it)	26,199	25,719	
L2 over the ring?	YES	YES	margin 218 / 3,339
FOOTPRINT = max(L1, arena volume + L2)	54,949	50,868	
Footprint cap (D-031) · margin	51	4,132	cap 55,000 SF
FITS 55,000 FOOTPRINT?	YES	YES	
TOTAL GSF (2 levels)	80,930	73,248	not capped (D-031)

FIXED = 6.0 SF/seat elevated seating. TELESCOPIC = every bowl seat on bleacher geometry (3.38 SF/seat). Both columns use the same x 1.25 gross-up, so only the seating type differs. Tier split 50/50 ASSUMED. Stage and utility room: no source, left out. Seating type stays OPEN (D-009).

2 EVENT FLOOR CHECK (R-005, R-012)



- Drawn 114 x 144 ft = 16,416 SF (locked 16,400; +16 SF).
- E-W: 2 x 42 ft mats + 3 x 10 ft clear (NFHS 2-1-5) = 114 ft.
- N-S: same 114 ft + two 15 ft table/bench zones (table ≥ 10 ft from mat, NFHS 2-3; depth ASSUMED).
- Rev A layout 114 x 126 = 14,364 SF (6 ft tables) fits inside: YES.
- Court 84 x 50 + 10 ft runout = 104 x 70 ft (dashed, long axis N-S): fits, YES.

3 FIXTURES BY LEVEL (IBC 2021 T2902.1)

LEVEL	LOAD	WC M	WC W	LAV M	LAV W	DF	SUM
L1	1,428	10	18	4	5	2	37
L2	1,100	8	14	3	4	2	29
TOTAL	2,528	18	32	7	9	4	66

L1 load = lower seats + 328 floor occupants (50 SF each); L2 = upper seats. Same in both columns (load follows seats, not seat type). Urinals may replace up to 67% of men's WCs (IPC 424.2). 1 service sink. SUM = WCs + lavatories (50 SF each, ASSUMED).

4 STAIRS + ELEVATOR (R-015)

L2 load 1,304 (1,100 seats + 204 in S&C, cross-training, admin) → 4 stairs (T1006.3.3) x 65 in (0.2 in/occupant, sprinklered + voice alarm, 1005.3.1), ≈ 206 SF each per level; 1 elevator (1104.4), 64 SF hoistway ASSUMED. 890 SF per level, same on both levels and aligned. Open stairs OK for two stories (1019.3 exc. 1). Floor-to-floor 15 ft ASSUMED.

5 WHEELCHAIR SPACES

2,200 bowl seats → 18 wheelchair spaces (IBC T1109.2.2.1 / ADA T221.2.1.1: 6 + 1 per 150 over 500), each with a companion seat (ADA 221.3), dispersed across both tiers with lines of sight (ADA 221.2.3, 802.2). Same count for either seating type; where they sit in a telescopic bank is an architect task.

6 RESULT

LOCKED PROGRAM (D-030)

16,400 SF floor · 2,200 bowl seats

2 levels · no suites

Fixed: footprint 54,949 · FITS

Telescopic: 50,868 · FITS

Total 80,930 GSF fixed / 73,248 telescopic. Fixed leaves only 51 SF under the cap; the drawn 16,416 SF floor uses 16 more. Telescopic frees ≈ 3,300 SF over the ring and ≈ 4,100 SF of footprint.

7 LOCKED IN phase2.yaml

- Event floor 16,400 SF (D-030); 4 x 42 ft mats, 2 x 2.
- 2,200 seats, all in the bowl; 2 levels; footprint cap 55,000 SF (D-031).
- S&C + cross-training on Level 2 over the lockers.
- The 22,000 SF arena tag is SUPERSEDED for the event floor (kept as history).
- Changes only on CHANGE APPROVED.

8 STILL OPEN

- Seating type, fixed vs telescopic (D-009): plans P2-A-101/102 show fixed solid, telescopic dashed.
- Suites: PARKED, future add-on, study after attendance is proven.
- AHJ / code edition (D-008); girls locker size (D-013); concession scope (D-011).

9 CITED vs ASSUMED

CITED: seat SF (R-008), fixtures + egress + wheelchair tables (R-009, R-015, R-016), gross-up and mechanical share (R-014), mat and court clearances (R-005, R-012). ASSUMED: 50/50 tiers, 50 SF/fixture, 15 ft floor-to-floor, table zone depth, concourse share, same gross-up for telescopic.

10 SOURCES (retrieved 2026-10-03)

- Shane 11:39 PM CT (D-030 decision)
- R-005, R-008, R-009, R-012, R-014, R-015, R-016
- Rev C (suites) frozen; history in Revs A-C

PRELIMINARY — CONCEPTUAL DESIGN — NOT FOR CONSTRUCTION

PROJECT	PHASE	SHEET TITLE	SCALE	DATE	REV	DRAWN BY	SHEET
Hazel Green Regional Athletic Complex Trojan Horse Arena · Hazel Green area, Madison County, Alabama (site TBD, D-006)	PHASE 2	LOCKED PROGRAM D-030 · AREA BY LEVEL, NOT A PLAN	NTS	October 2026	D	Drawn by KEYSTONE (AI) for Shane Brazelton	P2-G-003