

1 AREA BY LEVEL — 16,400 SF FLOOR, 2,200 SEATS, MIX SEATING (D-009)

SPACE	MIX (D-009)	ALL FIXED	BASIS
LEVEL 1 (net SF)			
Event floor (D-030, locked)	16,400	16,400	phase2.yaml · D-030
Lower tier seats (1,100), TELESCOPIC	3,719	6,600	3.38 SF/seat (R-008) · fixed col. 6.0
Boys Locker Room	3,500	3,500	phase2.yaml tag
Girls Locker Room (D-013)	3,503	3,503	phase2.yaml tag; D-013 open
Event / visitor locker rooms	3,600	3,600	4 x (14 wrestlers + 4 staff) x 50 SF
Foyer / trophy lobby (hall of champions)	800	800	200 + 400 + 200 (Loudoun 2014)
Lower concourse	1,375	1,375	25% of seats x 5 SF standing (T1004.5)
Public restrooms L1 (37 fixtures)	1,850	1,850	T2902.1 x 50 SF (R-009)
Concession stand	275	275	Loudoun kitchen proxy; D-011
First aid	120	120	Loudoun 2014; 1 room counted
Equipment storage (mats + floor covers)	700	700	Loudoun gym storage proxy
Equipment room	300	300	Loudoun equip./maint. proxy
Stairs (4) + elevator	890	890	R-015
L1 net	37,032	39,913	
Mechanical (5% of total gross, at grade)	3,854	4,047	R-014 · LOW
L1 GROSS (x 1.25)	51,108	54,949	R-014 gross-up
LEVEL 2 (net SF)			
Upper tier seats (1,100), FIXED	6,600	6,600	6.0 SF/seat (R-008)
Strength & Conditioning	6,000	6,000	phase2.yaml tag
Cross-Training Mat Area	4,000	4,000	phase2.yaml tag
Administrative office	470	470	150 + 120 + 200 (Loudoun 2014)
Upper concourse / hall of champions balcony	1,375	1,375	same factor, upper seats
Public restrooms L2 (29 fixtures)	1,450	1,450	T2902.1 x 50 SF (R-009)
Stairs (4) + elevator	890	890	R-015
L2 net	20,785	20,785	
L2 GROSS (x 1.25)	25,981	25,981	
FIT CHECK			
Arena volume gross (floor + lower tier, double height)	25,149	28,750	
Arena volume + L2 gross	51,130	54,731	L2 sits over the L1 ring
FOOTPRINT = max(L1, arena volume + L2)	51,130	54,949	mix: set by arena volume + L2
MARGIN under the 55,000 SF cap (D-031)	3,870	51	target ≥ 2,000 (Shane)
Meets the ≥ 2,000 SF target?	YES	NO	
TOTAL GSF (2 levels)	77,089	80,930	not capped (D-031)

MIX = D-009 as decided: lower tier on telescopic bleacher geometry (3.38 SF/seat), upper tier fixed (6.0 SF/seat). ALL FIXED = Rev D base case, for reference. Same x 1.25 gross-up. Tier split 50/50 ASSUMED. Mix: L1 alone is 51,108, so the arena volume + L2 (51,130) sets the footprint; the L1 ring must be 22 SF bigger than L1 needs, which that footprint gives.

2 SEATS BY SIDE AND TIER = 2,200

SIDE	LOWER (TELE.)	UPPER (FIXED)	TOTAL
North	353	308	661
South	341	308	649
East	406	484	890
TOTAL	1,100	1,100	2,200
capacity drawn	1,306	1,125	2,431

No west tier (OK'd). Lower: 6 rows x 24 in = 12 ft extended (R-008), less the 12 ft portal and two 8 ft vomitories. Upper: 15 ft at 6.0 SF/seat. Each tier = 1,100, split by side in proportion to drawn capacity (P2-A-101/102 Rev B). Spare capacity is left for wheelchair spaces and aisles; the upper tier has only 25 spare.

3 EVENT FLOOR (unchanged, R-005, R-012)

114 x 144 ft = 16,416 SF drawn (locked 16,400): 4 x 42 ft mats 2 x 2 with 10 ft clear, 15 ft table zones N and S; the 114 x 126 = 14,364 SF layout and an 84 x 50 court + 10 ft runout (104 x 70) fit. Long axis N-S on the entry axis.

4 FIXTURES BY LEVEL (IBC 2021 T2902.1)

LEVEL	LOAD	WC M	WC W	LAV M	LAV W	DF	SUM
L1	1,428	10	18	4	5	2	37
L2	1,100	8	14	3	4	2	29
TOTAL	2,528	18	32	7	9	4	66

L1 = lower seats + 328 floor occupants (50 SF each); L2 = upper seats. Unchanged from Rev D (load follows seats, not seat type). On the plans the restrooms flank the lobby, L2 stacked over L1.

5 STAIRS, ELEVATOR, WHEELCHAIR

L2 load 1,304 → 4 stairs (T1006.3.3) x 65 in (0.2 in/occ., 1005.3.1), ≈ 206 SF each per level + 1 elevator (1104.4) = 890 SF per level, aligned on both levels. 18 wheelchair spaces + companions (IBC T1109.2.2.1, ADA 221.3), dispersed (ADA 221.2.3) — placement in the telescopic and fixed tiers is an architect task.

6 RESULT

LOCKED PROGRAM + MIX
16,400 SF floor · 2,200 seats · 2 levels
telescopic lower · fixed upper
Footprint 51,130 · margin 3,870
Target ≥ 2,000 SF: MET

Total 77,089 GSF (Rev D all-fixed: 80,930). Block plan box shrinks from 250 x 220 to 204 x 252 ft = 51,408 SF: 3,592 SF under the cap and 278 SF over the program footprint, so the gross-up allowance stays inside the box (P2-A-101/102 Rev B).

7 LOCKED IN phase2.yaml

- Event floor 16,400 SF; 4 x 42 ft mats, 2 x 2 (D-030).
- 2,200 seats in the bowl, N, S and E sides; 2 levels; footprint cap 55,000 SF (D-031).
- Seating MIX: telescopic lower tier, fixed upper tier (D-009, Shane 4:30 AM CT).
- S&C + cross-training on Level 2 over the lockers. Changes only on CHANGE APPROVED.

8 STILL OPEN

- 50/50 tier split and 6 telescopic rows (ASSUMED); sightlines not checked.
- AHJ / code edition (D-008); girls locker size (D-013); concession scope (D-011); owner (D-007); site (D-006).
- Suites PARKED (future add-on).

9 CITED vs ASSUMED

CITED: seat SF and row depth (R-008), fixtures, egress and wheelchair tables (R-009, R-015, R-016), gross-up and mechanical share (R-014), mat and court clearances (R-005, R-012). ASSUMED: 50/50 tiers, 6 rows, 50 SF/fixture, 15 ft floor-to-floor, table zones, concourse share, box shape.

10 SOURCES (retrieved 2026-10-03)

- Shane 2026-10-04 4:30 AM CT (D-009 mix, Rev E, margin target)
- R-005, R-008, R-009, R-012, R-014, R-015, R-016
- Rev D (all fixed vs telescopic) frozen; history in Revs A-D

PRELIMINARY — CONCEPTUAL DESIGN — NOT FOR CONSTRUCTION

PROJECT	PHASE	SHEET TITLE	SCALE	DATE	REV	DRAWN BY	SHEET
Hazel Green Regional Athletic Complex Trojan Horse Arena · Hazel Green area, Madison County, Alabama (site TBD, D-006)	PHASE 2	LOCKED PROGRAM (MIX) D-009 · AREA BY LEVEL, NOT A PLAN	NTS	October 2026	E	Drawn by KEYSTONE (AI) for Shane Brazelton	P2-G-003