

1 AREA BY LEVEL — 2,200 SEATS, MIX, L2 LOOP, 76 IN STAIRS (D-052)

SPACE	REV G	REV F	BASIS
LEVEL 1 (net SF)			
Event floor 16,400 + 864 east clear zone	17,264	16,400	D-030 · D-053 east tier 16 ft
Lower tier seats (1,100), TELESCOPIC	3,719	3,719	3.38 SF/seat (R-008) · fixed col. 6.0
Boys Locker Room	3,500	3,500	phase2.yaml tag
Girls Locker Room (D-013)	3,503	3,503	phase2.yaml tag; D-013 open
Event / visitor locker rooms	3,600	3,600	4 x (14 wrestlers + 4 staff) x 50 SF
Foyer / trophy lobby (hall of champions)	800	800	200 + 400 + 200 (Loudoun 2014)
Lower concourse	1,375	1,375	25% of seats x 5 SF standing (T1004.5)
Public restrooms L1 (37 fixtures)	1,850	1,850	T2902.1 x 50 SF (R-009)
Concession stand	275	275	Loudoun kitchen proxy; D-011
First aid	120	120	Loudoun 2014; 1 room counted
Equipment storage (mats + floor covers)	700	700	Loudoun gym storage proxy
Equipment room	300	300	Loudoun equip./maint. proxy
Stairs (4 x 76 in) + elevator	1,145	874	D-052 · landing = width (D-051)
L1 net	38,151	37,016	
Mechanical (5% of total gross, at grade)	4,037	3,939	R-014 · LOW
L1 GROSS (x 1.25)	52,735	51,194	R-014 gross-up
LEVEL 2 (net SF)			
Upper tier seats (1,100), FIXED	6,600	6,600	6.0 SF/seat (R-008)
Strength & Conditioning	5,224	5,224	D-035 (as Rev F)
Cross-Training Mat Area	3,500	3,500	D-035 (as Rev F)
Administrative office	470	470	150 + 120 + 200 (Loudoun 2014)
Upper concourse / balcony	—	—	the loop replaces it (D-035)
Public restrooms L2 (29 fixtures)	1,450	1,450	T2902.1 x 50 SF (R-009)
Stairs (4 x 76 in) + elevator	1,145	874	D-052 · landing = width (D-051)
L2 net rooms (without the loop)	18,389	18,118	
Running / training loop (drawn, not grossed up)	5,026	4,942	A-102 Rev E (Rev F: Rev D) · no x1.25
L2 GROSS (x 1.25 rooms + loop)	28,012	27,590	
Arena volume gross (floor + east zone + lower tier)	26,229	25,149	
Arena volume + L2 gross	54,241	52,738	L2 sits over the L1 ring
PROGRAM FOOTPRINT = max(L1, arena volume + L2)	54,241	52,738	set by arena volume + L2
PROGRAM TOTAL GSF (L1 gross + L2 gross)	80,748	78,784	no cap (D-056)

SIZE — D-057: L1 FOOTPRINT · L2 AREA · TOTAL GSF · CHANGE vs LAST REV (no cap, no margin)							
	DRAWN	REV D	CHANGE	PROGRAM	REV F	CHANGE	DRAWN – PROG.
	A-101/102 E	drawn	vs Rev D	G-003 G	program	vs Rev F	(C-3)
L1 FOOTPRINT	53,062	51,503	+1,559	54,241	52,738	+1,503	−1,179
L2 AREA	28,914	28,363	+551	28,012	27,590	+423	+902
TOTAL GSF	81,976	79,866	+2,110	82,253	80,328	+1,925	−277

Program TOTAL here = program footprint + L2 gross (82,253), to compare like with like; L1 + L2 gross = 80,748. REV G = Rev F with 76 in stairs and 76 in intermediate landings (D-052, D-051; 270 SF each per level), the 864 SF east clear zone (D-053) in L1 and the arena volume, and the Rev E loop (5,026 SF). Drawn sizes are measured on P2-A-101/102 Rev E. The program footprint carries 1,506 SF of L1 ring that no program line counts; R-021 explains drawn vs program line by line. R-021's flat-add estimate (54,589 / 28,432) is replaced by this method.

2 SEATS BY SIDE AND TIER = 2,200 (REV E PLAN)

SIDE	LOWER (TELE.)	UPPER (FIXED)	TOTAL
North	359	314	673
South	347	314	661
East	394	472	866
TOTAL	1,100	1,100	2,200
capacity drawn	1,349	1,155	2,504
No west tier (OK'd). Lower: 6 rows x 24 in = 12 ft extended (R-008), less the 12 ft portal and two 8 ft vomitories. Upper: 15 ft, 5 rows x 36 in at 19 in risers (D-053), stepping down to the court (D-049), 6.0 SF/seat. Each tier = 1,100, split by side in proportion to drawn capacity (P2-A-101/102 Rev E). The 6 ft east shift makes the N / S bands 132 ft: split was N 661 / S 649 / E 890 (Rev F); totals unchanged. Upper spare 55.			

3 LEVEL 2 RUNNING / TRAINING LOOP (D-035)

2 lanes x 42 in = 7 ft all around, squared corners. Centerline 154 x 205 ft: 2 x (154 + 205) = 718 ft; 5,280 / 718 = 7.35 laps/mile. Area 5,026 SF. Lanes: UFC 4-740-02N 4.1.7 (42 in, min 3 lanes), Athletic Business (36-42 in; max 12 laps/mile, 8-10 preferred). 2 lanes is ASSUMED: 3 lanes (10.5 ft) does not fit without moving the upper tier. Event days: upper concourse, spectators cross it at the tier entries; non-event days: training. 42 in guards at open edges (IBC 1015.2, 1015.3). East leg 6 ft further east (D-053).

4 FIXTURES BY LEVEL (IBC 2021 T2902.1)

LEVEL	LOAD	WC M	WC W	LAV M	LAV W	DF	SUM
L1	1,428	10	18	4	5	2	37
L2	1,100	8	14	3	4	2	29
TOTAL	2,528	18	32	7	9	4	66

L1 = lower seats + 328 floor occupants (50 SF each); L2 = upper seats. Unchanged from Rev F (load follows seats). Restrooms flank the lobby, L2 stacked over L1.

5 STAIRS, ELEVATOR, WHEELCHAIR

4 stairs (T1006.3.3) x 76 in (D-052: worst case 1,462 x 0.2 in = 292.4 in ≤ 4 x 76 = 304 in), intermediate landing = width (D-051): 12.67 x 21.33 ft ≈ 270 SF each per level + 1 elevator (1104.4) = 1,145 SF per level, aligned on both levels. 18 wheelchair spaces + companions (IBC T1109.2.2.1, ADA 221.3), dispersed (ADA 221.2.3) — placement in the telescopic and fixed tiers is an architect task. ST-2 needs a 6.67 ft NE stair tower to clear the loop (was 5 ft).

6 RESULT

DRAWN SIZE (A-101/102 REV E) L1 53,062 · L2 28,914 SF TOTAL 81,976 GSF (+2,110 vs Rev D) 2,200 seats · loop 718 ft · 7.35 laps/mi No SF cap (D-056) · size = budget + parcel

Drawn building = 210 x 252 ft + 21.33 x 6.67 ft NE stair tower = 53,062 SF. Program footprint 54,241 (+1,179 vs drawn): the program grosses up the open arena box; the drawing absorbs the 76 in stairs in the box and draws the lobby void (R-021). Event floor drawn 120 x 144 = 17,280 SF.

7 LOCKED IN phase2.yaml

- Event floor 16,400 SF; 4 x 42 ft mats, 2 x 2 (D-030).
- 2,200 seats in the bowl, N, S and E sides; 2 levels; no SF cap (D-056, D-031 retired).
- Seating MIX: telescopic lower tier, fixed upper tier (D-009, Shane 4:30 AM CT).
- S&C 5,224 + cross-training 3,500 SF on Level 2 (D-035; were 6,000 / 4,000).
- Continuous L2 loop, 2 x 42 in (D-035). 76 in stairs (D-052); east tier 16 ft, 19 in upper risers (D-053).

8 STILL OPEN

- Loop lane count (2 ASSUMED; 3 preferred); 50/50 tier split and 6 telescopic rows (ASSUMED).
- Under-tier headroom reading (D-049): Rev E keeps rows 1-2 (< 7'-6" clear, ASSUMED) for storage / mech only.
- AHJ / code edition (D-008); girls locker size (D-013); concession scope (D-011); owner (D-007); site (D-006).
- Suites PARKED (future add-on).

9 CITED vs ASSUMED

CITED: seat SF and row depth (R-008), fixtures, egress and wheelchair tables (R-009, R-015, R-016), gross-up and mechanical share (R-014), lane width (UFC 4-740-02N, Athletic Business), guards (IBC 1015). ASSUMED: 2 lanes, loop not grossed up, east zone grossed up like the floor, 50/50 tiers, 6 rows, 50 SF/fixture, box shape.

10 SOURCES (retrieved 2026-10-04)

- Shane 2026-10-04 9:10 AM CT (Rev G); D-051, D-052, D-053, D-056, D-057; R-021
- R-008, R-009, R-014, R-015, R-016, R-020; UFC 4-740-02N; Athletic Business; IBC 2021 1011.6, 1015
- Rev F frozen; history in Revs A-F

PRELIMINARY — CONCEPTUAL DESIGN — NOT FOR CONSTRUCTION

PROJECT	PHASE	SHEET TITLE	SCALE	DATE	REV	DRAWN BY	SHEET
Hazel Green Regional Athletic Complex Trojan Horse Arena · Hazel Green area, Madison County, Alabama (site TBD, D-006)	PHASE 2	LOCKED PROGRAM + LOOP REV E PLAN · D-057 SIZES	NTS	October 2026	G	Drawn by KEYSTONE (AI) for Shane Brazelton	P2-G-003