

1 AREA BY LEVEL — 2,200 SEATS, L2 LOOP, ANNEX + BUMP-OUT (D-069)

SPACE	REV K	REV J	BASIS
LEVEL 1 (net SF)			
Event floor 16,400 + 864 east clear zone	17,264	17,264	D-030 · D-053 east tier 16 ft
Lower tier seats (1,100), TELESCOPIC	3,719	3,719	3.38 SF/seat (R-008) · fixed col. 6.0
Boys Locker Room	3,500	3,500	phase2.yaml tag
Girls Locker Room (D-013)	3,503	3,503	phase2.yaml tag; D-013 open
Event / visitor locker rooms	3,600	3,600	4 x (14 wrestlers + 4 staff) x 50 SF
Foyer / trophy lobby (hall of champions)	800	800	200 + 400 + 200 (Loudoun 2014)
Lower concourse	1,375	1,375	25% of seats x 5 SF standing (T1004.5)
Public restrooms L1 (37 WC + lav)	1,850	1,850	T2902.1 WC+lav x 50 SF (R-009)
Concession stand	275	275	Loudoun kitchen proxy; D-011
First aid	120	120	Loudoun 2014; 1 room counted
Equipment storage (mats + floor covers)	700	700	Loudoun gym storage proxy
Equipment room	300	300	Loudoun equip./maint. proxy
Stairs (4 x 76 in, 31 risers) + elevator	1,284	1,284	D-061 17'-9" · D-052 · D-051
L1 net	38,290	38,290	
Mechanical (5% of total gross, at grade)	4,056	4,056	R-014 · LOW
L1 GROSS (x 1.25)	52,933	52,933	R-014 gross-up
+ Chair / table / stage storage annex (gross)	2,100	2,100	D-067 · 2.0 aisle factor, no x1.25
+ Restroom bump-out, core 2 (gross)	1,680	—	D-069 · drawn 30 x 56 ft, no x1.25
L1 GROSS incl. annex + bump-out	56,713	55,033	both one storey (A-101 I)
LEVEL 2 (net SF)			
Upper tier seats (1,100), FIXED	6,600	6,600	6.0 SF/seat (R-008)
Strength & Conditioning	5,224	5,224	D-035 (as Rev F)
Cross-Training Mat Area	3,500	3,500	D-035 (as Rev F)
Administrative office	470	470	150 + 120 + 200 (Loudoun 2014)
Upper concourse / balcony	—	—	the loop replaces it (D-035)
Public restrooms L2 (29 WC + lav)	1,450	1,450	T2902.1 WC+lav x 50 SF (R-009)
Stairs (4 x 76 in, 31 risers) + elevator	1,284	1,284	D-061 17'-9" · D-052 · D-051
L2 net rooms (without the loop)	18,528	18,528	
Running / training loop (drawn, not grossed up)	5,026	5,026	A-102 Rev F (= Rev E) · no x1.25
L2 GROSS (x 1.25 rooms + loop)	28,186	28,186	
Arena volume gross (floor + east zone + lower tier)	26,229	26,229	
Arena volume + L2 gross	54,415	54,415	L2 sits over the L1 ring
PROGRAM FOOTPRINT = max + annex + bump-out	58,195	56,515	max(L1, AV + L2): arena volume + L2 + 2,...
PROGRAM TOTAL GSF (L1 gross + L2 gross)	84,899	83,219	no cap (D-056)

SIZE — D-057: L1 FOOTPRINT · L2 AREA · TOTAL GSF · CHANGE vs LAST REV (no cap, no margin)							
	DRAWN	REV H	CHANGE	PROGRAM	REV J	CHANGE	DRAWN – PROG.
	A-101 I / 102 F	drawn	vs Rev H	G-003 K	program	vs Rev J	(C-3)
L1 FOOTPRINT	56,861	55,181	+1,680	58,195	56,515	+1,680	−1,335
L2 AREA	28,933	28,933	±0	28,186	28,186	±0	+746
TOTAL GSF	85,793	84,113	+1,680	86,381	84,701	+1,680	−588

Program TOTAL here = program footprint + L2 gross (86,381); L1 + L2 gross = 84,899 (+1,680 vs Rev J). REV K = Rev J + the D-069 restroom bump-out (Option 2, Shane 3:31 PM CT): core 2, 1,680 SF one storey on the east wall at V2 / EXIT (E), added gross like the annex (its 30 x 56 ft is the drawn test-fit incl. +10 % walls / chases and the corridor; ASSUMED; 50 SF / fixture would be 2,400). Drawn sizes are measured on P2-A-101 Rev I / A-102 Rev F: L1 grows by the bump-out only, L2 unchanged. The program footprint carries 1,482 SF of L1 ring that no program line counts (R-021).

2 SEATS BY SIDE AND TIER = 2,200 (REV I PLAN)

SIDE	LOWER (TELE.)	UPPER (FIXED)	TOTAL
North	359	314	673
South	347	314	661
East	394	472	866
TOTAL	1,100	1,100	2,200
capacity drawn	1,349	1,155	2,504

No west tier (OK'd). Lower: 6 rows x 24 in = 12 ft extended (R-008), less the 12 ft portal and two 8 ft vomitories. Upper: 15 ft, 5 rows x 36 in at 21 in risers from the L2 loop at 17'-9" down to a 9.0 ft front row = 7'-6" clear under row 1 (D-061), 6.0 SF/seat. Each tier = 1,100, split by side in proportion to drawn capacity (P2-A-101/102 Rev F). Split unchanged from Rev G/H; no seats lost. Upper spare 55.

3 LEVEL 2 RUNNING / TRAINING LOOP (D-035)

2 lanes x 42 in = 7 ft all around, squared corners. Centerline 154 x 205 ft: 2 x (154 + 205) = 718 ft; 5,280 / 718 = 7.35 laps/mile. Area 5,026 SF. Lanes: UFC 4-740-02N 4.1.7 (42 in, min 3 lanes), Athletic Business (36-42 in; max 12 laps/mile, 8-10 preferred). 2 lanes is ASSUMED: 3 lanes (10.5 ft) does not fit without moving the upper tier. Event days: upper concourse, spectators cross it at the tier entries; non-event days: training. 42 in guards at open edges (IBC 1015.2, 1015.3). East leg 6 ft further east (D-053).

4 FIXTURES BY LEVEL (IBC 2021 T2902.1)

LEVEL	LOAD	WC M	WC W	LAV M	LAV W	DF	WC+LAV	SUM
SUM incl. 4 drinking fountains								
L1	1,428	10	18	4	5	2	37	39
L2	1,100	8	14	3	4	2	29	31
TOTAL	2,528	18	32	7	9	4	66	70
L1 req.	3,446	22	42	9	12	4	85	89
· lobby core		10	18	4	5	2	37	39
· core 2 (E)		5+7u	24	5	7	2	48	50

L1 / L2 rows = the Rev I set the program lines carry (L1 = lower seats + 328 floor at 50 SF). D-069 DECIDED Option 2: L1 chairs-only (3,446) = lobby core (rooms 4 + 5, as drawn) + core 2 in the east bump-out (rooms 25-27): 22 / 42 WC, 9 / 12 lav, 4 DF — PASS. Core-2 urinals $7 \leq 8$ (67 % of 12, IPC 2021 424.2). Larger events: posted loads (1004.9), temporary units.

SUM incl. 4 drinking fountains (2 per level, T2902.1). Restroom SF uses WC+LAV only (66 x 50 SF, ASSUMED); fountains sit outside the rooms. Rev G's SUM column was WC+LAV (66). 1 service sink per level (not counted).

5 STAIRS, ELEVATOR, WHEELCHAIR

4 stairs (T1006.3.3) x 76 in (D-052: worst case 1,462 x 0.2 in = 292.4 in $\leq$ 4 x 76 = 304 in). 17'-9" floor-to-floor (D-061): 31 risers of 6.87 in ($\leq$ 7 in, 1011.5.2), 2 flights (16 + 15), 165 in run, intermediate landing = width (D-051): 12.67 x 24.08 ft $\approx$ 305 SF each per level + 1 elevator (1104.4) = 1,284 SF per level, aligned on both levels. 18 wheelchair spaces + companions (IBC T1109.2.2.1, ADA 221.3), dispersed (ADA 221.2.3), architect to place. NE stair tower 24.08 x 6.67 ft (was 21.33 x 6.67).

6 RESULT

DRAWN SIZE (A-101/102 REV I) L1 56,861 · L2 28,933 SF TOTAL 85,793 GSF (+1,680 vs Rev H) 2,200 seats · loop 718 ft · 7.35 laps/mi No SF cap (D-056) · size = budget + parcel

Drawn building = 210 x 252 ft + 24.08 x 6.67 ft NE stair tower = 53,081 SF. Program footprint 58,195 (+5,115 vs drawn): the program grosses up the open arena box; the drawing absorbs the 31-riser stairs in the box and draws the lobby void (R-021). Event floor drawn 120 x 144 = 17,280 SF. + annex 2,100 + bump-out 1,680 SF.

7 LOCKED IN phase2.yaml

- Event floor 16,400 SF; 4 x 42 ft mats, 2 x 2 (D-030).
- 2,200 seats in the bowl, N, S and E sides; 2 levels; no SF cap (D-056, D-031 retired).
- Seating MIX: telescopic lower tier, fixed upper tier (D-009, Shane 4:30 AM CT).
- S&C 5,224 + cross-training 3,500 SF on Level 2 (D-035; were 6,000 / 4,000).
- Continuous L2 loop, 2 x 42 in (D-035). 76 in stairs (D-052); east tier 16 ft (D-053). L2 17'-9", 21 in upper risers (D-061).
- Chairs floor 2,346 (D-054); annex 2,100 (D-067); 2 restroom cores (D-069).

8 STILL OPEN

- X7 discharge east to a public way; core-2 plumbing (D-006, MEP).
- Loop lane count (2 ASSUMED; 3 preferred); 50/50 tier split and 6 telescopic rows (ASSUMED).
- Front row 7'-6" clear assumes $\approx$ 1'-6" deck structure (no margin, IBC 1003.2): structural engineer to confirm.
- AHJ / code edition (D-008); girls locker size (D-013); concession scope (D-011); owner (D-007); site (D-006).
- Suites PARKED (future add-on).

9 CITED vs ASSUMED

CITED: seat SF and row depth (R-008), fixtures, egress and wheelchair tables (R-009, R-015, R-016), gross-up and mechanical share (R-014), lane width (UFC 4-740-02N, Athletic Business), guards (IBC 1015). ASSUMED: 2 lanes, loop not grossed up, east zone grossed up like the floor, 50/50 tiers, 6 rows, 50 SF/fixture, box shape.

10 SOURCES (retrieved 2026-10-04)

- Shane 2026-10-04 3:31 PM CT (Rev K: D-069 CLOSED = Option 2, east restroom bump-out, fixture split)
- R-008, R-009, R-014-R-016, R-020; IPC 2021 424.2; IBC 2021 T2902.1, 2902.3.3, 1004.9
- Revs F-I frozen; Rev J in review; history in Revs A-J

PRELIMINARY — CONCEPTUAL DESIGN — NOT FOR CONSTRUCTION

PROJECT	PHASE	SHEET TITLE	SCALE	DATE	REV	DRAWN BY	SHEET
Hazel Green Regional Athletic Complex Trojan Horse Arena · Hazel Green area, Madison County, Alabama (site TBD, D-006)	PHASE 2	PROGRAM + LOOP + STORAGE + RESTROOMS REV I PLAN · D-069 · D-057	NTS	October 2026	K	Drawn by KEYSTONE (AI) for Shane Brazelton	P2-G-003