

बिड दस्तावेज़ / Bid Document

बिड विवरण / Bid Details	
बिड बंद होने की तारीख/समय / Bid End Date/Time	29-06-2026 16:00:00
बिड खुलने की तारीख/समय / Bid Opening Date/Time	29-06-2026 16:30:00
बिड पेशकश वैधता (बंद होने की तारीख से) / Bid Offer Validity (From End Date)	90 (Days)
मंत्रालय/राज्य का नाम / Ministry/State Name	Ministry Of Chemicals And Fertilizers
विभाग का नाम / Department Name	Department Of Fertilizers
संगठन का नाम / Organisation Name	Brahmaputra Valley Fertilizer Corporation Limited (bvfc)
कार्यालय का नाम / Office Name	Namrup Assam
शिकायत निवारण के संपर्क विवरण / Contact details of Grievance redressal	pdgogoi.bvfc@nic.in
कुल मात्रा / Total Quantity	7
वस्तु श्रेणी / Item Category	1250 Amps BFW Pump Motor Feeder , 1250 Amps Fire Water Pump Motor , 1250 Amps Benfield Solution Pump Motor Feeder , 1250 Amps 100 BFW Pump Motor Feeder , 1250 Amps PCC Feeder , 1250 Amps Raw Water Feeder , Installation and Commissioning
GeMARPTS में खोजी गई स्ट्रिंग्स / Searched Strings used in GeMARPTS	Retrofitting (Design, manufacturing, testing, supply, inspection, installation & commissioning) of M/s NGEF make, 11KV, 500MVA, 3phase and 3.3KV, 150MVA, 3phase, MOCBs (Minimum Oil Circuit Breaker) of type ECU5012/10 with M/S ABB make horizontally draw-out, horizontally isolated Vacuum Circuit Breakers (VCB's) conforming to IS: 13118/IEC56
GeMARPTS में खोजा गया परिणाम / Searched Result generated in GeMARPTS	Category not available on GeM for the text string uploaded by the buyer
अधिसूचना के लिए चयनित प्रासंगिक श्रेणियाँ / Relevant Categories selected for notification	Spares for Tripper and Apron Feeder
बीओक्यू शीर्षक / BOQ Title	retrofitting
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) / Minimum Average Annual Turnover of the bidder (For 3 Years)	20 Lakh (s)
मूल उपकरण निर्माता का औसत टर्नओवर (गत 3 वर्षों का) / OEM Average Turnover (Last 3 Years)	80 Lakh (s)

बिड विवरण/Bid Details	
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service	3 Year (s)
टर्नओवर के लिए एमएसई को छूट प्राप्त है / MSE Relaxation for Turnover	Yes Complete
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Relaxation for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Past Performance,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,OEM Annual Turnover,Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेन् है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	2
विगत प्रदर्शन /Past Performance	20 %
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	Yes
रिवर्स नीलामी योग्यता नियम/RA Qualification Rule	H1-Highest Priced Bid Elimination
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	1250 Amps BFW Pump Motor Feeder
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No

बिड विवरण/Bid Details

Payment Timelines	Payments shall be made to the Seller within 30 days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	86460

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	5.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	32

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज प्रस्तुत करने है। एमएसई कैटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

(c).ईएमडी और संपादन जमानत राशि लाभार्थी के पक्ष में होनी चाहिए। / Earnest Money Deposit (EMD) shall also be accepted by the buyer in the form of a surety bond.

लाभार्थी /Beneficiary :

Chief Manager (Fin.)

Namrup Assam, Department of Fertilizers, Brahmaputra Valley Fertilizer Corporation Limited (BVFCL), Ministry of Chemicals and Fertilizers

(Brahmaputra Valley Fertilizer Corporation Ltd.)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता / MII Purchase Preference

एमआईआई खरीद वरीयता / MII Purchase Preference	Yes
--	-----

मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% तक की सीमा में है / Purchase Preference to MII sellers available upto price within L1+X%	20
मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference	50
सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time)	Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time)

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं/सेवा प्रदाता को खरीद में प्राथमिकता, यदि उनका मूल्य L1+X% / Purchase Preference to MSE OEMs/ Service Provider available upto price within L1+X%	15
सूक्ष्म और लघु उद्यम मूल उपकरण निर्माता/सेवा प्रदाता को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Percentage of Bid quantity/amount for MSE OEMs/ Service Provider Purchase preference	25

ट्रेड्स भुगतान संबंधी विवरण/TReDS Payment Details

This Bid provides for Trade Receivables Discounting System (TReDS) as Preferred mode of payment. For MSME sellers, payments may be processed through a TReDS exchange in which the Buyer is registered, subject to applicable policy and regulatory guidelines. Accordingly, sellers intending to avail payment through TReDS are required to be registered with at least one TReDS exchange in which the buyer is registered.

1. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover, shall upload the supporting documents to prove his eligibility for Relaxation.
2. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
3. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as

indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

4. OEM Turn Over Criteria: The minimum average annual financial turnover of the OEM of the offered product during the last three years, ending on 31st March of the previous financial year, should be as indicated in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the OEM is less than 3 year old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

5. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017 and its subsequent Orders/Notifications issued by concerned Ministry .Benefits of MSE will be allowed only if seller/service provider is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

6. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs having valid Udyam Certificate and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service, and Buyer will decide eligibility for purchase preference based on documentary evidence submitted in case of product bids, whereas in case of services the eligibility is automatically validated. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

7. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

8. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 20% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

9. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:

- i. If number of technically qualified bidders are only 2 or 3.
- ii. If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
- iii. In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
- iv. If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
- v. If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

1250 Amps BFW Pump Motor Feeder

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Pranjal Deep Gogoi	786623,BVFCL, Namrup, PO Parbatpur	1	240

1250 Amps Fire Water Pump Motor

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Pranjal Deep Gogoi	786623,BVFCL, Namrup, PO Parbatpur	1	240

1250 Amps Benfield Solution Pump Motor Feeder

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Pranjal Deep Gogoi	786623,BVFCL, Namrup, PO Parbatpur	1	240

1250 Amps 100 BFW Pump Motor Feeder

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Pranjal Deep Gogoi	786623,BVFCL, Namrup, PO Parbatpur	1	240

1250 Amps PCC Feeder

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Pranjal Deep Gogoi	786623,BVFCL, Namrup, PO Parbatpur	1	240

1250 Amps Raw Water Feeder

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Pranjal Deep Gogoi	786623,BVFCL, Namrup, PO Parbatpur	1	240

Installation And Commissioning

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

Specification Document	View File
BOQ Detail Document	View File

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

प्रेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.N o.	प्रेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Pranjal Deep Gogoi	786623,BVFCL, Namrup, PO Parbatpur	1	240

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

1. Scope of Supply

Scope of supply (Bid price to include all cost components) : Only supply of Goods

2. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

Vendor's Scope

A) Design, manufacture and factory testing of the VCBs conforming to national and International standards / references. The quality of the materials used shall be of best quality and as per international standard.

B) Mounting the VCBs on wheel carriage which can be adopted in existing breaker cubicles with matching primary (Bus bar side & cable side) and secondary connection engagements.

C) Carriage wiring to be similar to existing one as per wiring scheme of M/s NGEF.

D) Installation and Commissioning of the VCBs in existing panels at customer's site.

E) Collection of detail data of existing MOCBs (to be retrofitted) & panels, dimensions, rack switches, auxiliary switch, and other associated systems required for execution of the work by visiting the customer's site.

F) Submission of drawings, test certificates, operation and maintenance instructions, recommended spare parts list, Guarantee against poor workmanship and supply and other relevant documents along with the supply.

H) GENERAL SPECIFICATIONS FOR VCB:-

1.01 This specification covers the complete Design, Manufacture, and Assembly, Testing at works before dispatch, Inspection & Delivery at site in suitably packed condition for V.C.B.s and accessories. The scope of work shall also include supply of V.C.B.s complete in all respect, supervision of Erection / Testing / Checking/ Installation & Commissioning & Retrofitting of existing MOCB of M/s NGEF, type EKV 5012 /10 of 11 KV and 3.3 KV by VCBs as per technical details of Annexure-V. All data of V.C.B shall be filled in Annexure- VI.

1.02 The VCB offered shall be of proven design by way of successful commercial operation for three years

1.03 All drawings, schedules & enclosures attached to these specifications shall form part of the specification.

1.04 The VCBs offered shall be with latest technology of Vacuum Interrupters, complete in all respects & shall match the Physical dimensions of the existing MOCB and panels. Any material which may not have been specifically mentioned, but which is usually necessary for satisfactory trouble free operation & maintenance of VCB shall be furnished without any extra charge.

2.00 Circuit Breakers:

The circuit breakers shall be of the 3 phase, single break , Horizontally draw out, horizontal isolation, Vacuum break type as mentioned in specification sheet suitable for LOCAL / REMOTE operation with rupturing capacity & continuous current carrying capacity as given in the specification. The circuit breakers shall comply with the requirement of all relevant standards. The circuit breaker shall have sustained rupturing capacity on repeated operations due to fault. The circuit breaker shall consist of three separate identical single pole operated through common shaft by the operating mechanism.

2.01 The rated closing coil supply is 110V DC. The closing coil & other auxiliary devices shall operate satisfactorily at all voltages between 80% to 120% of the rated control voltage 110V DC.

2.02 When the breaker is in closed position, a closing of an initiating control device shall neither result in further operation of the breaker closing mechanism nor endanger the operator.

- 2.03 An emergency handle shall be supplied for manual operation of the breaker in case of failure of closing power. The close push button provided for this purpose shall be accessible after opening the door.
- 2.04 Provision shall be made for manual closing & slow closing for maintenance & contact adjustment purpose. A suitable operating handle shall be supplied, one for each VCB, for this purpose.
- 2.05 Each breaker shall have three positions-SERVICE, TEST & ISOLATED with mechanical indications. The design of breaker should be such that without opening the front access door it should not be possible to pull out the breaker in disconnected position.
- 2.06 The breakers shall be provided with motor operated power closing mechanism & shall include trip-free (electrically & mechanically) & anti pumping features. The closing motor shall be suitably protected against damage due to over-heating. Motor operated mechanism shall be complete with universal motor, opening spring, closing spring & all necessary accessories to make the mechanism complete operating unit. The motor shall be suitable operation with voltage variation from 80% to 120% of rated voltage (110 Volt D.C.). As long as power is available to the motor, a continuous sequence of closing & opening shall be possible. After failure of power supply to motor at least one-close-open operation of the circuit breaker shall be possible.
- 2.07 The breakers shall be provided with shunt trip coil. Provision shall be made for mechanically tripping the breaker in case of emergency. The trip coil & other associated auxiliary devices shall operate reliably & satisfactorily at all voltages between 50 to 120% of its rated voltages i.e. 110 volt D.C.
- 2.08 Mechanical indicators for ON, OFF, ISOLATED position & spring CHARGED- DISCHARGED indications shall be provided on the front of the breakers. The breaker shall also be provided with an operation counter.
- 2.09 Mechanical interlocks shall be provided to prevent:
- i) A closed C.B. from being isolated from or inserted into the service position.
 - ii) Closing & opening of the C.B. in an intermediate position between service & Test & between Test & Disconnected position.
 - iii) Any other functions not permitted as per requirement specified.
- 2.10 Automatic Safety shutters with padlocking arrangement shall be provided to cover completely the primary fixed line contacts, when the breaker is in ISOLATED /TEST position.
- 2.11 Positive earthing of circuit breaker frame shall be maintained when it is in connected position & in all other positions in which the safety shutters are in open position.
- 2.12 VCB shall be mounted on the truck. Two operating lever to operate limit switch mounted inside the panel at respective position, one at left side & another at right side for service condition interlocking & indication respectively shall be mounted on the truck (When looking from operating end of the VCB). One separate operating lever to operate limit switch mounted inside the panel for VCB test position indication shall be mounted on the VCB at right side of the truck (when looking from operating end of the VCB).

3.0 ARC INTERRUPTING DEVICES

The arc interrupting devices shall be capable of interrupting satisfactorily at current zero to the rated interrupting current when used on predominantly capacitive or inductive circuits.

4.0 SURGE SUPPRESSORS

Surge suppressors shall have to be provided for the motor feeders with the VCBs.

5.0 CIRCUIT BREAKER AUXILIARY SWITCH CONTACTS & RACK SWITCH CONTACTS.

The circuit breaker shall be provided with the same numbers of normally open & normally closed contacts as in the existing MOCBs. Circuit breakers' auxiliary switch contacts, with the spare contacts to be wired to the terminal board. The auxiliary contacts shall be suitable for inductive breaking (not less than 5 Amps.) at the control voltage specified. Necessary number of rack switch contacts shall be included.

6.0 **TEST CERTIFICATES, DRAWINGS & LITERATURE ETC.**

Quadruplicate copies of the following documents & drawings shall be submitted along with the tender:-

- a) Complete report on the short circuit tests, certified by a recognized & independent testing authority i.e. CPRI, in support of the ratings of the circuit breakers offered. Routine & Type test as per latest IS standard.
- b) Principal dimensioned outline of each VCB with General Arrangement Drawings should be matched with the existing dimension of the MOCB and its panels.

7.0 **TOOLS & TACKLES**

- 7.01 M/s ABB shall furnish a complete & unused set of all special tools & tackles which are necessary or convenient for erection, testing, commissioning, maintenance & overhauling of the VCB.
- 7.02 The tools shall be dispatched in separate container clearly marked with the name of the equipment for which they are intended.
- 7.03 M/s ABB shall submit a list of tools proposed to be furnished under the scope of supply along with the offer (if any).

8.0 **TECHNICAL PARTICULARS :**

The technical & dimensional particulars of the existing MOCBs, which are required to be retrofitted are attached herewith for reference. The tenderer shall furnish the technical Particulars in the Blank proforma of Annexure 'VI' (technical particulars which is attached herewith) along with the offer.

9.0. **DEVIATIONS:**

The scope of supply shall be fully spelt out by the tenderer. Any intended omission or deviation must be clearly stated giving reference to this specification otherwise it will be understood that the equipment offered shall be as per this specification.

10. **COMMISSIONING SCHEDULE:-**The retrofitting job will be taken during ATA (Annual Turn Around) or any Scheduled or non scheduled shut down of long period and will be fixed after mutual agreement between BVFCL & the Successful bidder.

11. Payment Terms:

a) **For Supply:** Payment shall be made in 30 days after receipt and acceptance of materials at site.

b) Installation and Commissioning Charges shall be paid within 30 days after completion of work duly certified by the executing department

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs and including the modification of technical specifications and / or terms and conditions governing the bid. All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM. If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid & resultant contract shall be treated as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

1. Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).
2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Single Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.
4. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.
8. Seeking experience from specific organization / department / institute only or from foreign / export experience.
9. Creating bid for items from incorrect categories.
10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1 bidders through a Random Algorithm executed by GeM system.
14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.

For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.

The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:

- All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and
- All operative provisions of the erstwhile Labour Laws until their complete substitution.

All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.

This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.

However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---