

**बिड दस्तावेज़ / Bid Document**

| बिड विवरण/Bid Details                                                                                                        |                                                                                                                                                                                                                                                                                                                                    |
|------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| बिड बंद होने की तारीख/समय /Bid End Date/Time                                                                                 | 30-07-2026 11:00:00                                                                                                                                                                                                                                                                                                                |
| बिड खुलने की तारीख/समय /Bid Opening Date/Time                                                                                | 30-07-2026 11:30:00                                                                                                                                                                                                                                                                                                                |
| बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)                                                    | 120 (Days)                                                                                                                                                                                                                                                                                                                         |
| मंत्रालय/राज्य का नाम/Ministry/State Name                                                                                    | Ministry Of Power                                                                                                                                                                                                                                                                                                                  |
| विभाग का नाम/Department Name                                                                                                 | Na                                                                                                                                                                                                                                                                                                                                 |
| संगठन का नाम/Organisation Name                                                                                               | Nhpc Limited                                                                                                                                                                                                                                                                                                                       |
| कार्यालय का नाम/Office Name                                                                                                  | Nhpc Ltd Parbati-iii Power Station                                                                                                                                                                                                                                                                                                 |
| शिकायत निवारण के संपर्क विवरण/ Contact details of Grievance redressal                                                        | HOD Email id :hop-parbati3@nhpc.nic.in<br>Buyer Email id: dharmendra@nhpc.nic.in                                                                                                                                                                                                                                                   |
| कुल मात्रा/Total Quantity                                                                                                    | 1                                                                                                                                                                                                                                                                                                                                  |
| वस्तु श्रेणी /Item Category                                                                                                  | OTI / WTI Calibrator (Q3)                                                                                                                                                                                                                                                                                                          |
| बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) /Minimum Average Annual Turnover of the bidder (For 3 Years)               | 4 Lakh (s)                                                                                                                                                                                                                                                                                                                         |
| उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service               | 1 Year (s)                                                                                                                                                                                                                                                                                                                         |
| वर्षों के अनुभव एवं टर्नओवर से एमएसई को छूट प्राप्त है / MSE Relaxation for Years Of Experience and Turnover                 | Yes   Complete                                                                                                                                                                                                                                                                                                                     |
| स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है / Startup Relaxation for Years Of Experience and Turnover | Yes   Complete                                                                                                                                                                                                                                                                                                                     |
| विक्रेता से मांगे गए दस्तावेज़/Document required from seller                                                                 | Experience Criteria,Bidder Turnover,Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC)<br>*In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer |

| बिड विवरण/Bid Details                                                                                                                                                                                                    |                                                                                                                                                                                                                                          |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेजों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid? | No                                                                                                                                                                                                                                       |
| बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension                                                                                | 3                                                                                                                                                                                                                                        |
| दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended                                                                                                      | 7                                                                                                                                                                                                                                        |
| ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count                                                                                                                                            | 3                                                                                                                                                                                                                                        |
| बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled                                                                                                                                                                       | No                                                                                                                                                                                                                                       |
| बिड का प्रकार/Type of Bid                                                                                                                                                                                                | Two Packet Bid                                                                                                                                                                                                                           |
| तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation                                                                                        | 5 Days                                                                                                                                                                                                                                   |
| निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)                                     | No                                                                                                                                                                                                                                       |
| अनुमानित बिड मूल्य / Estimated Bid Value                                                                                                                                                                                 | 810000                                                                                                                                                                                                                                   |
| Payment Timelines                                                                                                                                                                                                        | Payments shall be made to the Seller within <b>45</b> days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC) |
| मूल्यांकन पद्धति/Evaluation Method                                                                                                                                                                                       | Total value wise evaluation                                                                                                                                                                                                              |
| मध्यस्थता खंड/Arbitration Clause                                                                                                                                                                                         | No                                                                                                                                                                                                                                       |
| सुलह खंड/Mediation Clause                                                                                                                                                                                                | No                                                                                                                                                                                                                                       |

#### ईएमडी विवरण/EMD Detail

|                             |                     |
|-----------------------------|---------------------|
| एडवाइजरी बैंक/Advisory Bank | State Bank of India |
| ईएमडी राशि/EMD Amount       | 16000               |

#### ईपीबीजी विवरण /ePBG Detail

|                             |                     |
|-----------------------------|---------------------|
| एडवाइजरी बैंक/Advisory Bank | State Bank of India |
|-----------------------------|---------------------|

|                                                                    |      |
|--------------------------------------------------------------------|------|
| ईपीबीजी प्रतिशत (%) / ePBG Percentage (%)                          | 5.00 |
| ईपीबीजी की आवश्यक अवधि (माह) / Duration of ePBG required (Months). | 15   |

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित कैटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने है। एमएसई कैटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b). ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

(c). ईएमडी और संपादन जमानत राशि लाभार्थी के पक्ष में होनी चाहिए। / Earnest Money Deposit (EMD) shall also be accepted by the buyer in the form of a surety bond.

#### लाभार्थी /Beneficiary :

NHPC LIMITED

NHPC LIMITED, SECTOR-33, FARIDABAD, HARYANA-121003, UNIT: PARBATI-III POWER STATION, BEHALI, PO LARJI, DISTT. KULLU (H.P.)

(.)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

#### एमआईआई खरीद वरीयता / MII Purchase Preference

|                                                                                                                                                                                                                                                                                                                                                                                           |                                                                                             |
|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------|
| एमआईआई खरीद वरीयता / MII Purchase Preference                                                                                                                                                                                                                                                                                                                                              | Yes                                                                                         |
| मेक इन इंडिया विक्रेताओं को खरीद में प्राथमिकता, यदि उनका मूल्य $L1+X\%$ तक की सीमा में है / Purchase Preference to MII sellers available upto price within $L1+X\%$                                                                                                                                                                                                                      | 20                                                                                          |
| मेक इन इंडिया खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Maximum Percentage of Bid quantity for MII purchase preference                                                                                                                                                                                                                                                 | 100                                                                                         |
| सार्वजनिक खरीद (मेक-इन-इंडिया को प्राथमिकता) आदेश 2017 के अनुसार केवल क्लास 1/क्लास 2 के स्थानीय आपूर्तिकर्ताओं को ही भागीदारी की अनुमति है दिनांक 16.09.2020 (समय-समय पर संशोधित एवं लागू) / Allow participation only from Class 1/Class 2 local suppliers as per the Public procurement(Preference to Make-in-india) order 2017 date 16.09.2020(as amended and applicable time to time) | Yes, in compliance with the MII ORDER : DPIIT Order(as amended and applicable time to time) |

#### एमएसई खरीद वरीयता/MSE Purchase Preference

|                                           |     |
|-------------------------------------------|-----|
| एमएसई खरीद वरीयता/MSE Purchase Preference | Yes |
|-------------------------------------------|-----|

|                                                                                                                                                                                                           |     |
|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----|
| सूक्ष्म और लघु उद्यम मूल उपकरण निर्माताओं/सेवा प्रदाता को खरीद में प्राथमिकता, यदि उनका मूल्य $L1+X\%$ / Purchase Preference to MSE OEMs/ Service Provider available upto price within $L1+X\%$           | 15  |
| सूक्ष्म और लघु उद्यम मूल उपकरण निर्माता/सेवा प्रदाता को खरीद में प्राथमिकता के लिए बिड की मात्रा का अधिकतम प्रतिशत / Percentage of Bid quantity/amount for MSE OEMs/ Service Provider Purchase preference | 100 |

#### ट्रेड्स भुगतान संबंधी विवरण/TReDS Payment Details

**This Bid provides for Trade Receivables Discounting System (TReDS) as Preferred mode of payment. For MSME sellers, payments may be processed through a TReDS exchange in which the Buyer is registered, subject to applicable policy and regulatory guidelines. Accordingly, sellers intending to avail payment through TReDS are required to be registered with at least one TReDS exchange in which the buyer is registered.**

1. If the bidder is a Micro or Small Enterprise as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Experience Criteria" as defined above subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
2. If the bidder is a Micro or Small Enterprise (MSE) as per latest orders issued by Ministry of MSME, the bidder shall be relaxed from the eligibility criteria of "Bidder Turnover" as defined above subject to meeting of quality and technical specifications. If the bidder itself is MSE OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover, shall upload the supporting documents to prove his eligibility for Relaxation.
3. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Experience Criteria" as defined above subject to their meeting of quality and technical specifications. The bidder seeking Relaxation from Experience Criteria, shall upload the supporting documents to prove his eligibility for Relaxation.
4. If the bidder is a DPIIT registered Startup, the bidder shall be relaxed from the the eligibility criteria of "Bidder Turnover" as defined above subject to their meeting of quality and technical specifications. If the bidder is DPIIT Registered OEM of the offered products, it would be relaxed from the "OEM Average Turnover" criteria also subject to meeting of quality and technical specifications. The bidder seeking Relaxation from Turnover shall upload the supporting documents to prove his eligibility for Relaxation.
5. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.
6. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.
7. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers

as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017 and its subsequent Orders/Notifications issued by concerned Ministry .Benefits of MSE will be allowed only if seller/service provider is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

**8. Purchase preference to Micro and Small Enterprises (MSEs):** Purchase preference will be given to MSEs having valid Udyam Certificate and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service, and Buyer will decide eligibility for purchase preference based on documentary evidence submitted in case of product bids, whereas in case of services the eligibility is automatically validated. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 100% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

9. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

### OTI / WTI Calibrator ( 1 pieces )

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 60% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

| विवरण/Specification | विशिष्टि का नाम /Specification Name    | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|---------------------|----------------------------------------|-----------------------------------------------------------------|
| Operating Features  | Cooling Time (140 deg C to 0 deg C)    | 30 to 35 minutes                                                |
|                     | Radial Uniformity for liquid bath mode | <0.02                                                           |
|                     | Heating Time (-30 deg C to +140 deg C) | 30 to 35 minutes                                                |
|                     | Radial Uniformity for dry block mode   | <0.008                                                          |

| विवरण/Specification   | विशिष्टि का नाम /Specification Name                                                                                                                                                                                                                       | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values) |
|-----------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------|
|                       | <b>Built-in universal sensor input allowing PRT, T/C, alongwith linear process inputs including 4-20mA current transmitters to be displayed. It should be programmable with upto 5 calibration points to provide high accuracy digital probe matching</b> | Yes                                                             |
|                       | Functionality: The unit should be suitable for comparison/Calibration of RTD, Thermocouple, Temperature switches, Thermostats and Liquid in glass thermometers, OTI and WTI gauges                                                                        | Yes                                                             |
|                       | Indicator Units                                                                                                                                                                                                                                           | deg C, deg F, K                                                 |
|                       | <b>Test Thermostats</b>                                                                                                                                                                                                                                   | 1                                                               |
|                       | <b>Stability in liquid bath mode</b>                                                                                                                                                                                                                      | +/-0.03 deg C                                                   |
|                       | <b>Switch Testing option for testing thermostats to be provided by bidder</b>                                                                                                                                                                             | Yes                                                             |
|                       | <b>Calibration Well Depth to allow calibration of larger dia sensors, longer sensors and simultaneous calibration of more no. of sensors at a time</b>                                                                                                    | 160 mm depth & 35 mm dia                                        |
|                       | <b>Stability in Dry block mode</b>                                                                                                                                                                                                                        | +/-0.03 deg C                                                   |
|                       | <b>Mode of operation</b>                                                                                                                                                                                                                                  | Dry Block Calibrator cum Stirred Liquid Bath                    |
|                       | <b>Temperature Range</b>                                                                                                                                                                                                                                  | 55 deg C below ambient to +140 deg C                            |
|                       | <b>Transmitter Input (4 to 20mA)</b>                                                                                                                                                                                                                      | Yes                                                             |
|                       | <b>Display Resolution (Best)</b>                                                                                                                                                                                                                          | 0.01 (degree Celsius)                                           |
| Portability           | <b>Unit shall be light weight and shall be supplied with a sturdy carry case for the main unit as well as the accessories</b>                                                                                                                             | Portable                                                        |
| Operational Component | <b>Suitable oil to cover the entire working ranges - 250ml to be provided by bidder along with instrument</b>                                                                                                                                             | Yes                                                             |

| विवरण/Specification   | विशिष्टि का नाम /Specification Name                                                                                                                                                                                  | बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)                                                                                                                                                                       |
|-----------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|                       | <b>Stirred Liquid Container kit for calibration of Liquid in glass thermometers &amp; OTI &amp; WTI Gauges and to accommodate different sizes of sensors to be provided</b>                                          | Yes                                                                                                                                                                                                                                   |
| Reference PRT Details | <b>PRT Self heating error at 1mA</b>                                                                                                                                                                                 | 0.004 ( <b>degree Celsius</b> )                                                                                                                                                                                                       |
|                       | <b>PRT Length</b>                                                                                                                                                                                                    | 210mm with 1.5 mtr PTFE 4 wire cable                                                                                                                                                                                                  |
|                       | <b>PRT Temperature Range</b>                                                                                                                                                                                         | -50 deg C to 250 deg C                                                                                                                                                                                                                |
|                       | <b>PRT Diameter</b>                                                                                                                                                                                                  | 4                                                                                                                                                                                                                                     |
|                       | <b>PRT stability</b>                                                                                                                                                                                                 | 0.010 ohm/year                                                                                                                                                                                                                        |
| General Specification | <b>Carrying Case</b>                                                                                                                                                                                                 | Yes                                                                                                                                                                                                                                   |
|                       | Computer Interface (To be provided along with Windows Driven software having capability to control, automatically log & display the temperature of bath with graphical presentation. Interface cable to be provided) | Serial                                                                                                                                                                                                                                |
|                       | <b>Software</b>                                                                                                                                                                                                      | Control, Monitor & Data logging                                                                                                                                                                                                       |
|                       | Power                                                                                                                                                                                                                | 230 VAC (+/-10%), 50 Hz, 150 W                                                                                                                                                                                                        |
|                       | Display                                                                                                                                                                                                              | LCD display                                                                                                                                                                                                                           |
| Accessories           | <b>Bill of Material</b>                                                                                                                                                                                              | Main equipment i.e., OTI/WI Calibrator, Traceable calibration certificate, Serial Communications, Software, Reference PRT, Metal block insert, Stirred liquid container bath, Manual, Mains lead, Sturdy carrying case for Calibrator |
| Warranty              | <b>Warranty (Years)</b>                                                                                                                                                                                              | 1.0 ( <b>year</b> )                                                                                                                                                                                                                   |
| Test Report           | Availability of Type Test Report for conformity of parameters from any ILAC/NABL accredited/Central Gov. LAB/OEM .                                                                                                   | Yes                                                                                                                                                                                                                                   |

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

| क्र.सं./S.N<br>o. | प्रेषिती/रिपोर्टिंग<br>अधिकारी /Consignee<br>Reporting/Officer | पता/Address                                                                  | मात्रा /Quantity | डिलीवरी के दिन/Delivery<br>Days |
|-------------------|----------------------------------------------------------------|------------------------------------------------------------------------------|------------------|---------------------------------|
| 1                 | Akhilesh Singh                                                 | 175122,Parbati -III Power<br>Station Vill- Behali, Post-Larji<br>Distt-Kullu | 1                | 120                             |

## क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions

### 1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be  $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$ , subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

### 2. Certificates

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

### 3. Generic

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- Copy of PAN Card.
- Copy of GSTIN.
- Copy of Cancelled Cheque.
- Copy of EFT Mandate duly certified by Bank.

### 4. Buyer Added Bid Specific ATC

Buyer uploaded ATC document [Click here to view the file.](#)

## अस्वीकरण/Disclaimer

The Additional Terms and Conditions (ATC) have been incorporated by the Buyer after approval of their Competent Authority. The Buyer ,is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any restriction arising in the bidding process due to these ATCs and including the modification of technical specifications and / or terms and conditions governing the bid.All representations / grievances pertaining to the ATC clauses shall be raised with the buyer organization directly and not with GeM.If any of the clause(s) is/are incorporated by the Buyer regarding the following, the bid & resultant contract shall be treated as null & void. Further, GeM reserves the right, at its sole discretion, to cancel the bid forthwith, without issuance of any prior notice or intimation :-

- Publishing Custom / BOQ bids for items for which regular GeM categories are available (unless such Custom / BOQ item is bunched with the major regular product Category Item).



2. Mandating procurement of / from specific Brand / Make / Model / Manufacturer / Dealer except in case of Single Bid / Proprietary Article Certificate (PAC) Buying.
3. Inclusion of disqualification criteria related to suspension of seller / service provider, where such suspension period has already expired.
4. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
5. Publishing bids on GeM for procurement of works.
6. Procurement of Goods by creating a Service bid on GeM & vice-versa.
7. Seeking sample with bid or approval of samples during bid evaluation process. However, trial / sample, as the case may be, shall be permitted in cases where trial / sample are allowed as per approved and published procurement policy of the Buyers' controlling Ministry / Department / State / Public Sector Enterprises Headquarters. If there is any violation of trial / sample clause with regard to approved policy of the Buyers' Ministry / Department / State / Public Sector Enterprises Headquarters, then this is to be determined and redressed by the concerned Buyer Organisation only.
8. Seeking experience from specific organization / department / institute only or from foreign / export experience.
9. Creating bid for items from incorrect categories.
10. Reference of conditions published on any external site or reference to external documents/clauses.
11. Asking for any Tender fee / Bid Participation fee, as the case may be.
12. Buyer added ATC Clauses which are in contravention of clauses defined in bid detail section, including specifications, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by the applicable GeM GTC.
13. Any ATC clause in contravention with GeM GTC Clause 4 (xiii) (h) will be invalid. In case of multiple L1 bidders against a service bid, the buyer shall place the Contract by selection of a bidder amongst the L-1 bidders through a Random Algorithm executed by GeM system.
14. In a category based bid, adding additional items, through buyer added, additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogues or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

**All GeM Sellers/Service Providers shall ensure full compliance with all applicable labour laws, including the provisions, rules, schemes and guidelines under the four Labour Codes i.e. the Code on Wages, 2019; the Industrial Relations Code, 2020; the Occupational Safety, Health and Working Conditions Code, 2020; and the Code on Social Security, 2020 as and when notified and brought into force by the Government of India.**

**For all provisions of the Labour Codes that are pending operationalisation through rules, schemes or notifications, the corresponding provisions of the pre-existing labour enactments (such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972, etc. and relevant State Rules) shall continue to remain applicable.**

**The Seller/ Service Providers shall, therefore, be responsible for ensuring compliance under:**

- All notified and enforceable provisions of the new Labour Codes as mentioned hereinabove; and
- All operative provisions of the erstwhile Labour Laws until their complete substitution.

**All obligations relating to wages, social security, safety, working conditions, industrial relations etc. and any other statutory requirements shall be strictly met by the Seller/ Service Provider. Any non-compliance shall constitute a breach of the contract and shall entitle the Buyer to take appropriate action in accordance with the contract and applicable law.**

**This Bid is governed by the General Terms and Conditions, conditions stipulated in Bid and Service Level Agreement specific to the Service, as the case may be, as provided in the Marketplace.**

**However, in case of Service, if any condition specified in General Terms and Conditions is contradicted by the conditions stipulated in Service Level Agreement specific to said Service, then it will over-ride the conditions in the General Terms and Conditions.**

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

**---धन्यवाद/Thank You---**