

REVISIONS

REV#	DWN BY	DESCRIPTION	DATE
A	MNK	ISSUED FOR APPROVAL	Mar 1 2025

SK#06
07 pages
Date: 05-08-2025

OVERSIZE HOLES ARE ACCEPTABLE FOR GRAVITY COLUMN BASE PLATES

OVERSIZE HOLES WITH WELDED PLATE WASHERS ARE ACCEPTABLE FOR LATERAL COLUMN BASE PLATE

TYP 3/16



Snap#01 from Model

Q2

Please confirm the clouded weld for plate washer to base plate.



BP-1

ADHESIVE ANCHOR SETTING TYPE- 1

(REF: A/S304)

7 LOCATIONS



BP-2

ADHESIVE ANCHOR SETTING TYPE- 2

(REF: B/S304)

2 LOCATIONS



BP-5

ADHESIVE ANCHOR SETTING TYPE- 3

(REF: D/S304)

12-LOCATIONS

ERECTOR NOTE:
COLUMNS ORIENDATION REFER PLAN.

Q3

Per the green clouded note,
We will follow PL1/4"x2"x0-2" plate washer for 3/4"Ø hilti HAS-E-55 epoxy anchor at ALL columns in this project.
Please confirm.

OK STRUCTURALLY

APPROVER,
ALL SCREW ANCHOR LOCATIONS,
WE HAVE FOLLOWED 1" THICK
NON SHRINK GROUT.

APPROVER,
WE HAVE FOLLOWED 1/4" THK.
LEVELING PLATE FOR THIS PROJECT.
PLEASE CONFIRM.

REVISIONS

REV#	DWN BY	DESCRIPTION	DATE
A	MNK	ISSUED FOR APPROVAL	Mar 1 2025

THE INFORMATION NOTED HEREON THIS DRAWING IS THE PROPERTY OF STEEL FAB ENTERPRISES, INC. AND SHALL NOT BE USED WITHOUT WRITTEN CONSENT.

STEEL FAB ENTERPRISES, LLC
AISC CERTIFIED FABRICATOR AND ERECTOR
MISCELLANEOUS METALS FABRICATOR AND ERECTORS
623 BAUMGARDNER ROAD, LANCASTER, PA 17603
TEL. (717)464-0330 FAX (717)464-9464
WWW.STEELFABENTERPRISES.COM

PROJECT OWNER : 1250 MARYLAND AVENUE
PROJECT DESCRIPTION : 1250 MARYLAND AVENUE
PROJECT ADDRESS : 1250 MARYLAND AVENUE SW WASHINGTON,DC 20024
CONTRACTOR : BALFOUR BEATTY

DRAWN BY : JSV	DATE : 02-27-2025	PROJ. NO. : 25001	REV # A
CHECKED BY : MNK	DATE : 02-27-2025	DWG NO. : 02AB02	

DWG DESCRIPTION : ADHESIVE ANCHOR SETTING TYPES

OVERSIZE HOLES ARE ACCEPTABLE FOR GRAVITY COLUMN BASE PLATES

OVERSIZE HOLES WITH WELDED PLATE WASHERS ~~ARE ACCEPTABLE FOR LATERAL~~ COLUMN BASE PLATE

Q4

Please review & confirm if the 7/8Ø holes in the base plate for 3/4Ø KH-EZ screw anchors w/PL.1/4x2x0-2 plate washer are OK to proceed?



BP-1

ADHESIVE ANCHOR SETTING TYPE- 1

(REF: A/S304)

7 LOCATIONS



BP-2

ADHESIVE ANCHOR SETTING TYPE- 2

(REF: B/S304)

2 LOCATIONS



BP-5

ADHESIVE ANCHOR SETTING TYPE- 3

(REF: D/S304)

12-LOCATIONS

ERECTOR NOTE:
COLUMNS ORIENDATION REFER PLAN.

OK STRUCTURALLY

APPROVER, ALL SCREW ANCHOR LOCATIONS, WE HAVE FOLLOWED 1" THICK NON SHRINK GROUT.

APPROVER, WE HAVE FOLLOWED 1/4" THK. LEVELING PLATE FOR THIS PROJECT. PLEASE CONFIRM.

REVISIONS

REV#	DWN BY	DESCRIPTION	DATE
A	MNK	ISSUED FOR APPROVAL	Mar 1 2025

THE INFORMATION NOTED HEREON THIS DRAWING IS THE PROPERTY OF STEEL FAB ENTERPRISES, INC. AND SHALL NOTED BE USED WITHOUT WRITTEN CONSENT.

STEEL FAB ENTERPRISES, LLC
AISC CERTIFIED FABRICATOR AND ERECTOR
MISCELLANEOUS METALS FABRICATOR AND ERECTORS
623 BAUMGARDNER ROAD, LANCASTER, PA 17603
TEL. (717)464-0330 FAX (717)464-9464
WWW.STEELFABENTERPRISES.COM

PROJECT OWNER : 1250 MARYLAND AVENUE
PROJECT DESCRIPTION : 1250 MARYLAND AVENUE
PROJECT ADDRESS : 1250 MARYLAND AVENUE SW WASHINGTON,DC 20024
CONTRACTOR : BALFOUR BEATTY

DRAWN BY : JSV	DATE : 02-27-2025	PROJ. NO. : 25001	REV # A
CHECKED BY : MNK	DATE : 02-27-2025	DWG NO. : 02AB02	

DWG DESCRIPTION : ADHESIVE ANCHOR SETTING TYPES



Q5

During approval,we were pick the wrong point for the magenta clouded dimensions. Please confirm the clouded 7-0 & 2-2 dimensions between grids C'9(stright grid) and grid 'D.4'(straight grid) at grid '26" intersection.



KEY PLAN

PARTIAL LEVEL-08 NEW STEEL COLUMN ADHESIVE ANCHOR PLAN-(PHASE-6) (SEQ#6)

1 / 07AB01

(REF: 1/S133_C & 1/S133_D)

SLAB ELEVATION IS AN EXISTING CONDITION THAT SHOULD BE VERIFIED IN FIELD.

NOTES:

1. TOP OF EXSITING SLAB ELEVATION AT LEVEL-08: 125'1" (V.I.F).
2. ALL COLUMN BOTTOM OF BASE PL. ELEVATION [128'-2 1/4"] (U.N.O).
3. ALL GRID DIMENSIONS TO BE VERIFY IN FIELD (U.N.O).
4. REFER SHEET 07AB02 & 07AB03 FOR ADHESIVE ANCHOR SETTING TYPES OF PHASE-06.
5. ALL NEW STEEL COLUMN LOCATIONS ARE CENTER OF EXISTING CONCRETE COLUMN (U.N.O).
6. ALL DIMENSIONS ARE LOCATE FROM GRID TO CENTER OF NEW & EXIST. CONCRETE COLUMN CENTER (U.N.O).
7. ALL ELEVATION SHOWN IN PLAN FOR BOTTOM OF BASE PLATE (U.N.O).
8. ALL SKEWED GRIDS AND CURVED GRIDS LOCATION ARE SHOWN FROM CENTER LINE OF MD AVE CIRCLE WORK POINT.

PROJECT NORTH & TRUE NORTH

LEGEND

THE INFORMATION NOTED HEREON THIS DRAWING IS THE PROPERTY OF STEEL FAB ENTERPRISES, INC. AND SHALL NOT BE USED WITHOUT WRITTEN CONSENT.

STEEL FAB ENTERPRISES, LLC
MISCELLANEOUS METALS FABRICATOR AND ERECTORS
623 BAUMGARDNER ROAD, LANCASTER, PA 17603
TEL. (717)464-0330 FAX (717)464-9464
WWW.STEELFABENTERPRISES.COM

AISC CERTIFIED FABRICATOR AND ERECTOR

REVISIONS

		DESCRIPTION	DATE
A	MKK	ISSUED FOR APPROVAL	Mar 1 2025

PROJECT OWNER : 1250 MARYLAND AVENUE			
PROJECT DESCRIPTION : 1250 MARYLAND AVENUE			
PROJECT ADDRESS : 1250 MARYLAND AVENUE SW WASHINGTON,DC 20024			
CONTRACTOR : BALFOUR BEATTY			
DRAWN BY : JSV	DATE : 02-27-2025	PROJ. NO. : 25001	REV # A
CHECKED BY : KMA	DATE : 02-27-2025	DWG NO. : 07AB01	
DWG DESCRIPTION : PARTIAL LEVEL-08 NEW STEEL COLUMN ADHESIVE ANCHOR PLAN-(PHASE-6)(SEQ#7)			

NOT SURE WHAT THIS IS MEASURING

CONFIRMED EXCEPT AS NOTED ON PLAN

APPROVER,
PLEASE REVIEW AND CONFIRM
ALL CLOUDED DIMENSION & ANGLE
FOR THE SKEWED GRID INTERSECTION
POINT ARE OK TO PROCEED?

ARCH. PLEASE CONFIRM

APPROVER,
PLEASE VERIFY AND CONFIRM, WE HAVE ASSUMED THAT THE
CLOUDED,COLUMN LOCATION DERECTLY SEATED
ON THE IN EXISTING CONCRETE SLAB, SINCE
LATEST SURVEY DRAWING DOES NOT SHOWN
EXISTING CONCRETE COLUMN FOR THIS LOCATION.





Snap from architectural drawing 1/A002 (Grid plan)

1
09AB01

PARTIA
ADHESI

NOTES:
1. TOP OF EXS
2. ALL COLUM
3. ALL GRID DI
4. REFER SHE
5. ALL NEW ST
6. ALL DIMENS
CONCRETE
7.ALL ELEVATI
8. ALL SKEWE
SHOWN FR

APPROVER,
PLEASE REVIEW AND VERIFY
ALL EXISTING COLUMN SIZES
ARE OK TO PROCEED?

RESPONSIBILITY OF CONTRACTOR AND GC TO VERIFY ALL EXISTING CONDITIONS, REVIEWED TO CONFIRM WITH DESIGN DRAWINGS ONLY

COLUMN SIZES
ED WITH EXISTING
RAL DRAWINGS.
FIELD FOR
OLUMN SIZE

Q6

Please confirm the green clouded dimension between grid "AA" and Scenic easement line.





THE INFORMATION NOTED HEREON THIS DRAWING IS THE PROPERTY OF STEEL FAB ENTERPRISES, INC. AND SHALL NOT BE USED WITHOUT WRITTEN CONSENT.

STEEL FAB ENTERPRISES, LLC
MISCELLANEOUS METALS FABRICATOR AND ERECTORS
623 BAUMGARDNER ROAD, LANCASTER, PA 17603
TEL. (717)464-0330 FAX (717)464-9464
WWW.STEELFABENTERPRISES.COM

AISC CERTIFIED FABRICATOR AND ERECTOR

REVISIONS

REV#	DWN BY	DESCRIPTION	DATE
A	MNK	ISSUED FOR APPROVAL	Mar 1 2025

PROJECT OWNER : 1250 MARYLAND AVENUE			
PROJECT DESCRIPTION : 1250 MARYLAND AVENUE			
PROJECT ADDRESS : 1250 MARYLAND AVENUE SW WASHINGTON,DC 20024			
CONTRACTOR : BALFOUR BEATTY			
DRAWN BY : JSV	DATE : 02-27-2025	PROJ. NO. : 25001	REV # A
CHECKED BY : KMA	DATE : 02-27-2025	DWG NO. : 09AB01	
DWG DESCRIPTION : PARTIAL LEVEL-08 NEW STEEL COLUMN ADHESIVE ANCHOR PLAN-(PHASE-8)(SEQ#9)			

BILL OF MATERIAL

ASSEMBLY MARK	TOTAL QTY	SUB-PIECE MARK	UNIT QTY	MATERIAL DESCRIPTION	LENGTH FT	LENGTH IN	REMARKS	UNIT WEIGHT	TOTAL WEIGHT
02M1000	26			ANGLE			UNP	21	555
	26	02M1000	1	L5x3x1/2	1	8	A36	21	555



26 ANGLES 02M1000

Q7

Please review the clouded note and confirm.

APPROVER,
PLEASE CONFIRM PAINT & PREPARATION.

ALL RE-ENTRANT CUT TO BE 1/2" RADIUSED (U.N.O)
WELDS : E70XX
HOLES : 13/16" DIA (U.N.O)
MAT'L : A36 (U.N.O)
CLEAN : SSPC-SP3
PAINT : NO PAINT

REVISIONS

REV#	DWN BY	DESCRIPTION	DATE
A	MNK	ISSUED FOR APPROVAL	Mar 1 2025

FOR SHOP USE :

	INITIAL	HOURS	DATE
CUT			
VISUAL			
DATE			

QUALITY CONTROL CHECK

	DIMENSIONAL
	VISUAL
	DATE

THE INFORMATION NOTED HEREON THIS DRAWING IS THE PROPERTY OF STEEL FAB ENTERPRISES, INC. AND SHALL NOTED BE USED WITHOUT WRITTEN CONSENT.

STEEL FAB ENTERPRISES, LLC
AISC CERTIFIED FABRICATOR AND ERECTOR
MISCELLANEOUS METALS FABRICATOR AND ERECTORS
623 BAUMGARDNER ROAD, LANCASTER, PA 17603
TEL. (717)464-0330 FAX (717)464-9464
WWW.STEELFABENTERPRISES.COM

PROJECT OWNER : 1250 MARYLAND AVENUE
PROJECT DESCRIPTION : 1250 MARYLAND AVENUE
PROJECT ADDRESS : 1250 MARYLAND AVENUE SW, WASHINGTON, DC 20024
CONTRACTOR : BALFOUR BEATTY

DRAWN BY : MNK	DATE : 02-27-2025	PROJ. NO. : 25001	REV # A
CHECKED BY : KMA	DATE : 02-27-2025	DWG NO. : 02M1000	

DWG DESCRIPTION : ANGLE DETAIL

BILL OF MATERIAL

ASSEMBLY MARK	TOTAL QTY	SUB-PIECE MARK	UNIT QTY	MATERIAL DESCRIPTION	LENGTH FT	LENGTH IN	REMARKS	UNIT WEIGHT	TOTAL WEIGHT
04M1001	2			ANGLE			UNP	35	70
	2	04M1001	1	L5x3x1/2	1	10	A36	23	47
	2	pl1207	1	PL1/2x3 3/4	1	10	A36	12	23



Q8

Please review the clouded welds and confirm.

FOR SHOP USE :	INITIAL	HOURS	DATE
CUT			
VISUAL			
DATE			
DATE			

QUALITY CONTROL CHECK

	DIMENSIONAL
	VISUAL
	DATE

THE INFORMATION NOTED HEREON THIS DRAWING IS THE PROPERTY OF STEEL FAB ENTERPRISES, INC. AND SHALL NOTED BE USED WITHOUT WRITTEN CONSENT.

STEEL FAB ENTERPRISES, LLC
AISC CERTIFIED FABRICATOR AND ERECTOR
MISCELLANEOUS METALS FABRICATOR AND ERECTORS
623 BAUMGARDNER ROAD, LANCASTER, PA 17603
TEL. (717)464-0330 FAX (717)464-9464
WWW.STEELFABENTERPRISES.COM

PROJECT OWNER : 1250 MARYLAND AVENUE
PROJECT DESCRIPTION : 1250 MARYLAND AVENUE
PROJECT ADDRESS : 1250 MARYLAND AVENUE SW, WASHINGTON, DC 20024
CONTRACTOR : BALFOUR BEATTY

DRAWN BY : MNK	DATE : 02-27-2025	PROJ. NO. : 25001	REV # A
CHECKED BY : KMA	DATE : 02-27-2025	DWG NO. : 04M1001	

DWG DESCRIPTION : ANGLE DETAIL

ALL RE-ENTRANT CUT TO BE 1/2" RADIUSED (U.N.O)
WELDS : E70XX
HOLES : 13/16" DIA (U.N.O)
MAT'L : A36 (U.N.O)
CLEAN : SSPC-SP3
PAINT : NO PAINT

REVISIONS

REV#	DWN BY	DESCRIPTION	DATE
A	MNK	ISSUED FOR APPROVAL	Mar 1 2025