

Environment Agency Response

Consultee response · dated 2026-06-17

1. No objection on flood risk grounds provided the development is carried out in accordance with the Flood Risk Assessment. The site lies in Flood Zone 2 with a small area of Zone 3a along the canal edge. Residential accommodation must be raised above the 1 in 100 year plus climate change level (32.10m AOD).

2. Groundwater: the site overlies a Secondary A aquifer. Piling must be risk assessed to avoid contaminant migration.