

Lead Local Flood Authority Response

Consultee response · dated 2026-06-10

1. No objection subject to a detailed drainage condition. The site is currently 96% impermeable. The proposal must limit discharge to 5 l/s/ha for the 1 in 100 year plus 40% climate change event, requiring approximately 410 cubic metres of attenuation.
2. Green roofs on Blocks A and B are welcomed and may be counted towards attenuation.