

Environment Agency: Tidal Flood Risk

Consultee response · dated 2026-06-11

- 1.** The site lies in Flood Zone 3a (tidal) and benefits from the Bristol Frome defences to a 1 in 200 standard. Residential use at ground floor level is not acceptable; sleeping accommodation must be at first floor or above. A flood warning and evacuation plan is required. The Sequential Test must be passed.
- 2.** Ground floor should be limited to commercial or parking uses, which lowers the achievable number of apartments.