

Historic England: Pre-Application Advice

Consultee response · dated 2026-06-02

1. Historic England supports re-use of the warehouses. It advises that the scheme minimises intervention to the primary structure and recommends a structural strategy that retains the timber floor plates as an exposed feature.
2. It recommends analysis of the cast iron column loading before any additional floors or plant are proposed.