

Thames Water: Network Capacity

Consultee response · dated 2026-08-05

1. Foul water: the existing network has insufficient capacity for 150 dwellings. Network reinforcement is required and Thames Water will need up to 18 months from a firm order to deliver it. A Grampian condition is likely.
2. Water supply: capacity available subject to a 200mm main extension at the developer's cost.