

RESOLUTION NO. 2015- _____

Entitled: "A RESOLUTION AUTHORIZING THE SUBMITTAL OF AN APPLICATION TO THE WYOMING STATE LOAN AND INVESTMENT BOARD FOR A LOAN FROM THE WYOMING CLEAN WATER STATE REVOLVING FUND FOR AN AMOUNT NOT TO EXCEED \$9.9 MILLION FOR CONSTRUCTION COSTS FOR THE PHASE ONE SOUTHERN SEWER INTERCEPTOR MAIN PROJECT AND AUTHORIZING THE MAYOR, THE CITY CLERK AND THE DIRECTOR OF THE BOARD OF PUBLIC UTILITIES TO EXECUTE THE APPLICATION AND ALL RELATED LOAN DOCUMENTS."

WHEREAS, Wyoming Statute 15-7-401 provides for a Board of Public Utilities (BOARD) to manage, operate, maintain and control a municipal waterworks, a sanitary sewer system and sewage disposal plants; and

WHEREAS, Cheyenne City Code, Section 2.68.010, established such a BOARD to have exclusive authority to manage, operate, maintain and control the Municipal Waterworks, Sanitary Sewer System and Sewage Disposal Plants of the City and to make all rules and regulations necessary for the safe, economical and efficient operation and maintenance of the above facilities; and

WHEREAS, the 2003 and 2013 Water and Wastewater Master Plans recommend development of the Phase One Southern Sewer Interceptor Main to collect and transport sewage collected from the southern portion of Cheyenne and deliver the sewage flows to the Crow Creek Water Reclamation Facility to increase flows into the treatment plant to increase the supply necessary for the expansion of the recycle water treatment works; and

WHEREAS, the Governing Body of the City of Cheyenne (CITY) and the BOARD recognize the 2003 and 2013 Water and Wastewater Master Plans as essential planning tools and the necessity for the Phase One Southern Sewer Interceptor Main Project (PROJECT); and

WHEREAS, the PROJECT includes, but is not limited to, the construction and installation of, and materials for, approximately 4.25 miles of sanitary sewer mains with diameters of 10 inch to 24 inch, with manholes, diversion structures, sewage lift stations, back-up power, easements and all other necessary appurtenances to make the PROJECT functional; and

WHEREAS, the construction costs associated with the PROJECT are estimated to be \$9.9 million; and

WHEREAS, the CITY and the BOARD are committed to repaying the loan from revenues collected from charges for wastewater services with the adoption of:

City Ordinance No. 3975 on June 10, 2013 and BOPU Resolution No. 2013-04 on May 1, 2013; and

City Ordinance No. 4025 on June 9, 2014 and BOPU Resolution No. 2014-05 on May 5, 2014; and

City Ordinance No. 4073 on June 8, 2015 and BOPU Resolution No. 2015-04 on May 4, 2015; and

WHEREAS, the CITY and the BOARD recognize that the annual principal and interest payment on the proposed loan will be about \$635,056.57, assuming a loan term of 20 years at a 2.5% interest rate; and

WHEREAS, the CITY and the BOARD recognize that the Project is essential to maintain adequate wastewater treatment services and for expanding the recycle water for the community of Cheyenne.

NOW, THEREFORE, BE IT RESOLVED THAT THE GOVERNING BODY OF THE CITY OF CHEYENNE, does hereby approve:

1) The submittal of an application to the Wyoming State Loan and Investment Board for a loan from the Wyoming Clean Water State Revolving Fund for an amount not to exceed \$9,900,000 for PROJECT construction and related costs of the Phase One Southern Sewer Interceptor Main Project for the City of Cheyenne; and

2) That the Mayor, the City Clerk and the Director of the Board of Public Utilities are hereby designated as the authorized representatives of the City of Cheyenne to act on behalf of the City of Cheyenne in all matters related to this application and related documents and are authorized to execute the application and all related loan documents including, but not limited to, the loan agreement, the assignment and pledge of revenues, the promissory note and any amendments to those documents.

ADOPTED THIS _____ day of _____ 2015.

CITY OF CHEYENNE:

Richard L. Kaysen, Mayor

(SEAL)
Attest:

Carol Intlekofer, City Clerk

City of Cheyenne Board of Public Utilities Southern Sewer Interceptor Main - Phase I Project				
Alignment C (Red)				
ENGINEER'S PRELIMINARY OPINION OF PROBABLE CONSTRUCTION COST				
Description	Unit	Quantity	Unit Cost	Total Cost
DIVISION 1				
General Requirements				
Mobilization, Bonds, and Insurance ⁽¹⁾	LS	1	\$317,030.00	\$317,030.00
Traffic Control ⁽²⁾	LS	1	\$63,410.00	\$63,410.00
Conformance with NPDES Permit (SWPP) ⁽³⁾	LS	1	\$190,220.00	\$190,220.00
Subtotal Division 1	-	-	-	\$570,660.00
DIVISION 2				
Trenching and Backfilling for Utilities				
Trench Stabilization Material ⁽⁴⁾	TON	990	\$35.00	\$34,650.00
CLSM Cutoff Wall ⁽⁵⁾	EA	57	\$650.00	\$37,050.00
Dewatering	LS	1	\$2,500.00	\$2,500.00
Sanitary Sewer Installations				
24-inch Sanitary Sewer	LF	15,200	\$155.00	\$2,356,000.00
12-inch Sanitary Sewer	LF	2,200	\$110.00	\$242,000.00
10-inch Force Main	LF	2,490	\$80.00	\$199,200.00
18-inch Force Main	LF	2,490	\$120.00	\$298,800.00
5.0-foot diameter Manhole	EA	42	\$7,000.00	\$294,000.00
Marker Post	EA	47	\$235.00	\$11,045.00
4.0-foot diameter Manhole	EA	5	\$5,500.00	\$27,500.00
Connection to Existing System ⁽⁶⁾	EA	1	\$20,000.00	\$20,000.00
Utility Casings				
40-inch Bored Steel Casing ⁽⁷⁾	LF	780	\$900.00	\$702,000.00
Lift Station				
Lift Station	EA	1	\$2,000,000.00	\$2,000,000.00
Diversion Structures				
Diversion Structures ⁽⁸⁾	EA	2	\$45,000.00	\$90,000.00
Surface Restoration				
Roadway Removal and Replacement ⁽⁹⁾	SF	500	\$6.00	\$3,000.00
Seeding and Restoration ⁽¹⁰⁾	AC	22.83	\$1,000.00	\$22,830.00
Subtotal Division 2	-	-	-	\$6,340,575.00
Subtotal				\$6,911,240.00
Contractor Overhead and Profit (10%)				\$691,120.00
Subtotal				\$7,602,360.00
Contingency (30%)				\$2,280,710.00
Total Construction Cost				\$9,883,100.00

Notes:

- (1) Mobilization has been estimated at 5% of the Division 2 Subtotal.
- (2) Traffic Control has been estimated at 1% of the Division 2 Subtotal for Avenue C, Murray Rd, and Livingston Drive
- (3) Conformance with NPDES Permit is estimated at 3% of the Division 2 Subtotal.
- (4) Trench stabilization material is based upon providing 6-inch of rock for half of the sewer alignment.
- (5) Cutoff walls are estimated at a 350 foot spacing. Actual locations or spacing will require geotechnical information.
- (6) Existing connection to sewer along Livingston Drive.
- (7) Bored crossings are expected at Suncor dual gas lines, E College Drive, S College Drive, Allison Draw, and Crow Creek
- (8) Includes Diversion Structure over SCWSD sanitary sewer. Inclusive of two manual gates, flow meter, electrical, and I-C
- (9) Includes asphalt pavement removal and replacement at Avenue C, Artesian Road, and Livingston Drive
- (10) Seeding and Restoration is based on a 50 foot wide disturbed area work zone when not under pavement or casing pipe.

