
Presentation of the 5-bus test system

Thierry Van Cutsem


thierry.h.van.cutsem@gmail.com https://thierryvancutsem.github.io/home/

December 2024

System overview



Thévenin equivalent



$$X_{th} = \frac{1}{\frac{S_{sc}}{S_{base}}} = \frac{100}{6000} = 0.0167 \text{ pu}$$

 S_{sc} : short-circuit power¹

 $S_{\it base}$: base power of network = 100 MVA

$$E_{th} \angle \theta_{th} = \bar{V} + j X_{th} \bar{I}$$

$$\iff E_{th} \cos \theta_{th} + j E_{th} \sin \theta_{th} = (v_x + j v_y) + j X_{th} (i_x + j i_y)$$

Algebraic-only model:


$$E_{th}\cos\theta_{th} - v_x + X_{th}i_y = 0$$

$$E_{th}\sin\theta_{th} - v_y - X_{th}i_x = 0$$

 $^{^{1}}$ more precisely: contribution of Thévenin equivalent to short-circuit power at bus $1\,$


Synchronous machine

Round-rotor machine typical of thermal power plants



f: field (or excitation) winding d_1 : direct-axis damper winding q_1, q_2 : quadrature-axis damper windings

After applying Park transformation:



3-phase stator replaced by d, q windings. Inductance matrices:


$$\mathbf{L}_{d} = \left[egin{array}{cccc} L_{\ell} + M_{d} & M_{d} & M_{d} & M_{d} \\ M_{d} & L_{\ell f} + M_{d} & M_{d} & M_{d} \\ M_{d} & M_{d} & L_{\ell d1} + M_{d} \end{array}
ight]$$
 $\mathbf{L}_{q} = \left[egin{array}{cccc} L_{\ell} + M_{q} & M_{q} & M_{q} \\ M_{q} & L_{\ell q_{1}} + M_{q} & M_{q} \\ M_{q} & M_{q} & L_{\ell q2} + M_{q} \end{array}
ight]$

- independent of rotor position
- d and q axes decoupled
- in per unit, using the proper base 4/1

Magnetic saturation of material

Open-circuit characteristic:

- machine operating at no load, rotating at nominal angular speed
- \bullet terminal voltage E_q measured for various values of the field current i_f




$$\begin{array}{l} \text{Saturation factor}: \ k = \frac{OA}{OB} = \frac{O'A'}{O'A} < 1 \\ \text{A standard model}: \ k = \frac{1}{1+m(E_q)^n} \qquad m,n>0 \end{array}$$

Electrical part of model in (d,q) reference frame with phasor approximation

- M_d^u (resp. M_a^u) non-saturated value of M_d (resp. M_q)
- ψ_{ad} (resp. ψ_{aq}): air-gap flux in d (resp. q) axis
- all variables in per unit, except time t
- $\omega_N = 2\pi f_N$ f_N : nominal frequency

Connecting the model to the (x, y) reference frame



 δ : "rotor angle"

Motion equation

$$\frac{1}{\omega_{\it N}}\frac{d}{dt}\delta = \omega - \frac{\omega_{\it ref}}{\omega_{\it N}} \qquad \omega : \mbox{ rotor speed in per unit}$$

$$2H\frac{d}{dt}\omega = T_m - T_e = T_m - (\psi_d i_q - \psi_q i_d)$$

 T_m : mechanic torque given by turbine

 T_e : electromagnetic torque opposed by machine

$$H = \frac{\frac{1}{2}I\left(\frac{\omega_N}{p}\right)^2}{S_M}$$
 inertia constant (in s)


I: moment of inertia of *all* rotating masses p: number of pair of poles S_N : nominal apparent power of machine (in MVA)

Data

$$S_N=500$$
 MVA $U_N=15$ kV stator (or armature): resistance $R_a=0$. leakage react. $X_\ell=0.15$ pu synchronous reactance*: d-axis $X_d=2.20$ pu transient reactance*: d-axis $X_d'=0.30$ pu q-axis $X_q'=0.40$ pu subtransient reactance*: d-axis $X_d'=0.20$ pu q-axis $X_q'=0.40$ pu q-axis $X_q'=0.20$ pu open-circuit transient time constant*: d-axis $T_{do}'=7.00$ s q-axis $T_{qo}'=1.50$ s open-circuit subtransient time constant*: d-axis $T_{do}'=0.05$ s q-axis $T_{qo}'=0.05$ s saturation $m=0.10$ $n=6.0257$ inertia: $H=4$ s

^{*}used at initialization to obtain $L_{\ell f}, L_{\ell d1}, M_d^u, R_f, R_{d1}, L_{\ell q1}, L_{\ell q2}, M_q^u, R_{q1}, R_{q2}$

Speed governor and steam turbine




Turbine nominal power $P_{nom} = 460$ MW. All variables in pu on the P_{nom} base.

$$\sigma = 0.04 \quad T_{mes} = 0.1 \; s \quad T_{sm} = 0.4 \; s$$

$$\dot{z}_{min} = -0.05 \; pu/s \quad \dot{z}_{max} = 0.05 \; pu/s \quad z_{min} = 0. \quad z_{max} = 1. \; pu$$

$$T_{hp} = 0.3 \; s \quad f_{hp} = 0.4 \quad T_r = 5.0 \; s \quad f_{mp} = 0.3 \quad T_{lp} = 0.3 \; s \quad ivo = 1$$

Automatic voltage regulator, excitation system and overexcitation limiter



All variables on the base (voltage and current) of the excitation system.


$$G = 70. \quad T_a = T_b = 1 \text{ s} \quad T_e = 0.4 \text{ s} \quad v_f^{min} = 0. \quad v_f^{max} = 5 \text{ pu}$$

$$K_{pss} = 50 \quad T_w = 5 \text{ s} \quad T_1 = T_3 = 0.323 \text{ s} \quad T_2 = T_4 = 0.0138 \text{ s} \quad C = 0.06 \text{ pu}$$


$$i_{f\,1}^{lim} = 2.90 \text{ pu} \quad i_{f\,2}^{lim} = 1.00 \text{ pu} \quad T_{oel} = 12 \text{ s} \quad K_{oel} = 2.0$$

$$L_1 = -1.1 \quad L_2 = 0.1 \quad L_3 = 0.2 \text{ pu}$$

Load



Induction motor model:



Constant admittance load: $P = GV^2 = P_o(V/V_o)^2$ $Q = -BV^2 = Q_o(V/V_o)^2$

MS: equivalent motor representing a population of "small motors" *:


$$R_s = 0.031$$
 $L_{ss} = 3.30$ $L_{sr} = 3.20$ $L_{rr} = 3.38$ $R_r = 0.018$ pu $H = 0.7$ s $A = 0.5$ $B = 0.5$


ML: equivalent motor representing a population of "large motors" *:

$$R_s = 0.013$$
 $L_{ss} = 3.867$ $L_{sr} = 3.80$ $L_{rr} = 3.97$ $R_r = 0.009$ pu $H = 1.5$ s $A = 0.5$ $B = 0.5$

^{*}values in pu on the motor MVA base

Load Tap Changer (LTC)





Range of variation of ratio r:

• minimum: 0.81

maximum: 1.10

• number of tap positions: 30

Voltage control logic:

if $V_2 < V_2^o - \epsilon$ decrease r by one position if $V_2 > V_2^o + \epsilon$ increase r by one position else leave r unchanged


$$V_2^o=1.00$$
 pu $\epsilon=0.01$ pu

Delays:


before first tap change: 25 s

between successive tap changes: 10 s

Operating point # 1



Operating point # 2



Operating point # 3

