

WATER QUALITY DATA OF DRAINS, STP_s & WTP_s MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
4369	COLLING WATER BLOW DOWNS FROM ANDHRA SUGARS LTD., KOVVUR, BEFORE JOINING RIVER GODAVARI	DRAIN	ANDHRA PRADESH	25	32	5.8	7.2	6.8	7.9	249	482	1.2	2.6	0.3	2.1	3	14	21	150		
3052	GUNTATHIPPA DRAIN B/C WITH RIVES CANAL AT RAMAVARAPPADU, VIJAYAWADA TOWN	DRAIN	ANDHRA PRADESH	22	25	0.3	1.8	6.9	7.9	1548	2280	17.8	37.0	5.5	8.8	440	470	2300	5200	21	240
2355	TEKI DRAIN AT TALLAREVU, TALLAREVU (V & M), BEFORE JOINING CORINGA WILDLIFE SANCTUARY	DRAIN	ANDHRA PRADESH	24	26	3.4	6.4	6.7	7.8	488	19470	2.8	5.8	1.1	3.2	7	15	120	460		
3053	TULIA BAGH DRAIN AT MATLAPALEM (V), VEMULAVADA (M)	DRAIN	ANDHRA PRADESH	24	26	4.9	6.9	6.7	7.6	525	24500	2.4	3.6	0.8	3.3	3	20	75	460	4	4
20004	STP AT RAJAHMUNDRY	STP	ANDHRA PRADESH			6.4	7.2	6.5	7.6	574	1573	10.0	14.0	3.0	9.4	9	21	150	460		
2047	N-CHOE (ATTAWA CHOE), CHANDIGARH(EXIT POINT)	DRAIN	CHANDIGARH	15	29	0.3	8.8	7.1	7.8	150	793	3.0	118.0	0.9	4.3	330	260000	1100	940000		
2048	PATIALA KI RAO, CHANDIGARH(EXIT POINT)	DRAIN	CHANDIGARH	14	30	0.3	2.8	7.5	7.9	756	900	35.0	254.0	1.5	3.2	70000	7000000	170000	70000000		
2049	SUKHNA CHOE, CHANDIGARH(EXIT POINT)	DRAIN	CHANDIGARH	14	32	0.3	0.3	7.0	7.9	784	1254	35.0	262.0	0.9	2.9	110000	1700000	220000	11000000		
5268	ABU FAZAL DRAIN	DRAIN	DELHI					7.1	7.6			40.0	54.0								

WATER QUALITY DATA OF DRAINS, STP₅ & WTP₅ MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
1505	BARAPULA DRAIN, DELHI	DRAIN	DELHI					7.2	7.9			37.0	76.0								
1501	BURARI DRAIN B/C WITH NAZAFGARH DRAIN, DELHI	DRAIN	DELHI					7.2	7.8			39.0	48.0								
1502	CIVIL MILL DRAIN, DELHI	DRAIN	DELHI					7.0	7.3			40.0	52.0								
5267	DRAIN NO. 14	DRAIN	DELHI					7.5	7.5			21.0	21.0								
5263	ISBT + MORI GATE DRAIN	DRAIN	DELHI					7.2	7.8			36.0	50.0								
5269	JAITPUR DRAIN	DRAIN	DELHI					7.1	7.9			35.0	54.0								
5266	KAILASH NAGAR DRAIN	DRAIN	DELHI					7.0	7.6			30.0	58.0								
5261	KHYBER PASS DRAIN	DRAIN	DELHI					7.4	7.4			30.0	30.0								
5259	MAGZINE ROAD DRAIN	DRAIN	DELHI					7.3	7.3			38.0	38.0								
1857	MAHARANI BAGH DRAIN, DELHI	DRAIN	DELHI					7.0	7.7			42.0	50.0								
5262	METCALF HOUSE DRAIN	DRAIN	DELHI					7.1	7.2			20.0	28.0								
5275	MOLARBANDH DRAIN	DRAIN	DELHI					6.8	7.7			27.0	48.0								
1377	NAJAFGARH DRAIN AT WAZIRABAD BEFORE CONF. TO RIV.YAMUNA, DELHI	DRAIN	DELHI					7.1	7.5			42.0	60.0								
5271	OLD AGRA CANAL AT OKHLA	DRAIN	DELHI					7.2	7.3			43.0	45.0								
5273	OLD AGRA CANAL NEAR KALINDI KUNJ - SARITA VIHAR PULL	DRAIN	DELHI					7.0	7.6			33.0	48.0								
1503	POWER HOUSE DRAIN, DELHI	DRAIN	DELHI					6.5	7.6			36.0	58.0								
1858	SARITA VIHAR, DELHI	DRAIN	DELHI					7.4	7.7			26.0	32.0								

WATER QUALITY DATA OF DRAINS, STP₅ & WTP₅ MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
1504	SEN NURSING HOME DRAIN, DELHI	DRAIN	DELHI					7.1	7.4			40.0	56.0								
1506	SHAHDARA DRAIN, DELHI	DRAIN	DELHI					7.0	7.9			49.0	60.0								
5265	SHASTRI PARK DRAIN	DRAIN	DELHI					6.8	7.5			27.0	40.0								
5276	SONIA VIHAR DRAIN	DRAIN	DELHI					6.9	7.6			36.0	63.0								
5260	SWEEPER COLONY DRAIN	DRAIN	DELHI					7.3	7.6			40.0	40.0								
5264	TONGA STAND DRAIN	DRAIN	DELHI					7.2	7.2			25.0	25.0								
5270	TUGHLAKABAD DRAIN	DRAIN	DELHI					7.0	7.8			32.0	64.0								
3041	WATER WORKS- WAZIRABAD, DELHI	WATER TREATMENT PLANT (RAW WATER)	DELHI			7.1	7.1	6.9	7.5			6.5	6.5	0.3	0.7	5500	5500				
3042	WATER WORKS- SONIA VIHAR, DELHI	WATER TREATMENT PLANT (RAW WATER)	DELHI					7.1	7.5					0.3	0.3						
3043	WATER WORKS- CHANDRAVAL, DELHI	WATER TREATMENT PLANT (RAW WATER)	DELHI					6.9	7.5					0.3	0.7						
3044	WATER WORKS- NANGLOI, DELHI	WATER TREATMENT PLANT (RAW WATER)	DELHI					7.1	7.6					0.3	0.4						

WATER QUALITY DATA OF DRAINS, STP_s & WTP_s MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
3045	WATER WORKS-HAIDERPUR, DELHI	WATER TREATMENT PLANT (RAW WATER)	DELHI					7.1	7.8					0.3	0.6						
3046	WATER WORKS-DWARKA, DELHI	WATER TREATMENT PLANT (RAW WATER)	DELHI					7.1	7.7					0.3	0.6						
20013	PANAJI STP AT TONCA	STP	GOA	29	29			7.0	7.9			5.6	40.0			2	2400	2	5400	2	350
20015	AHMEDABAD-1 BENRAMPURAPIRANA ROAD, AHMEDABAD	STP	GUJARAT	27	30			7.5	7.9			6.0	25.0			1600	1600	1600	1600		
20016	AHMEDABAD-2 NAROL SARKHEJ HIGHWAYNR. 35 MLD STP, NAROL-SARKHEJ HIGHWAY, VASNA AHMEDABAD	STP	GUJARAT	27	30			6.8	7.8			8.0	34.0			1600	1600	1600	1600		
4860	RANIA DRAIN MEETING DISCHARGE OF PHED STP, 6 MLD, RANIA, SIRSA	DRAIN	HARYANA			5.6	5.9	7.6	8.2	830	984	8.0	11.0			1500	7200	4200	13000	1100	2800
4861	NEAR HUDA/ HSVP WATER WORKS, BASAI, GURUGRAM	WATER TREATMENT PLANT (RAW WATER)	HARYANA	22	30	7.0	7.7	7.0	7.8	1010	1210	1.0	1.0	0.3	0.3	80	160	1900	2900	2	2

WATER QUALITY DATA OF DRAINS, STP₅ & WTP₅ MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
3047	WATER WORKS- GURGAON	WATER TREATMENT PLANT (RAW WATER)	HARYANA	26	32	7.0	7.3	7.2	8.0	1120	1640	1.0	1.0	0.3	0.3	110	310	2700	5100	2	2
3048	WATER WORKS- FARIDABAD	WATER TREATMENT PLANT (RAW WATER)	HARYANA	31	31	6.8	6.8	7.2	7.2	1560	1560	1.0	1.0								
4464	ALHI KHAD NEAR INTAKE WSS AT VILL. NOG	DRAIN	HIMACHAL PRADESH	12	29	8.2	9.3	6.9	8.2	286	470	1.0	1.0	0.3	2.6	22	84	130	540	2	2
3868	BARAGRAM NALLAH BEFORE CONFLUENCE TO RIVER BEAS	DRAIN	HIMACHAL PRADESH	1	13	7.5	8.9	6.8	8.0	50	106	1.0	1.0	0.3	0.7	21	58	58	280	2	2
3881	BHATIAN NALLAH D/S SARA TEXTILE, NALAGARH	DRAIN	HIMACHAL PRADESH	12	28	3.9	6.1	7.6	8.0	678	5130	1.0	20.0	1.2	10.9	2	1600	26	1600	2	11
3879	BHATIAN NALLAH U/S BHATIAN VILLAGE, NEAR TVS INDUSTRY, NALAGARH	DRAIN	HIMACHAL PRADESH	11	26	0.3	6.2	7.1	8.1	670	7530	1.2	90.0	0.6	7.2	7	1600	130	1600	2	1600
4425	RAW WATER FOR LWSS OF CHURAT NALLAH	DRAIN	HIMACHAL PRADESH	8	15	7.8	9.2	7.5	8.3	102	231	1.0	1.0	0.3	4.0	7	70	26	1600	2	70
4463	DHANESHAH NALLAH (U/S SAINJ WATER SUPPLY SCHEME) NEAR GYASI MATA MANDIR	DRAIN	HIMACHAL PRADESH	9	19	7.1	8.2	7.9	8.4	114	766	1.0	1.0	0.3	2.2	9	39	20	1600	2	2
4474	HALOG NALLAH NEAR HALOG WATER SUPPLY SCHEME	DRAIN	HIMACHAL PRADESH	8	13	9.4	9.6	7.6	8.3	97	347	1.0	1.0	0.4	1.4	2	170	7	1600	2	2

WATER QUALITY DATA OF DRAINS, STP₅ & WTP₅ MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
4481	HATHLI NALLAH LIFT WATER SUPPLY SCHEME FOR MUNICIPAL COUNCIL HAMIRPUR	DRAIN	HIMACHAL PRADESH	19	28	7.6	8.5	6.6	7.9	278	680	1.0	2.3	0.3	8.5	2	6	21	47	2	2
5253	HURLA NALLA D/S HURLA BRIDGE, VPO HURLA, TEHSIL BHUNTER, DIS. KULLU	DRAIN	HIMACHAL PRADESH	5	18	7.3	8.3	7.1	8.5	60	155	1.0	1.0	0.3	0.7	31	94	140	540	2	2
4426	RAW WATER FOR LWSS OF JAGROTI NALLAH	DRAIN	HIMACHAL PRADESH	8	14	7.6	9.3	7.6	8.3	92	156	1.0	1.0	0.3	1.0	2	130	2	1600	2	50
4454	JARANGLA NALLAH U/S WATER SUPPLY SCHEME	DRAIN	HIMACHAL PRADESH	8	15	8.8	9.4	7.5	8.3	110	485	1.0	1.0	0.4	5.3	2	20	23	3500	2	2
4466	JARANGLA NALLAH D/S WATER SUPPLY SCHEME	DRAIN	HIMACHAL PRADESH	8	15	8.8	9.4	7.5	8.4	112	524	1.0	1.0	0.4	4.2	2	20	33	3500	2	2
5257	KALAM NALLA D/S OF MSW PROCESSING SITE AT CHOWRI, DIST. CHAMBA	DRAIN	HIMACHAL PRADESH	10	16	8.5	9.1	7.0	8.1	125	282	1.0	1.0	0.5	2.0	2	22	47	1600	2	2
4477	KHALADA NALLAH NEAR WATER SUPPLY SCHEME FOR KULLU TOWN	DRAIN	HIMACHAL PRADESH	2	18	7.8	8.8	7.2	8.0	67	230	1.0	1.0	0.3	2.9	32	110	140	920	2	2
4455	KLUIN NALLAH U/S WATER SUPPLY SCHEME	DRAIN	HIMACHAL PRADESH	8	13	9.0	9.5	7.0	8.2	77	496	1.0	1.0	0.3	1.7	2	40	94	3500	2	2
4482	LIFT WATER SUPPLY SCHEME (PANJARAR) AND BHOTA ROPARI & UJHAN	DRAIN	HIMACHAL PRADESH	19	28	7.5	8.5	6.5	8.1	312	689	1.0	2.1	0.3	1.6	2	4	17	70	2	2
4036	KUNNI PUL, VILL SAMAHU, PO KUNI HAR, TEHSIL ARKI	DRAIN	HIMACHAL PRADESH	10	15	7.4	7.8	7.9	8.4	231	3640	1.0	1.8	1.2	5.3	2	12	21	350	2	2

WATER QUALITY DATA OF DRAINS, STP₅ & WTP₅ MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
4430	LIFT NALLAH BEFORE CONFLUENCE TO ASHWANI KHAD NEAR DOGRHA BRIDGE	DRAIN	HIMACHAL PRADESH	9	23	6.4	8.1	5.9	8.3	83	828	1.5	12.0	0.3	6.9	17	350	540	1600	7	140
4475	MACHADA NALLAH, MAJHOUTI WATER SUPPLY SCHEME NEAR NIRATH	DRAIN	HIMACHAL PRADESH	8	13	9.3	9.7	7.5	8.3	116	359	1.0	1.0	0.3	2.3	7	170	21	1600	2	2
4476	MANALSU NALLAH NEAR WATER SUPPLY SCHEME FOR MANALI TOWN	DRAIN	HIMACHAL PRADESH	3	12	8.0	9.2	6.6	8.5	33	76	1.0	1.0	0.3	0.7	26	140	84	540	2	2
3863	RAMPUR JATTAN MOGINAND NALA BEFORE CONFLUENCE TO RIVER MARKANDA NEAR RADHA SWAMI SATSANG BHAWAN	DRAIN	HIMACHAL PRADESH			5.0	6.0	7.2	8.3	763	1819	2.7	5.5	0.6	2.1	140	2400	540	9200	2	2
3865	ROON NALLAH NEAR MEERPUR KOTLA, GURUDWARA	DRAIN	HIMACHAL PRADESH			7.2	8.8	7.7	8.2	330	662	1.1	2.9	0.6	0.9	26	220	170	540	2	2
4034	SAHU NALLAH U/S BHURI SINGH SHEP	DRAIN	HIMACHAL PRADESH	8	15	8.8	9.7	7.6	8.2	130	286	1.0	1.0	0.5	3.1	2	68	94	5400	2	2
4035	SAHU NALLAH D/S BHURI SINGH SHEP	DRAIN	HIMACHAL PRADESH	8	14	8.5	9.7	7.5	8.2	129	292	1.0	1.0	0.6	2.6	2	93	63	9200	2	2
4462	SAINJ NALLAH (U/S SAINJ WATER SUPPLY SCHEME AT DARGI)	DRAIN	HIMACHAL PRADESH	9	19	7.0	8.2	7.6	8.4	104	682	1.0	1.0	0.3	2.6	5	34	26	1600	2	2
3861	SALANI NALLAH NEAR BRIDGE, NH-7, MOGINAND KALA AMB	DRAIN	HIMACHAL PRADESH			7.2	8.7	7.4	8.4	328	758	1.4	2.8	0.5	0.9	49	280	220	920	2	2
3867	SARVARI NALLAH BEFORE CONFLUENCE TO RIVER BEAS	DRAIN	HIMACHAL PRADESH	3	18	7.6	8.5	7.2	7.9	110	218	1.0	1.0	0.3	1.6	22	150	79	540	2	2

WATER QUALITY DATA OF DRAINS, STP_s & WTP_s MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
1870	SUKHANA NALLAH AT PARWANOO NEAR KALKA BARRIER, EXIT POINT OF H. P.	DRAIN	HIMACHAL PRADESH	8	11	4.3	8.7	7.4	8.3	253	1284	1.0	26.0	0.5	15.7	2	1600	21	1600	2	12
3875	SURAJMUKHI NALLAH U/S WSS GALAYANA D/S OF SHOOLINI UNIVERSITY	DRAIN	HIMACHAL PRADESH	7	9	7.2	8.8	7.7	8.3	223	853	1.0	7.5	2.8	10.4	2	33	24	540	2	2
4480	SURAJMUKHI NALLAH D/S STP AT U/S OF SHOOLINI UNIVERSITY SAMTI SOLAN	DRAIN	HIMACHAL PRADESH	6	8	6.8	8.5	7.7	8.3	221	824	1.0	2.6	1.9	8.8	2	24	26	350	2	2
4029	TAALO NALA (FROM NAHAR TOWN) AT KHADDAR KA BAGH B/C TO RIVER MARKANDA	DRAIN	HIMACHAL PRADESH			7.0	8.7	7.2	8.3	290	774	1.4	3.0	0.7	0.9	46	220	280	540	2	2
4082	BAJU NALLAH AT KHOKHYAL NEAR BARAGE, CONFLUENCE POINT OF SAHAR-KHAD AND KATHUA CITY NALLAHS	DRAIN	JAMMU & KASHMIR	12	26	5.2	6.5	7.6	8.5	94	240	2.0	2.1								
5172	NELLIKUNNU BRIDGE AT NELLIKUNNU, KASARAGOD	DRAIN	KERALA			2.0	7.6	6.5	7.8			1.0	2.8			34	350				
20017	STP NEAR PAMBA AT PATHANAMTHITTA KERALA	STP	KERALA					7.5	8.9			20.0	30.0								
2789	NALA AT D/S OF AKLAI MANDIR, VILLAGE- AKLAI, TALUKA- MALSHIRAS, DISTRICT- SOLAPUR.	DRAIN	MAHARASHTRA	26	36	4.4	5.2	7.2	8.1	1245	1750	7.2	13.0	0.3	2.4	20	150	150	900	7	35

WATER QUALITY DATA OF DRAINS, STP₅ & WTP₅ MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
2785	BPT, NAVAPUR, VILLAGE- NAVAPUR, TALUKA- PALGHAR, DISTRICT- PALGHAR.	DRAIN	MAHARASHTRA	26	26	0.3	4.2	6.4	8.1	3758	28540	9.0	180.0	1.6	27.7	2	130	26	920		
2178	CHIKHALI NALA MEETS GODAVARI RIVER, VILLAGE- CHIKHALI, TALUKA- NASHIK, DISTRICT- NASHIK.	DRAIN	MAHARASHTRA	20	29	0.3	6.0	7.4	8.0	762	1066	3.0	18.0	0.7	4.9	4	170	45	180	2	2
2783	COLOUR CHEM NALA, VILLAGE- MAJIWADA, TALUKA- THANE, DISTRICT- THANE.	DRAIN	MAHARASHTRA	26	32	0.3	5.2	7.0	7.8	519	10830	1.0	75.0	0.4	6.5	170	92000	920	160000		
2790	PIMPAL-PANERI NALA AT RATNAGIRI NEAR FINOLEX INDUSTRIES, VILLAGE- YAHGANIGAON, TALUKA- RATNAGIRI, DISTRICT- RATNAGIRI.	DRAIN	MAHARASHTRA	26	31	7.0	7.9	6.0	7.2	245	5476	1.8	3.0	0.3	1.7	6	11	21	43	2	2
2782	RABODI NALA, VILLAGE- RABODI, TALUKA- THANE, DISTRICT- THANE.	DRAIN	MAHARASHTRA	20	29	0.3	4.4	7.0	7.9	328	5507	1.0	115.0	0.4	4.9	130	3500	540	92000		
2784	SANDOZ NALA, VILLAGE- SANDOZBAUG, TALUKA- THANE, DISTRICT- THANE.	DRAIN	MAHARASHTRA	20	30	0.3	4.4	7.1	7.8	553	7738	1.0	160.0	0.4	3.7	170	16000	540	16000		

WATER QUALITY DATA OF DRAINS, STP_s & WTP_s MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
2786	TARAPUR MIDC NALA (NEAR SUMP 1), VILLAGE- MIDC TARAPUR, TALUKA- PALGHAR, DISTRICT- PALGHAR.	DRAIN	MAHARASHTRA	26	26	1.5	4.5	7.2	7.5	1569	3557	8.0	36.0	1.3	14.1	2	130	22	540		
2787	TARAPUR MIDC NALA (NEAR SUMP 2), VILLAGE- MIDC TARAPUR, TALUKA- PALGHAR, DISTRICT- PALGHAR.	DRAIN	MAHARASHTRA	26	26	0.3	4.4	6.6	7.8	1326	5574	7.0	145.0	1.1	2.7	2	130	33	540		
2788	TARAPUR MIDC NALA (NEAR SUMP 3), VILLAGE- MIDC TARAPUR, TALUKA- PALGHAR, DISTRICT- PALGHAR.	DRAIN	MAHARASHTRA	26	26	0.3	4.5	7.2	7.8	1416	3728	7.0	84.0	2.0	6.5	13	220	70	920		
3934	GANDA NALLAH AT MARTHAPUR	DRAIN	ODISHA	20	23	4.3	8.6	7.1	8.0	146	890	1.3	2.1	0.3	20.2	13	1300	49	3500		
3923	GURADIH NALLAH AT PANPOSH	DRAIN	ODISHA	23	31	1.2	6.8	6.9	7.7	328	717	4.3	8.0	0.3	9.7	3300	54000	7900	160000	13	350
3939	KUNDRA NALLAH AT JODA	DRAIN	ODISHA	19	31	6.1	7.3	6.7	7.9	118	175	1.1	1.8	0.3	2.7	210	1700	1100	4900		
20019	STP, PURI AT MANGALAGHAT	STP	ODISHA					7.5	7.9			4.5	27.0			45	160000	130	160000		
20020	WASTEWATER OF TALCHER	STP	ODISHA					6.8	7.5			23.0	80.0			160000	160000	160000	160000		
2914	POINT SOURCE BUDHA NALLAH, PUNJAB	DRAIN	PUNJAB	11	29	0.3	0.3	7.2	7.6	1169	1941	70.0	180.0	3.2	14.0	940000	4100000	2800000	16000000		
2906	DHANAULA DRAIN FALLING INTO LASSARA DRAIN NEAR VILL. DHUNAS, PUNJAB	DRAIN	PUNJAB	10	38	0.3	1.4	7.6	8.0	4641	5551	119.0	163.0	3.8	7.9	84000	170000	280000	430000		

WATER QUALITY DATA OF DRAINS, STP_s & WTP_s MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
2907	HUDIARA DRAIN AT VILL. DHAHUKE (WHERE IT ENTERS PAKISTAN), PUNJAB	DRAIN	PUNJAB	11	29	0.3	0.3	7.1	8.1	995	1628	32.0	160.0	2.7	6.2	23000	230000	84000	630000		
2908	OUTLET OF NADIALA DRAIN INTO DHAKANSU NALLAH, PUNJAB	DRAIN	PUNJAB	9	36	0.3	1.5	6.6	7.9	1225	2691	23.0	76.0	1.4	6.3	7800	120000	94000	420000		
2909	TALLEWAL DRAIN AT BRIDGE JALWALAN - LOHGARH LINK ROAD	DRAIN	PUNJAB	11	40	0.3	1.5	7.3	8.0	1712	2893	51.0	92.0	1.9	4.8	21000	120000	110000	350000		
2910	BRIDGE ON TUNG DHAB DRAIN, FATENGARH CHURIAN ROAD, AMRITSAR	DRAIN	PUNJAB	10	29	0.3	0.3	7.1	8.3	1370	3191	82.0	247.0	3.2	6.8	40000	460000	170000	840000		
4158	SAGARPARA DRAIN AT VILL SAGRA DIST, PATIALA	DRAIN	PUNJAB	9	36	0.3	2.8	7.3	8.2	983	4261	19.0	38.0	0.9	3.9	3200	17000	24000	70000		
20021	JALANDHAR	STP	PUNJAB					7.1	7.6			14.0	38.0			790	2100				
20022	LUDHIANA-1, BHATTIAN	STP	PUNJAB					7.1	8.0			6.0	22.0			120	2100				
20023	LUDHIANA-2, BALLOKE	STP	PUNJAB					7.1	7.7			5.0	12.0			92	700				
20024	LUDHIANA-3, JAMALPUR	STP	PUNJAB					7.0	7.6			6.0	11.0			130	4000	390	17000		
20025	PHAGWARA	STP	PUNJAB					6.8	7.9			13.0	28.0			210	14000				
20026	PHILLAUR	STP	PUNJAB					7.3	12.0			6.0	23.0			2	1700				
20027	KAPURTHALA	STP	PUNJAB					7.0	7.5			18.0	38.0			630	1400				
20028	SULTANPUR LODHI	STP	PUNJAB					7.1	7.8			18.0	36.0			840	63000				
10047	CHENNAI WATERWAYS AT OTTERI NULLAH (ORIGIN)	DRAIN	TAMIL NADU	29	32	0.3	1.0	6.2	7.2	1328	2980	18.0	430.0	0.3	14.7	130	400	1400	2800		

WATER QUALITY DATA OF DRAINS, STP_s & WTP_s MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
10048	CHENNAI WATERWAYS AT OTTERI NULLAH (KILPAUK GARDEN)	DRAIN	TAMIL NADU	28	33	0.3	1.2	6.6	7.2	1293	2350	14.0	69.0	0.3	12.0	120	790	940	3500		
10051	CHENNAI WATERWAYS AT BUCKINGHAM CANAL X OTTERI NULLAH CONFLUENCE (GMR VASAVI INDUSTRIES)	DRAIN	TAMIL NADU	26	33	0.3	1.4	6.7	7.3	1141	2240	15.0	28.0	0.3	16.0	37	410	580	2800		
10056	CHENNAI WATERWAYS AT MAMBALAM DRAIN (GOLF COURSE)	DRAIN	TAMIL NADU	28	32	0.3	1.0	6.6	6.8	951	1895	20.6	216.0	0.3	8.0	68	1400	700	1700		
20032	CHENNAI-1 NESAPAKKAM (ZONE-IV)	STP	TAMIL NADU	27	31			7.7	10.2			2.0	8.0			2	61	120	460		
20033	CHENNAI-2 PERUNGADI(ZONE-V)	STP	TAMIL NADU	28	33			7.0	7.3			2.0	5.0			2	45	92	580		
20034	CHENNAI-3KODUNGAIYUR (ZONE I&II)	STP	TAMIL NADU	29	33			7.0	7.4			6.0	16.0			2	40	140	460		
20035	CHENNAI-4 KOYAMBEDU (ZONE-III)	STP	TAMIL NADU	27	32			6.7	7.5			4.0	8.0			2	55	93	330		
20038	ERODE-2	STP	TAMIL NADU	29	36	0.3	2.9	7.7	7.9	1021	1266	10.0	15.0	0.3	0.9	21	1400	39	2100		
20041	KARUR	STP	TAMIL NADU	30	34	0.3	0.9	7.3	8.2	1647	2200	26.0	105.0	0.3	2.5	18	17000	37	92000		
20042	MAYILADUTHURAI	STP	TAMIL NADU	26	35	0.3	5.8	7.3	8.5	1091	1386	12.0	54.0	0.3	4.5	14	2600	17	9400		
20043	TIRCHIRAPPALLI-SRIRANGAM	STP	TAMIL NADU	23	30	0.3	0.3	7.5	8.7	1072	1379	23.0	124.0	0.3	11.4	240	3900	1100	17000		
20044	THANJAVUR	STP	TAMIL NADU	25	30	0.3	0.3	7.3	7.8	1046	1336	6.0	58.0	0.3	1.2	2200	21000	7000	70000		
20045	TIRUNELVELI	STP	TAMIL NADU	27	28	0.3	0.3	7.0	7.5	1016	1194	13.0	32.0			480	830	940	1700		
20046	MADURAI	STP	TAMIL NADU	25	39	0.3	6.0	6.7	7.9	1357	1563	4.0	18.0	0.3	1.0	2	11000	2	22000	2	2

WATER QUALITY DATA OF DRAINS, STP_s & WTP_s MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
20047	KUMBAKONAM	STP	TAMIL NADU	26	32	0.3	0.3	7.4	7.9	1289	1482	6.0	86.0	0.3	1.3	1700	26000	3400	94000		
3054	RIVER GODAVARI - OUTLET OF ASH POND EFFLUENTS OF M/S.NTPC, RAMAGUNDAM	DRAIN	TELANGANA	25	29	1.6	6.0	8.5	11.2	599	1043	1.0	5.4	0.9	3.8	2	17	17	280	2	2
4665	RIVER MANERU (TRIBUTARY OF GODAVARI) - OUTLET OF KTPP ASH POND JOINING TO MORANCH VAGU, CHELPUR (V), GHANPUR (MULUGU) (M), , JAYASHANKAR BHUPALAPALLI DISTRICT	DRAIN	TELANGANA	25	28	2.8	6.1	7.5	8.8	522	856	1.8	3.2	0.4	17.0	2	2	26	58	2	2
3055	AMBERPET STP (339 MLD) - OUTLET , AMBERPET (V&M), HYDERABAD	STP	TELANGANA	25	31	0.9	4.6	6.9	8.2	1322	1659	4.4	30.0	4.2	8.0	4	46	220	920	2	6
3056	LANGARHOUSE STP (1.25 MLD) - OUTLET, GOLCONDA (V&M) ,HYDERABAD	STP	TELANGANA	25	32	2.1	5.3	7.0	8.4	1277	2074	8.0	36.0			2	17	280	1600		
3057	NAGOLE STP (172 MLD)- OUTLET, NAGOLE,RANGAREDDY	STP	TELANGANA	26	30	2.4	5.6	7.0	8.1	821	1327	11.0	33.0			2	32	2	920	2	2
3058	KHAIRATABAD STP (20 MLD) - OUTLET, NEAR RAJ NAGAR, KHARITABAD , HYDERABAD	STP	TELANGANA	26	28	3.8	4.8	7.0	7.9	958	1253	6.0	22.0			2	12	84	540		

WATER QUALITY DATA OF DRAINS, STP_s & WTP_s MONITORED UNDER NWMP- 2023

STN Code	Monitoring Location	Type Water Body	State Name	Temperature (°C)		Dissolved Oxygen (mg/L)		pH		Conductivity (µmho/cm)		BOD (mg/L)		NitrateN (mg/L)		Fecal Coliform (MPN/100ml)		Total Coliform (MPN/100ml)		Fecal Streptococci (MPN/100ml)	
				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
3059	SAFILGUDA STP (0.6 MLD) - OUTLET, SAFILGUDA,MEDCHAL	STP	TELANGANA	26	30	3.8	5.2	7.1	7.5	1153	2032	6.0	21.0			20	25	210	920		
3060	DURGAM STP (5 MLD) - OUTLET, RAIDURG (V), SERILINGAMPALLY (M), RANGAREDDY (D)	STP	TELANGANA	26	29	2.9	4.1	7.0	7.4	1173	1670	15.0	29.0			2	32	150	1600		
3061	NALLACHERUVU STP (30 MLD) - OUTLET, UPPAL, RANGAREDDY	STP	TELANGANA	26	28	3.5	4.5	7.2	8.0	1419	1715	10.0	29.0			2	39	2	540	2	2
3062	SAROORNAGAR STP (2.5 MLD) - OUTLET, SAROORNAGAR (V & M), RANGAREDDY DISTRICT	STP	TELANGANA	25	30	3.1	4.3	7.0	8.2	1317	1590	8.0	42.0			4	17	49	920		
3050	WATER WORKS- GHAZIABAD	WATER TREATMENT PLANT (RAW WATER)	UTTAR PRADESH	18	26	0.3	11.0	7.1	7.5	160	201	1.0	1.0	0.3	0.3	2	2	2	2	2	2