

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM "

Periode Ke : *Nov - Des 2022*

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
1	Selasa, 15-11-2022	A-1	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
2	Selasa, 15-11-2022	A-2	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
3	Selasa, 15-11-2022	A-3	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗	✓	✓	
4	Selasa, 15-11-2022	A-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
5	Selasa, 15-11-2022	A-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
6		A-6	OVERHAUL MOD TANK													
7		A-7														
8	Senin, 19-12--2022	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
9		A-16	MOD TANK													
10	Senin, 19-12--2022	A-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
11	Senin, 19-12--2022	A-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
12		A-19	TANK CLEANING													
13	Senin, 19-12--2022	A-20	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	FWL Bug
14	Senin, 19-12--2022	A-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
15	Senin, 19-12--2022	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
16	Senin, 19-12--2022	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
17	Kamis, 17-11-2022	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	
18		A-25	TANK CLEANING													
19	Kamis, 17-11-2022	A-26	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗	✓	✓	
20	Kamis, 17-11-2022	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
21	Kamis, 17-11-2022	A-28	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
22		A-29	MOD TANK													
23	Selasa, 22-11-2022	A-30	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
24	Selasa, 22-11-2022	A-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
25	Selasa, 22-11-2022	A-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
26	Selasa, 22-11-2022	A-33	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	FWL No Support
27	Jumat, 18-11-2022	E-1	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	FWL bug
28	Jumat, 18-11-2022	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
29	Jumat, 18-11-2022	E-3	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	FWL Error
30		E-4	TANK CLEANING													
31	Jumat, 18-11-2022	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
32	Jumat, 18-11-2022	E-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
33	Jumat, 18-11-2022	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
34		T-901	TANK CLEANING													


No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
35	Senin, 12-12-2022	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
36	Senin, 12-12-2022	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
37	Senin, 12-12-2022	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
38	Senin, 12-12-2022	T-201	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
39	Senin, 12-12-2022	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
40	Senin, 12-12-2022	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
41		V-1	MOD TANK													
42		V-2	MOD TANK													
43	Kamis, 24-11-2022	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	Intermitten
44	Kamis, 24-11-2022	D20-05B	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	✓	✓	Intermitten
45	Kamis, 24-11-2022	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	Intermitten
46	Kamis, 24-11-2022	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	Intermitten
47		D20-06A	MOD TANK													
48	Kamis, 24-11-2022	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	Intermitten
49	Kamis, 24-11-2022	D20-07A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	Intermitten
50	Kamis, 24-11-2022	D20-07B	✓	✓	✓	✗	✓	✓	✓	✓	✗	✗	✗	✓	✓	Intermitten, RDU Rusak
51	Kamis, 24-11-2022	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	Intermitten
52		D20-04A	TANK CLEANING													
53	Kamis, 24-11-2022	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
54	Kamis, 24-11-2022	D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
55	Kamis, 24-11-2022	D20-01A	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✗	✓	✓	
56		D20-01B	OVERHALL													
57	Kamis, 24-11-2022	D20-13A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
58	Kamis, 24-11-2022	D20-13B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
59		D20-15A	MOD TANK													
60	Kamis, 24-11-2022	D20-15B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
61	Selasa, 13-11-2022	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
62		R-2	MOD TANK													
63	Selasa, 13-11-2022	R-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
64	Selasa, 13-11-2022	R-4	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
65	Selasa, 13-11-2022	R-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
66	Selasa, 13-11-2022	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
67	Selasa, 13-11-2022	R-7	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
68	Selasa, 13-11-2022	R-8	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
69	Selasa, 13-11-2022	R-9	✓	✗	✗	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	Menunggu pergantian kabel sinyal
70	Selasa, 13-11-2022	R-10	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
71	Jumat, 25-11-2022	D20-08	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	TankHub tidak support FWL
72	Jumat, 25-11-2022	R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan	
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST		
73	Jumat, 25-11-2022	V-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Intermitten	
74	Jumat, 25-11-2022	V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓		
75	Jumat, 25-11-2022	V-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓		
76	Jumat, 25-11-2022	V-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
77	Jumat, 25-11-2022	V-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
78	Selasa, 06-12-2022	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	RDU Rusak	
79	Selasa, 06-12-2022	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓		
80	Selasa, 06-12-2022	O-1	✓	✓	✓	✗	✓	✓	✓	✓	✗	✗	✗	✓	✓		
81	Selasa, 06-12-2022	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓		
82	Senin, 19-12-2022	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓		
83	Senin, 19-12-2022	O-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
84	Senin, 19-12-2022	O-6	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	✓		
85	Senin, 19-12-2022	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓		
86	Selasa, 29-11-2022	O-9	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓		
87	Selasa, 29-11-2022	O-10	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
88	Selasa, 29-11-2022	O-11	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	MST Rusak	
89	Selasa, 29-11-2022	O-12	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✓	✓	✓		
90	Selasa, 29-11-2022	O-13	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✓	✓	✓		
91	Selasa, 29-11-2022	O-14	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✗	✓	✓		
92	Senin, 12-12-2022	D20-17	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓		
93	Senin, 12-12-2022	D20-18	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
94	Selasa, 06-12-2022	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓		
95	Selasa, 06-12-2022	O-16	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	✓		
96	Selasa, 06-12-2022	O-17	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
97	Selasa, 06-12-2022	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
98	Selasa, 06-12-2022	O-19	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	Menunggu pergantian kabel sinyal	
99	Selasa, 06-12-2022	O-20	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
100	Selasa, 06-12-2022	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
101		O-22	MOD TANK														
102	Selasa, 19-11-2022	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
103	Selasa, 19-11-2022	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
104		O-25	TANK CLEANING														
105		D20-11	MOD TANK														
106	Jumat, 09-12-2022	D20-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
107	Jumat, 09-12-2022	P-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓		
108	Jumat, 09-12-2022	P-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓		
109	Kamis, 08-11-2022	P-1	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓		
110	Kamis, 08-11-2022	P-2	✓	✗	✗	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓		


No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan	
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST		
111		P-3	TANK CLEANING														
112		P-4	MOD TANK														
113	Senin, 19-12-2022	P-5	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓		
114		P-7	MOD TANK														
115	Senin, 19-12-2022	P-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
116	Senin, 19-12-2022	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓		
117	Kamis, 08-12-2022	D-320-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
118	Kamis, 08-12-2022	D-320-02A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
119	Kamis, 08-12-2022	D-320-02B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
120	Kamis, 08-12-2022	C20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
121	Kamis, 08-12-2022	C20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
122																	

NOTE :

PT Control Systems


ROBY

Instrument MA4


M. HOOI T.