

## Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM "

Periode Ke : April 2023

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
1	Senin, 20/03/2023	A-1	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
2	Senin, 20/03/2023	A-2	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
3	Senin, 20/03/2023	A-3	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗	✓	✓	
4	Senin, 20/03/2023	A-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
5	Senin, 20/03/2023	A-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
6		A-6	<b>OVERHAUL</b>													
7	Selasa, 21/03/2023	A-7	✓	✓	✓	✓	✗	✗								WIKI
8	Selasa, 21/03/2023	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
9		A-16	<b>MOD TANK</b>													
10	Rabu, 22/03/2023	A-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
11	Rabu, 22/03/2023	A-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
12		A-19	<b>TANK CLEANING</b>													
13	Rabu, 22/03/2023	A-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
14	Rabu, 22/03/2023	A-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
15	Rabu, 22/03/2023	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
16	Rabu, 22/03/2023	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
17	Rabu, 22/03/2023	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
18	Rabu, 22/03/2023	A-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
19	Rabu, 22/03/2023	A-26	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗	✓	✓	
20	Rabu, 22/03/2023	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
21	Rabu, 22/03/2023	A-28	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
22	Rabu, 22/03/2023	A-29	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
23	Kamis, 23/03/2023	A-30	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
24	Kamis, 23/03/2023	A-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
25	Kamis, 23/03/2023	A-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
26	Kamis, 23/03/2023	A-33	✓	✓		✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	MST tidak support FWL
27	Kamis, 23/03/2023	E-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
28	Kamis, 23/03/2023	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
29	Kamis, 23/03/2023	E-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
30		E-4	<b>TANK CLEANING</b>													
31	Jum'at, 24/03/2023	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
32	Jum'at, 24/03/2023	E-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
33	Jum'at, 24/03/2023	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	



No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan	
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST		
34		T-901	TANK CLEANING														
35	Senin, 20/03/2023	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
36	Senin, 20/03/2023	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
37	Senin, 20/03/2023	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
38	Senin, 20/03/2023	T-201	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓		
39	Senin, 20/03/2023	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓		
40	Senin, 20/03/2023	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓		
41	Senin, 20/03/2023	V-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
42	Senin, 20/03/2023	V-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
43	Selasa, 11/04/2023	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	Intermitten, PT. Pinaras	
44	Selasa, 11/04/2023	D20-05B	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	✓	✓	Intermitten, PT. Pinaras	
45	Selasa, 11/04/2023	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	Intermitten, PT. Pinaras	
46	Selasa, 11/04/2023	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	Intermitten, PT. Pinaras	
47		D20-06A	MOD TANK														
48	Selasa, 11/04/2023	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	Intermitten, PT. Pinaras	
49	Selasa, 11/04/2023	D20-07A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	Intermitten, PT. Pinaras	
50	Selasa, 11/04/2023	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	Intermitten, Kabel RDU Putus	
51	Selasa, 11/04/2023	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	Intermitten, PT. Pinaras	
52		D20-04A	TANK CLEANING														
53	Selasa, 11/04/2023	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
54	Selasa, 11/04/2023	D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
55	Selasa, 11/04/2023	D20-01A	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✗	✓	✓	Power Switch Rusak, Tangki Sibuk	
56	Selasa, 11/04/2023	D20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓		
57	Selasa, 27/03/2023	D20-13A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
58	Selasa, 27/03/2023	D20-13B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓		
59		D20-15A	MOD TANK														
60	Selasa, 27/03/2023	D20-15B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
61	Rabu, 12/04/2023	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓		
62		R-2	MOD TANK														
63	Rabu, 12/04/2023	R-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓		
64	Rabu, 12/04/2023	R-4	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	✓	✓		
65	Rabu, 12/04/2023	R-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
66	Rabu, 12/04/2023	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓		
67	Rabu, 12/04/2023	R-7	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓		
68	Rabu, 12/04/2023	R-8	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
69		R-9	OVERHAUL														
70		R-10	OVERHAUL														



No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
71	Rabu, 12/04/2023	D20-08	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	MST tidak support FWL
72	Jum'at, 14/04/2023	R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
73	Senin, 20/03/2023	V-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
74	Senin, 20/03/2023	V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
75	Senin, 20/03/2023	V-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
76	Senin, 20/03/2023	V-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
77	Senin, 20/03/2023	V-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
78	Selasa, 11/04/2023	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
79	Selasa, 11/04/2023	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
80	Selasa, 11/04/2023	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
81	Selasa, 11/04/2023	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
82	Rabu, 12/04/2023	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
83	Rabu, 12/04/2023	O-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
84	Rabu, 12/04/2023	O-6	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	✓	
85	Rabu, 12/04/2023	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	
86	Kamis, 30/03/2023	O-9	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
87	Kamis, 30/03/2023	O-10	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
88	Kamis, 30/03/2023	O-11	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
89	Kamis, 30/03/2023	O-12	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✓	✓	✓	
90	Kamis, 30/03/2023	O-13	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✓	✓	✓	
91	Kamis, 30/03/2023	O-14	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✗	✓	✓	Power Switch Rusak, menunggu pergantian PT. Pinaras
92	Rabu, 12/04/2023	D20-17	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	MST Rusak, Gak ada Spare
93	Rabu, 12/04/2023	D20-18	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
94	Kamis, 30/03/2023	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
95	Kamis, 30/03/2023	O-16	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	✓	
96	Selasa, 28/03/2023	O-17	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
97	Kamis, 13/04/2023	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
98	Kamis, 13/04/2023	O-19	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	
99	Kamis, 13/04/2023	O-20	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
100	Kamis, 13/04/2023	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
101	Senin, 20/03/2023	O-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	WIKA
102	Senin, 20/03/2023	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
103	Selasa, 04/04/2023	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
104		O-25	OVERHAUL													
105	Rabu, 05/04/2023	D20-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
106	Rabu, 05/04/2023	D20-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
107	Selasa, 04/04/2023	P-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
108	Selasa, 04/04/2023	P-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
109	Selasa, 04/04/2023	P-1	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
110	Selasa, 04/04/2023	P-2	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
111		P-3	<b>TANK CLEANING MOD TANK</b>													
112		P-4														
113	Kamis, 13/04/2023	P-5	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
114	Rabu, 29/03/2023	P-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
115	Rabu, 29/03/2023	P-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
116	Rabu, 29/03/2023	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
117	Kamis, 13/04/2023	D-320-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
118	Kamis, 13/04/2023	D-320-02A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
119	Kamis, 13/04/2023	D-320-02B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
120	Kamis, 13/04/2023	C20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
121	Kamis, 13/04/2023	C20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Intermitten
122																
			0	1	0	0	1	1	2	28	34	43	63	0	0	

**NOTE :**

- a. Pemasangan shroud cable :

PT.Control Systems



Instrument MA4

