

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM "

Periode Ke : September 2023

		Nama Tangki	3	ATG S	iystems		Tank Master Status Powe			er Switch Shroud Cable				Gre	ound		
lo	Hari/Tanggal		Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	Keterangan	
1	Senin, 21 Agustus 2023	A-1	~	1	/	~	V		V	×	√	×	×	V	V		
2	Senin, 21 Agustus 2023	A-2	1	V	V	V	V	V	V	×	1	×	×	V	1		
3	Senin, 21 Agustus 2023	A-3	1	√	V	1	V	1	✓	×	1	1	×	√	1		
1	Senin, 21 Agustus 2023	A-4	V	V	×	✓	V	/	V	x	1	×	×	V	V	Sensor FWL Broken	
5	Senin, 21 Agustus 2023	A-5	V	/	1	~	V	V	1	✓	1	1	x	V	~		
5		A-6						0	VERHA	UL							
7		A-7						M	OD TA	NK							
	Rabu, 23 Agustus 2023	A-15	1	1	1	~	V	/	/	✓	V	1	V	/	V		
		A-16				•		M	OD TA	NK							
0		A-17						0	VERHA	UL							
1	Rabu, 23 Agustus 2023	A-18	1	√	-	1	V	√	√	√	1	/	√	V	1		
2	Selasa, 19 September 2023	A-19	√	V	/	1	×	x	V	✓	V	1	V	✓	V	Menuggu serah terima	
3	Rabu, 23 Agustus 2023	A-20	V	√	V	V	√	V	V	V	V	1	V	V	V		
4	Selasa, 23 Agustus 2023	A-21	V	V	×	1	V	1	V	√	1	V	×	V	1	FWL Error	
5	Selasa, 23 Agustus 2023	A-22	1	√	√	1	√	1	V.	V	1	×	×.	V	V		
6	Selasa, 23 Agustus 2023	A-23	1	1	V	1	V	/	_	V	1	1	×	~	1		
7	Selasa, 23 Agustus 2023	A-24	1	1	V	1	V.	V	V	✓	V	1	V	√	_		
8	Selasa, 23 Agustus 2023	A-25	V	1	V	V	V	V	V	V	1	1	V	V	1		
9	Selasa, 23 Agustus 2023	A-26	1	1	-	1	_	✓	V	×	1	V	×	_	1		
0	Selasa, 23 Agustus 2023	A-27	1	1	V	1	V	V	/	✓	V	1	×	V	1		
1		A-28						0	VERHA	UL							
2	Jum'at, 25 Agustus 2023	A-29	V	_	V	1	V	1			1	1	V	V	V .		
3	Jum'at, 25 Agustus 2023	A-30	1	V	V	V	V	V	V	_	V	/	_	V	1		
4	Jum'at, 25 Agustus 2023	A-31	V	1	V	1	✓	/	-	x	1	×	×	/	1		
5	Jum'at, 25 Agustus 2023	A-32	V	√	V	~	√	V	V	✓	x	1	×	V	V		
6	Jum'at, 25 Agustus 2023	A-33	V	√		V	✓	V	V	1	1	V	×	V	1	Water level sensor not available	
7		E-1						O	VERHA	UL							
8	Senin, 28 Agustus 2023	E-2	V	V	V	√	✓	✓	V	√	1	1	√	V	V		
9	Senin, 28 Agustus 2023	E-3	1	V	×	1	V	V	V	✓	V	1	1	1	V	FWL Error	
0		E-4						TANI	K CLEA	NING							
1	Senin, 28 Agustus 2023	E-5	1	V	V	V	V	1	V	1	1	1	×	V	V		
2	Senin, 28 Agustus 2023	E-6	V	√	V	1	V	1	- N	1	1	1	x	V	V		
3		E-7		1				0	VERHA	UL		1		•			

		TENER!		ATG S	ystems		Tank Mas	ter Status	Powe	r Switch		Shroud Cable		Gro	ound	
No	Hari/Tanggal	Nama Tangki	Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	Keterangan
34		T-901						O	VERHA	UL						
35	Selasa, 29 Agustus 2023	T-902	1	V	V	V	V	V	1	√	1	1	√	✓	V	
36	Selasa, 29 Agustus 2023	T-903	V	1	1	√	√	V	· /	✓	1	1	1	1	V	
37	Selasa, 29 Agustus 2023	T-904	1	√	V	1	V	. 🗸	V	✓	1	V	✓	✓	V	
38		T-201						O	VERHA	UL						
39	Selasa, 29 Agustus 2023	T-202	1	V	1	1	V	✓	/	✓	1	V	×	V	V	
40	Selasa, 29 Agustus 2023	T-203	1	√	V	✓	V	✓	/	1	1	1	x	V	V	
41	Senin, 21 Agustus 2023	V-1	1	V	V	1	V	V	1	V	1	V	✓	V	V	
42	Senin, 21 Agustus 2023	V-2	1	V	V	V	V	V	-	V	√	1	V	V	V	
43	Senin, 21 Agustus 2023	D20-05A	1	V	V	1	/	✓	/	V	1	V	x	V	V	
44	Senin, 21 Agustus 2023	D20-05B	. ✓	V .	V	1	V	1	V	V	1	1	×	√	√	
45	Senin, 21 Agustus 2023	D20-05C	1	V	/	1	V	V	1	√	1	V	×	√	V	
46	Senin, 21 Agustus 2023	D20-05D	1	1	V	V	1	1	✓	√	1	ж	×	1	1	
47		D20-06A						M	OD TA	NK						
48	Senin, 21 Agustus 2023	D20-06B	1	V	V	1	V	1	V	√	1	×	×	V	V	
49	Senin, 21 Agustus 2023	D20-07A	1	√	V	V	V	V	√	✓	1	×	×	V	1	•
50	Senin, 21 Agustus 2023	D20-07B	V	V	V	V	V	V	V	V	V	×	×	√	√	
51	Senin, 21 Agustus 2023	D20-07C	1	V	V	V	V	V	V	V	1	×	×	V	V	
52		D20-04A						TAN	K CLEA	NING						
53	Senin, 28 Agustus 2023	D20-04B	V	V	V	V	V	V	V	✓	1	1	✓	V	1	
54	Senin, 28 Agustus 2023	D20-04C	V	V	√	V	V	√	_	√	1	V	V	V	V	
55	Senin, 28 Agustus 2023	D20-01A	1	V	V	V	1	V	x	_	1	×	×	√	1	
56	Senin, 28 Agustus 2023	D20-01B	V	1	1	V	1	V	V	V	1	×	×	_	V	
57	Senin, 28 Agustus 2023	D20-13A	V	√	✓	1	V	V	V	×	x	×	×	V	_	
58	Senin, 28 Agustus 2023	D20-13B	V	V	V	V	1	√	1	×	×	x	х	1	V	
59		D20-15A						M	OD TA	NK		•				
60	Senin, 28 Agustus 2023	D20-15B	V	1	V	_	-	1	V	×	×	×	×	V	V	
61	Selasa, 12 September 2023	R-1	V	1	V	V	V	V	V	1	1	×	×	√	1	
62		R-2						M	OD TA	NK						
63	Selasa, 12 September 2023	R-3	V	V	V	V	V	V		1	×	×	x	1	V	
64	Selasa, 12 September 2023	R-4	/	V	✓	V	V	V	V	x	1	V	×	√	V	
65	Selasa, 12 September 2023	R-5	_	V	√	V	V	V	V	x	x	×	×	1	V	
66	Selasa, 12 September 2023	R-6	1	V	1	_	/	_	V	V	×	×	x	V	✓	
67	Selasa, 12 September 2023	R-7	1	V	/	/	/	_	1	×	V	×	x	V	√	
68	Selasa, 12 September 2023	R-8	_	-	✓	V	V	V	V	×	×	×	×	√	V	
69		R-9						O	VERHA	UL						
70		R-10							VERHA							

				ATG S	ystems		Tank Mas	ter Status	Powe	r Switch	215	Shroud Cable		Gro	ound	
No	Hari/Tanggal	Nama Tangki	Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	Keterangan
71	Selasa, 12 September 2023	D20-08	V	V		_	V	V	✓	V	1	V	V	√	√	Water level sensor not available
72	Kamis, 14 September 2023	R-11	V	V .	1	_	✓	V	-	V	1	×	×	√	✓	
73		V-3						0	VERHA	UL						
74	9	V-4						0	VERHA	UL						
75	Kamis, 14 September 2023	V-5	V	V	V	V	×	×	/	V	V	V	×	√	V	ATG dimatikan
76	Kamis, 14 September 2023	V-6	√	✓	√	1	/	✓	V	V	V	V	V	√	~	
77	Kamis, 14 September 2023	V-7	V	1	✓	V	✓	1	V	√	1	V	✓	V	V	
78	Rabu, 6 September 2023	N-2	1	✓	V	✓	✓	✓	√	√	1	V	×	V	✓	
79	Rabu, 6 September 2023	N-4	V	V	V	V	✓	1	V	V	V	V	×	1	V	
80	Rabu, 6 September 2023	0-1	√	~	√	V	V	√	V	V	1	×	×	V	V	
81	Rabu, 6 September 2023	0-2	. 🗸	V	V	1	V	√	√	1	1	×	×	√	V	39
82	Kamis, 7 September 2023	0-3	V	✓	V	V	✓	V	V	√	1	×	×	✓	√	
83	Kamis, 7 September 2023	0-4	V	√	✓	V	1	1	V	V	V	×	×	1	V	
84	Kamis, 7 September 2023	0-6	1	V	✓	V	V	1	V	V	V	x	V	~	V	
85	Kamis, 7 September 2023	0-8	√	1	✓	V	✓	✓	√	✓	V	×	✓	√	√	
86	Jum'at, 8 September 2023	0-9	V	V	✓	V	✓	V	V	√	√	V	×	√	✓	
87		O-10	OVERHAUL													
88	Jum'at, 8 September 2023	0-11	√	~	✓	V	✓	V	V	V	V	×	×	√	V	
89	Jum'at, 8 September 2023	0-12	√	~	V	✓	V	√	✓	√	1	V	V	√	✓	
90	Jum'at, 8 September 2023	0-13	V	1	V	V	√	√	√	✓	1	V	✓	√	V	
91	Jum'at, 8 September 2023	0-14	1	V	V	V	√	V	V	✓	√	×	×	1	✓	
92	Rabu, 6 September 2023	D20-17	√	×	√	✓	. 🗸	V	1	V	1	×	×	√	V	MST Rusak, Gak ada Spare
93	Rabu, 6 September 2023	D20-18	~	V	1	V	√	V	V	V	V	×	×	√	V	
94	Senin, 5 September 2023	0-15	V	1	√	V	✓	V	V	✓	1	×	×	✓	V	
95	Senin, 5 September 2023	O-16	V	V	V	V	✓	√	✓	×	V	×	V	√	✓	
96	Senin, 5 September 2023	0-17	√	. 1	√	V	V	V	V	×	V	X	x	V	V	
97	Senin, 21 Agustus 2023	O-18	1	V	√	✓	√	√	1	√	V	V	V	~	V	k.
98	Senin, 21 Agustus 2023	O-19	√	1	√	V	√	1	√	- V	√	×	✓	√	√	
99	Senin, 21 Agustus 2023	0-20	V	1	√	✓	~	√	✓	x	1	×	×	V	✓	
100	Senin, 21 Agustus 2023	0-21	√	V	√	✓	V	V	√	V	✓	√	√	1	V	
101	Senin, 21 Agustus 2023	0-22	√	√	√	V	V	V			V	✓	V	√	✓	
102	Senin, 21 Agustus 2023	0-23	V .	1	√	V	✓	V	√	√	√	- V	√	1	V	
103	Senin, 21 Agustus 2023	0-24	1	√	1	✓	V	1	1	✓	1	✓	1	✓	√	
104		O-25	OVERHAUL													
105	Rabu, 6 September 2023	D20-11	1	/	V	√	V	V	V	/	1	✓	V	√	√	
106	Rabu, 6 September 2023	D20-12	V	V	√	V	√	1	1	√	1	✓	V-	√	√	
107	Rabu, 6 September 2023	P-31	V	1	V	V	✓	1	V	×	V	×	×	1	V	

				ATG S	ystems	網圖	Tank Mass	ter Status	Powe	r Switch		Shroud Cable		Gre	ound	
No	Hari/Tanggal	Nama Tangki	Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	Keterangan
108	Rabu, 6 September 2023	P-32	V	V	✓	V	V	V	1	√	×	×	×	√	✓	
109	Senin, 21 Agustus 2023	P-1	V	V	✓	V	V	V	1	×	V	x	×	V	V	
110	Senin, 21 Agustus 2023	P-2	V	✓	✓	V	1	1	· /	✓	×	×	x	1	√	
111		P-3						0'	VERHA	UL						
112	Senin, 21 Agustus 2023	P-4	1	1	1	1	V	1			V	1	✓	V	✓	
113	Senin, 21 Agustus 2023	P-5	1	V	√	V	V	V	V		×	×	×	V	√	
114	Senin, 21 Agustus 2023	P-7	V	1	✓	V	V	V			V	1	V	V	V	
115	Senin, 21 Agustus 2023	P-8	1	V	V	V	V	V	1	V	V	V	1	V	V	
116	Selasa, 19 September 2023	D20-03	1	V	√	V	x	x	V	_	√	1	_	V	V	Menuggu serah terima
117	Selasa, 12 September 2023	D-320-12	1	1	✓	V	V	1	1	V	V	V	V	_	V	
118	Selasa, 12 September 2023	D-320-02A	. 1	1	✓	✓	√	1	✓	V	V	√	1	_	√	DF
119	Selasa, 12 September 2023	D-320-02B	V	V	V	V	√	1	V	✓	√	V	1	V	V	
120	Selasa, 12 September 2023	C20-01A	1	1	√	V	1	1	V	V	1	V	~	1	✓	
121	Selasa, 12 September 2023	C20-01B	√	V	√	V	V	1	1	_	V	V	V	V	✓	
122																

	ATG S	ystems		Tank Mas	ter Status	Power	r Switch		Shroud Cable	Ground		
Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST
0	1	3	0	3	3	1	18	11	42	58	0	0

NOTE:

Pemakaian shroud kabel di ATG:
D20-78, 3 shroud, Upgrading
D20-11, 3 shroud, Upgrading

*** FWL = Free Water Level RDU = Remote Display Unit

A-19, 3 shroud, MODTANK

MST = Multi Spot Temperature RTG = Radar Tank Gauge PT.Control Systems

Instrument MA4

Page 4