


Monthly Report Pekerjaan TSA Preventive Maintenance Peralatan ATG Area OM, LAWE LAWE, DHP, BPP I dan UTL RU V BALIKPAPAN

Monday, February 19, 2024

ATG PERFOMANCE







LIST ITEM	STATUS
Kurang Power FJB14 dan FJB 17 "Menunggu MCB dan orang listrik"	Hold
Troubleshoot temperatur ATG D20-04C "Menunggu TA, tanki stanby, Perlu ganti card"	Hold
 Jalur kabel P-31, P-32, R-11 Putus by RDMP 	OnProgress
Power FJB11 fix "Tambah MCB"	Fix

KERUSAKAN SPARE PART

LIST ITEM	STATUS
Display GWR U-11 dan U-10 (UTL).	Rusak
 MST D20-17 "Menunggu Overhaul". 	Rusak
Sensor FWL A-4	Rusak



Total Resetting level Monthly



Des Jan Feb Mar Apr Mei Juni Juli Agus Sep Okt Nov Des Jan Feb

Assist re-Calibration ATG

P-5, R-9, D20-13A, D20-18, D20-11, D20-12, P-2, T-201, T-202, T-203, D20-15B, V-5, D20-01A, D20-01B, D20-06B, O3, D20-03, D20 17, D20-13B, V-4

Total Verifikasi : 89
Total On Call : 9
Total Kerusakan SparePart : 2
Total Assist re-Calibration ATG : 20

PT. Control Systems

Mengetahui, PT. Pertamina RU V Balikpapan

Floure 1.