

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM "

Periode Ke : Agustus 202

	Hari/Tanggal	Nama Tangki		ATG S	ystems		Tank Mas	ter Status	Power Switch		Shroud Cable			Gre	ound	Keterangan
No			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	Keterangan
	Senin, 22 Juli 2023	A-1	1	V	V	~	√	_	V	x	1	×	x	~	V	
2	Senin, 22 Juli 2023	A-2	1	√	-	-	V	V	V	×	V	×	×	✓	V	
3	Senin, 22 Juli 2023	A-3	1	V	V	1	V		_	×	V	V	x	V	√	
4	Senin, 22 Juli 2023	A-4	V	V	×	1	V	V .	V.	×	√	×	x	V	V	Sensor FWL Broken
5	Senin, 22 Juli 2023	A-5	1	1	1	~	V	V	_	✓	V	V	x	V	V	
5		A-6						0	VERHA	UL						
,		A-7	-					M	OD TA	NK						
3	Rabu, 24 Juli 2023	A-15	1	V	1	1	V	V	V	✓	V	1	√	V	V	
9		A-16						M	OD TA	NK						
0		A-17						0	VERHA	UL						
1	Rabu, 24 Juli 2023	A-18	1	V	-	V	✓	_	/	V	√	V	√	V	V	
2		A-19						TANI	K CLEA	ANING		100	*			
13	Rabu, 24 Juli 2023	A-20	1	V	1	1	1	V	1	V	√	1	✓	V	1	
4	Selasa, 23 Juli 2023	A-21	V	V	ж	1	√	1	1	1	✓	V	×	✓	V	FWL Error
.5	Selasa, 23 Juli 2023	A-22	V	V	1	V	\	V	V	V	1	×	×	V	V	n e
.6	Selasa, 23 Juli 2023	A-23	1	1	V	V	1	V	V	1	1	1	×	1	V	
7	Selasa, 23 Juli 2023	A-24	V	V	V	V	✓	/	V	V	1	V	✓	1	√	
8	Selasa, 23 Juli 2023	A-25	1	1	_	V	- V	V	~	1	V	V	✓	V	✓	
19	Selasa, 23 Juli 2023	A-26	V	1	V	_	✓	√	V	x	V	1	×	V	√	
0	Selasa, 23 Juli 2023	A-27	_	1	1	V	✓	✓	V	✓	1	V	×	1	V	
1		A-28						0	VERHA	UL		-			30	
2	Jum'at, 26 Juli 2023	A-29	1	1	1	V	V	V			V	1	V	~	√	
23	Jum'at, 26 Juli 2023	A-30	1	1	V	V	V	V	V	V	1	1	V	V	1	
24	Jum'at, 26 Juli 2023	A-31	V	1	1	1	1	√	V	×	1	×	×	V	V	
25	Jum'at, 26 Juli 2023	A-32	1	V	V	V	1	1	V	1	×	1	×	√	1	
26	Jum'at, 26 Juli 2023	A-33	1	V .		1	1	_	1	V	✓	V	x	√	V	Water level sensor not available
27		E-1						O	VERHA	UL						
28	Senin, 29 Juli 2023	E-2	V	1	V	V	1	1	1	√	1	1	V	V	V	
29	Senin, 29 Juli 2023	E-3	V	1	x	V	1	1	V	V	√	V	1	1	V	FWL Error
30		E-4	TANK CLEANING									7/ T				
31	Senin, 29 Juli 2023	E-5	V	V	V	1	V	1	V	V	✓	1	×	1	V	
32	Senin, 29 Juli 2023	E-6	V	1	V	1	V	1	V	V	V	V	×	1	V	
33		E-7						0	VERHA	UL						

-	Hari/Tanggal	Nama Tangki		ATG S	ystems	32110	Tank Master Status		Power Switch			Shroud Cable		Gro	ound	Veterangen
No			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	Keterangan
34		T-901						O	ERHA	UL						
35	Selasa, 30 Juli 2023	T-902	1	V	1	1	V	V	V	√	✓	1	√	√	V	
36	Selasa, 30 Juli 2023	T-903	1	✓	1	1	_	V	✓	✓	✓	~	√	V	V	
37	Selasa, 30 Juli 2023	T-904	1	V	-	1	✓	· 🗸	✓	1	1	1	√	√	√	
38		T-201						0/	ERHA	UL						
39	Selasa, 30 Juli 2023	T-202	1	V	V	V	V	V	V	V	1	V	x	1	√	
40	Selasa, 30 Juli 2023	T-203	1	1	V	1	√	V	_	1	√	V	x	V	V	
41	Senin, 22 Juli 2023	V-1	1	✓	V	V	V	V	. 🗸	✓	1	1	√	√	V	
42	Senin, 22 Juli 2023	V-2	1	V	V	1	V	✓	✓	✓	1	1	√	V	√	
43	Senin, 22 Juli 2023	D20-05A	1	V	V	V	_	V	V	√	√	V	x	√	✓	
44	Senin, 22 Juli 2023	D20-05B	1	√	_	_	_	/	V	V	V	V	x	V	V	
45	Senin, 22 Juli 2023	D20-05C	1	✓	V	1	✓	√	V	V	1	√	×	√	V	
46	Senin, 22 Juli 2023	D20-05D	1	√	✓	1	V	V	V	V	1	×	×	1	V	
47		D20-06A						M	OD TA	NK						
48	Senin, 22 Juli 2023	D20-06B	1	√	V	1	V	V	V	V	· 1	x	ж	1	V	
49	Senin, 22 Juli 2023	D20-07A	1	√	V	V	√	V	V	√	1	×	×	V	V	
50	Senin, 22 Juli 2023	D20-07B	1	V	V	V	✓	V	V	1	1	- X	×	V	V	
51	Senin, 22 Juli 2023	D20-07C	V	V	V	V	V		V	√	√	ж	×	V	V	
52		D20-04A		1				TANI	CLE	ANING						
53	Senin, 29 Juli 2023	D20-04B	V	√	V	1	V	√	1	1	1	1	V	_	V	
54	Senin, 29 Juli 2023	D20-04C	V	1	V	~	✓	V	V	1	1	1	1	✓	V	
55	Senin, 29 Juli 2023	D20-01A	1	V	V	1	1	V	x	V	1	x	x	V	V	
56	Senin, 29 Juli 2023	D20-01B	V	1	V	/	✓	V	V	V	1	×	×	V	_	8
57	Senin, 29 Juli 2023	D20-13A	/	V	V	/	V	V	V	×	×	×	×	V	_	
58	Senin, 29 Juli 2023	D20-13B	V	V	V	V	✓	V	1	×	×	×	x	V	V	
59		D20-15A						M	OD TA	NK						
60	Senin, 29 Juli 2023	D20-15B	1	V	V	V	V	V	V	×	x	×	×	V .	V	
61	Selasa, 13 Agustus 2023	R-1	1	V	V	V	V	V	V	4	1	×	×	V	_	
62		R-2						M	OD TA	NK						
63	Selasa, 13 Agustus 2023	R-3	V	V	V	V	V	V	V	V	×	×	×	1	V	
64	Selasa, 13 Agustus 2023	R-4	√	V	V	V	1	V	V	×	1	V	×	V	V	
65	Selasa, 13 Agustus 2023	R-5	_	V	V	_	1	V	V	×	×	×	×	V	V	
66	Selasa, 13 Agustus 2023	R-6		√	V	V	/	V	V .	V	×	×	×	V	V	
67	Selasa, 13 Agustus 2023	R-7	V	V	/	V	1	V	1	×	1	×	×	V	✓	
68	Selasa, 13 Agustus 2023	R-8	V	V	V	/	1	V	V	×	×	×	×	V	V	
69		R-9		1		1		O	VERHA	UL						
70		R-10							VERHA							

No	Hari/Tanggal		HIN R	ATG S	ystems		Tank Mas	ter Status	Power Switch		Shroud Cable			Gro	und	Val
		Nama Tangki	Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	Keterangan
1	Selasa, 13 Agustus 2023	D20-08	-	1		V	V	_	1	V	V	V	~	V	✓	Water level sensor not available
2	Kamis, 15 Agustus 2023	R-11	_	V	V	/	/	_	V	√	V	×	×	√	_	
3		V-3						0	VERHA	UL						
4		V-4		OVERHAUL												
5	Kamis, 15 Agustus 2023	V-5	√	1	✓	V	×	×	V	✓	V	V	×	V	V	ATG dimatikan
6	Kamis, 15 Agustus 2023	V-6	1	V	_	V	V	V	V	✓	V	V	V	1	√	
7	Kamis, 15 Agustus 2023	V-7	V	1	√	-	✓	V	V	√	1	1	√	V	V	
8	Rabu, 7 Agustus 2023	N-2	_	V	V	V	V	V	V	V	V	V	×	V	✓	
9	Rabu, 7 Agustus 2023	N-4	1	V	V	V	√	1	1	√	V	V	×	V	✓	
0	Rabu, 7 Agustus 2023	0-1	1	V	√	V	✓	1	V	✓	V	×	×	1	√	
1	Rabu, 7 Agustus 2023	0-2	V	/	· /	V	√	1	V	V	1	×	×	~	√	E Properties
12	Kamis, 8 Agustus 2023	0-3	1	V	√	✓	√	V	1	V	1	×	×	1	✓	a .
3	Kamis, 8 Agustus 2023	0-4	1	1	1	✓	1	1	V	V	1	×	×	1	V	
14	Kamis, 8 Agustus 2023	0-6	_	V	√	V	V	V	V	V	✓	x	V	1	V	
5	Kamis, 8 Agustus 2023	0-8	1	_	1	1	V	1	1	V	V	×	V	√	✓	
6	Jum'at, 9 Agustus 2023	0-9	V	1	√	V	√	V	1	V	V	V	×	V	V	
7		0-10						O	VERHA	UL						
18	Jum'at, 9 Agustus 2023	0-11	V	V	V	V	V	1	V	V	√	×	×	1	V	
19	Jum'at, 9 Agustus 2023	0-12	V	V	V	V	V	_	1	✓	1	✓	V	1	√	
ю	Jum'at, 9 Agustus 2023	0-13	1	V	√	V	_	V	1	V	V	✓	V	V	V	
1	Jum'at, 9 Agustus 2023	0-14	1	V	1	V	✓	_	√	✓	V	×	x	V	✓	
92	Rabu, 7 Agustus 2023	D20-17	V	x	1	V	√	_	V	V	V	×	x	V	V	MST Rusak, Gak ada Spare
93	Rabu, 7 Agustus 2023	D20-18	1	V	√	V	V	V	1	✓	V	×	×	-	√	
94	Senin, 5 Agustus 2023	O-15	_	V	V	V	V		V	V	√	×	×	~	√	
95	Senin, 5 Agustus 2023	0-16	_	V	V	1	√	/	V	×	V	×	V	V	V	
96	Senin, 5 Agustus 2023	0-17	V	V	V	V	√	/	V	×	1	x	×	V	V	
97	Senin, 22 Juli 2023	0-18	~	V	V	V	V	V	V	V	√	✓	V	V	V	
98	Senin, 22 Juli 2023	0-19	~	1	V	1	V	V	V	√	√	×	V	V	V	
99	Senin, 22 Juli 2023	0-20	V	√	1	1	V	/	_	×	V	×	×	V	V	
00	Senin, 22 Juli 2023	0-21	1	V	V	V	✓	V	· V	V	V	V	V	V	V	
01	Senin, 22 Juli 2023	0-22	V	V	V	1	V	✓			1	✓	_	V	V	
02	Senin, 22 Juli 2023	0-23	_	1	1	V	V	√	V	✓	✓	✓	1	✓	V	
03	Senin, 22 Juli 2023	0-24	1	V	V	1	V	√	✓	✓	1	√	V	V	✓	
.04		O-25						0	VERHA	UL						
05	Rabu, 7 Agustus 2023	D20-11	_	/	V	1	V	V	✓	V	V	1	1	V	V	
06	Rabu, 7 Agustus 2023	D20-12	_	V	V	V	1	1	1	✓	V	V	~	V	V	
107	Rabu, 7 Agustus 2023	P-31	V	1	V	V	V	V	V	x	V	×	×	✓	✓	

No				ATG S	ystems		Tank Master Status		Power Switch		Shroud Cable			Gro	und	
	Hari/Tanggal	Nama Tangki	Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	Keterangan
108	Rabu, 7 Agustus 2023	P-32	/	√	V	1	V	√	-	1	×	×	×	V	✓	
109	Senin, 22 Juli 2023	P-1	V	1	V	1	V	1	1	×	V	×	x	*	√	
110	Senin, 22 Juli 2023	P-2	V	V	V	V	V	✓ .	V	V	x	×	x	V	✓	
111		P-3		OVERHAUL												
112	Senin, 22 Juli 2023	P-4	√	1	V	V	V	1			V .	V	V	V	✓	
113	Senin, 22 Juli 2023	P-5	V	1	✓	V	V	V	1	V	×	x	×	V	√	
114	Senin, 22 Juli 2023	P-7	V	V	√	1	V	√			V	V	✓	✓	✓	
115	Senin, 22 Juli 2023	P-8	V	V	V	V	V	V	_	V	V	V	/	V	✓	
116		D20-03						0/	ERHA	UL						
117	Selasa, 13 Agustus 2023	D-320-12	V	V	V	V	✓	√	V	V	√	✓	_	1	√	
118	Selasa, 13 Agustus 2023	D-320-02A	. 1	V	V	V	V	1	V	V	V	✓	1	1	√	
119	Selasa, 13 Agustus 2023	D-320-02B	V	V	V	V	V	1	1	V	V	1	_	1	V	
120	Selasa, 13 Agustus 2023	C20-01A	V	V	√	V	✓	1	V	V	V	V	V	1	V	
121	Selasa, 13 Agustus 2023	C20-01B	V	V	√	V	✓	1	V	V	✓	V	V	1	1	·
122	9.															
			0	1	3	0	1	1	1	18	11	42	58	0	0	

NOTE:

*** FWL = Free Water Level RDU = Remote Display Unit MST = Multi Spot Temperature RTG = Radar Tank Gauge PT.Control Systems

40 -16