


Monthly Report Pekerjaan TSA Preventive Maintenance Peralatan ATG Area OM, LAWE LAWE, DHP, BPP I dan UTL RU V BALIKPAPAN

Thursday, September 21, 2023

ATG PERFOMANCE







| LIST ITEM | STATUS |
|--|--------|
| Troubleshoot sinyal P-1 "Ned more power" | V |
| Troubleshoot Kabel Power R-5 "Putus" | 1 |
| Troubleshoot Power ATG R-8 "MCB Trip" | 1 |
| | |
| | |
| | |
| | |
| | 1 |
| | - |
| | _ |
| | |
| | |
| | |
| | - |
| | |
| | |
| | - |
| | |

KERUSAKAN SPARE PART

| LIST ITEM | STATUS |
|--|--------|
| Display GWR U-11 dan U-10 (UTL). | Rusak |
| MST D20-17 "Menunggu Overhaul". | Rusak |
| Spot 4 Temperature D20-05A Rusak | Rusak |
| • Sensor FWL A-4 | Rusak |
| | |
| | |
| | |
| | |
| | |



Total Resetting level Monthly



Assist re-Calibration ATG

TK-101-T1B, TK-101-T1D, R-05, R-07, TK-101-T1A, TK-101-T1C, C-20-01B, R-06

Total Verifikasi : 82
Total On Call : 6
Total Kerusakan SparePart :
Total Assist re-Calibration ATG : 8

PT. Control Systems

Mengetahui, PT. Pertamina RU V Balikpapan

M- HADORI