


Monthly Report Pekerjaan TSA Preventive Maintenance Peralatan ATG Area OM, LAWE LAWE, DHP, BPP I dan UTL RU V BALIKPAPAN

aturday, January 20, 2024

ATG PERFOMANCE



PROBLEM FOUND


TRODELINITOUND	
LIST ITEM	STATUS
Kurang Power FJB 11 dan FJB 17 "Menunggu MCB dan orang listrik"	Hold
Troubleshoot temperatur ATG D20-04C "Menunggu TA, tanki stanby, Perlu ganti card"	Hold
 Primary card T-1B DHP Error 	Fix
• Jalur kabel P-31, P-32, R-11 Putus by RDMP	OnProgress
Migrasi sinyal D20-15A FJB2 ke FJB14	Fix

KERUSAKAN SPARE PART

LIST ITEM	STATUS
Display GWR U-11 dan U-10 (UTL).	Rusak
 MST D20-17 "Menunggu Overhaul". 	Rusak
 Spot 4 Temperature D20-05A Rusak 	Rusak
Sensor FWL A-4	Rusak
Primary Card GWR T-1B	Rusak
Primary Card GWR V-17	Rusak



Total Resetting level Monthly



Des Jan Feb Mar Apr Mei Juni Juli Agus Sep Okt Nov Des Jan

Assist re-Calibration ATG

: 95	
	: 95

Total Verifikasi : 95
Total On Call : 7
Total Kerusakan SparePart : 1
Total Assist re-Calibration ATG :

PT. Control Systems

Mengetahui, PT. Pertamina RU V Balikpapan

ALPAN TE