

Verifikasi ATG Pekerjaan TSA Preventive Maintenance Peralatan ATG Area UTL RU V BALIKPAPAN

									Bulan :	Fel	buari 2023
No	Hari / tanggal	Tanki	Area	Level Liquid (mm)					Operator		
				Pengukuran			Koreksi				
				ATG	DT	Selisih	ATG	DT	Selisih	Nama	Paraf
1	Kamis, 16/02/2023	U-10		8,097	8,082	-15				Nur m	n hai
2	Kamis, 16/02/2023	U-11	Π.	7,512	7,500	-12				in M	٨
3	Kamis, 16/02/2023	U-12	一	7,009	6,999	-10				1	J.
4	Kamis, 16/02/2023	U-13		OPERASIONAL BERKELANJUTAN						(
5	Kamis 16/02/2023	U-14		OPERASIONAL BERKELANJUTAN							

NOTE:

PT.CS

Prick

picky

HUK SAMMI