



Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area Lawe-lawe "


Periode ke : Juli 2023


No	Har/Tanggal	Nama Tangki	ATG Systems			Tank Master Status		Shroud Cable		Ground		Keterangan
			Level	Temp	PWL	Tank Master	Intranet	RTG	MST	RTG	MST	
1		TK-101-T1A	✓	✓	✓	✓	✗	✓	✓	✓	✓	
2		TK-101-T1B	✓	✓	✓	✓	✗			✓	✓	
3		TK-101-T1C	✓	✓	✓	✓	✗			✓	✓	
4		TK-101-T1D	✓	✓	✓	✓	✗	✗	✗	✓	✓	
5		TK-101-T1E	✓	✓	✓	✓	✗	✗	✗	✓	✓	
6		TK-101-T1F	✓	✓	✓	✓	✗			✓	✓	
7		TK-101-T1G	✓	✓	✓	✓	✗	✗	✗	✓	✓	

NOTE :

PT. Control Systems

Instrumen M44 Lawe-lawe





- Intranet lawe² dikeluarkan karena mengganggu system tankmaster.net di Balikpapan. diabaikan update system security dan print IT.
- Beberapa RTG isolasi kabel sudah mulai getas perlu diganti shroud Cable, monev air masuk.