

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM "

Periode Ke : Februari 2024

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
1	Senin, 21 Januari 2024	A-1	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
2	Senin, 21 Januari 2024	A-2	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
3	Senin, 21 Januari 2024	A-3	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	Good	
4	Senin, 21 Januari 2024	A-4	✓	✓	✗	✓	✓	✓	✓	✗	✓	✗	✗	Good with note	Sensor FWL Broken, Gak ada Spare
5		A-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Cleaning	
6		A-6												Overhaul	
7		A-7												Modtank	
8	Rabu, 23 Januari 2024	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
9		A-16												Modtank	
10		A-17												Overhaul	
11		A-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Cleaning	
12	Selasa, 19 Februari 2024	A-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
13	Rabu, 23 Januari 2024	A-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
14		A-21												Overhaul	
15	Selasa, 23 Januari 2024	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
16	Selasa, 23 Januari 2024	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
17	Selasa, 23 Januari 2024	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
18	Selasa, 23 Januari 2024	A-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
19	Selasa, 23 Januari 2024	A-26	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	Good	
20	Selasa, 23 Januari 2024	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
21		A-28												Overhaul	
22	Jum'at, 25 Januari 2024	A-29	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
23		A-30												Modtank	
24	Jum'at, 25 Januari 2024	A-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
25	Jum'at, 25 Januari 2024	A-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	Good	
26	Jum'at, 25 Januari 2024	A-33	✓	✓		✓	✓	✓	✓	✓	✓	✓	✗	Good	Water level sensor not available
27	Selasa, 19 Februari 2024	E-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
28	Senin, 28 Januari 2024	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
29	Senin, 28 Januari 2024	E-3	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	Good with note	FWL Error
30	Selasa, 19 Februari 2024	E-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
31	Senin, 28 Januari 2024	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
32	Senin, 28 Januari 2024	E-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
33	Selasa, 19 Februari 2024	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
34		T-901												Overhaul	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
35	Selasa, 29 Januari 2024	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
36	Selasa, 29 Januari 2024	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
37	Selasa, 29 Januari 2024	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
38	Selasa, 29 Januari 2024	T-201	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
39	Selasa, 29 Januari 2024	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
40	Selasa, 29 Januari 2024	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
41	Senin, 21 Januari 2024	V-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
42	Senin, 21 Januari 2024	V-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
43	Senin, 21 Januari 2024	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
44	Senin, 21 Januari 2024	D20-05B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
45	Senin, 21 Januari 2024	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
46	Senin, 21 Januari 2024	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
47		D20-06A												Modtank	
48	Senin, 21 Januari 2024	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
49	Senin, 21 Januari 2024	D20-07A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
50	Senin, 21 Januari 2024	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
51	Senin, 21 Januari 2024	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
52	Kamis, 14 Febuari 2024	D20-04A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
53	Senin, 28 Januari 2024	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
54	Senin, 28 Januari 2024	D20-04C	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good with note	Temp Spot 2, 3 dan 4 Error
55	Senin, 28 Januari 2024	D20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
56	Senin, 28 Januari 2024	D20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
57		D20-13A												Overhaul	
58	Senin, 28 Januari 2024	D20-13B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good	
59	Kamis, 14 Febuari 2024	D20-15A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
60	Senin, 28 Januari 2024	D20-15B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good	
61	Selasa, 12 Febuari 2024	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
62		R-2												Modtank	
63	Selasa, 12 Febuari 2024	R-3	✓	✓	✗	✓	✓	✓	✓	✓	✗	✗	✗	Good with note	FWL Error
64		R-4												Overhaul	
65	Selasa, 12 Febuari 2024	R-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good	
66	Selasa, 12 Febuari 2024	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	Good	
67	Selasa, 12 Febuari 2024	R-7	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
68	Selasa, 12 Febuari 2024	R-8	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good	
69		R-9												Overhaul	
70		R-10												Overhaul	
71	Selasa, 12 Febuari 2024	D20-08	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓	Good	Water level sensor not available
72	Kamis, 14 Febuari 2024	R-11	✓	✓	✓	✓	✗	✗	✓	✓	✓	✗	✗	Good with note	Kabel power dan sinyal putus

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
73	Kamis, 14 Februari 2024	V-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
74	Kamis, 14 Februari 2024	V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
75	Kamis, 14 Februari 2024	V-5	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✗	Good	ATG dimatikan
76	Kamis, 14 Februari 2024	V-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
77	Kamis, 14 Februari 2024	V-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
78	Rabu, 6 Februari 2024	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
79	Rabu, 6 Februari 2024	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
80	Rabu, 6 Februari 2024	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
81	Rabu, 6 Februari 2024	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
82	Kamis, 7 Februari 2024	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
83	Kamis, 7 Februari 2024	O-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
84	Kamis, 7 Februari 2024	O-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
85	Kamis, 7 Februari 2024	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
86	Jum'at, 8 Februari 2024	O-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
87		O-10												Overhaul	
88	Jum'at, 8 Februari 2024	O-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
89	Jum'at, 8 Februari 2024	O-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
90	Jum'at, 8 Februari 2024	O-13	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
91	Jum'at, 8 Februari 2024	O-14	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
92	Rabu, 6 Februari 2024	D20-17	✓	✗	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good with note	MST Rusak, Gak ada Spare
93	Rabu, 6 Februari 2024	D20-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
94	Senin, 5 Februari 2024	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
95	Senin, 5 Februari 2024	O-16	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	Good	
96	Senin, 5 Februari 2024	O-17	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
97	Senin, 21 Januari 2024	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
98	Senin, 21 Januari 2024	O-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
99	Senin, 21 Januari 2024	O-20	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
100	Senin, 21 Januari 2024	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
101	Senin, 21 Januari 2024	O-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
102	Senin, 21 Januari 2024	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
103	Senin, 21 Januari 2024	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
104	Senin, 21 Januari 2024	O-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
105	Rabu, 6 Februari 2024	D20-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
106	Rabu, 6 Februari 2024	D20-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
107	Rabu, 6 Februari 2024	P-31	✓	✓	✓	✓	✗	✗	✓	✗	✓	✗	✗	Good with note	Kabel power dan sinyal putus
108	Rabu, 6 Februari 2024	P-32	✓	✓	✓	✓	✗	✗	✓	✓	✗	✗	✗	Good with note	Kabel power dan sinyal putus
109	Senin, 21 Januari 2024	P-1	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
110	Senin, 21 Januari 2024	P-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
111	Senin, 12 Febuari 2024	P-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
112	Senin, 21 Januari 2024	P-4	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
113		P-5												Overhaul	
114	Senin, 21 Januari 2024	P-7	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
115	Senin, 21 Januari 2024	P-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
116	Selasa, 19 Febuari 2024	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
117	Selasa, 12 Febuari 2024	D-320-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
118	Selasa, 12 Febuari 2024	D-320-02A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
119	Selasa, 12 Febuari 2024	D-320-02B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
120		C20-01A												Overhaul	
121	Selasa, 12 Febuari 2024	C20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
122															


ATG Systems				Tank Master Status		Power Switch		Shroud Cable		
Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU
0	2	3	0	4	4	0	16	8	39	53

NOTE :

*** FWL = Free Water Level
RDU = Remote Display Unit

MST = Multi Spot Temperature
RTG = Radar Tank Gauge

PT.Control Systems



Instrument MA4

