


Monthly Report Pekerjaan TSA Preventive Maintenance Peralatan ATG Area OM, LAWE LAWE, DHP, BPP I dan UTL RU V BALIKPAPAN

ATG PERFOMANCE





LIST ITEM	STATUS
 Troubleshoot A-23 "Dotnet Delay" 	V
 Troubleshoot FJB 4 "Migrasi FJB 4 ke Systemhub 3" 	~
Troubleshoot temperatur ATG D20-04C	Hold
 Troubleshoot T-903 "Temperatur Hunting" 	1
• Troubleshoot Tank R-3, R-6 "Intermitten Signal"	1
● Troubleshoot Tank R-7 "Migrasi Kabel"	V

KERUSAKAN SPARE PART

LIST ITEM	STATUS
 Display GWR U-11 dan U-10 (UTL). 	Rusak
MST D20-17 "Menunggu Overhaul".	Rusak
Spot 4 Temperature D20-05A Rusak	Rusak
• Sensor FWL A-4	Rusak



Total Resetting level Monthly



	Calibration ATG
Total Verifikasi	: 93

Total On Call : 5 Total Kerusakan SparePart Total Assist re-Calibration ATG

PT. Control Systems

Mengetahui, PT. Pertamina RU V Balikpapan