

## Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM "

Periode Ke : Maret 2024

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
1	Senin, 21 Febuari 2024	A-1	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
2	Senin, 21 Febuari 2024	A-2	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
3	Senin, 21 Febuari 2024	A-3	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	Good	
4	Senin, 21 Febuari 2024	A-4	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
5		A-5	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✗	Cleaning	
6		A-6												Overhaul	
7		A-7												Modtank	
8	Rabu, 23 Febuari 2024	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
9		A-16												Modtank	
10		A-17												Overhaul	
11		A-18	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✓	Cleaning	
12	Selasa, 19 Maret 2024	A-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
13	Rabu, 23 Febuari 2024	A-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
14		A-21												Overhaul	
15	Selasa, 23 Febuari 2024	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
16	Selasa, 23 Febuari 2024	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
17	Selasa, 23 Febuari 2024	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
18	Selasa, 23 Febuari 2024	A-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
19	Selasa, 23 Febuari 2024	A-26	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	Good	
20	Selasa, 23 Febuari 2024	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
21		A-28												Overhaul	
22	Jum'at, 25 Febuari 2024	A-29	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
23		A-30												Modtank	
24	Jum'at, 25 Febuari 2024	A-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
25	Jum'at, 25 Febuari 2024	A-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	Good	
26	Jum'at, 25 Febuari 2024	A-33	✓	✓		✓	✓	✓	✓	✓	✓	✓	✗	Good	Water level sensor not available
27	Selasa, 19 Maret 2024	E-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
28	Senin, 28 Febuari 2024	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
29	Senin, 28 Febuari 2024	E-3	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	Good with note	FWL Error
30	Selasa, 19 Maret 2024	E-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
31	Senin, 28 Febuari 2024	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
32	Senin, 28 Febuari 2024	E-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
33	Selasa, 19 Maret 2024	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
34		T-901	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
35	Selasa, 29 Februari 2024	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
36	Selasa, 29 Februari 2024	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
37	Selasa, 29 Februari 2024	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
38	Selasa, 29 Februari 2024	T-201	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
39	Selasa, 29 Februari 2024	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
40	Selasa, 29 Februari 2024	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
41	Senin, 21 Februari 2024	V-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
42	Senin, 21 Februari 2024	V-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
43	Senin, 21 Februari 2024	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
44	Senin, 21 Februari 2024	D20-05B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
45	Senin, 21 Februari 2024	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
46	Senin, 21 Februari 2024	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
47		D20-06A												Modtank	
48	Senin, 21 Februari 2024	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
49	Senin, 21 Februari 2024	D20-07A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
50	Senin, 21 Februari 2024	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
51	Senin, 21 Februari 2024	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
52	Kamis, 14 Maret 2024	D20-04A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
53	Senin, 28 Februari 2024	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
54	Senin, 28 Februari 2024	D20-04C	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good with note	Temp Spot 2, 3 dan 4 Error
55	Senin, 28 Februari 2024	D20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
56	Senin, 28 Februari 2024	D20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
57		D20-13A												Modtank	
58	Senin, 28 Februari 2024	D20-13B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good	
59	Kamis, 14 Maret 2024	D20-15A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Cleaning	
60	Senin, 28 Februari 2024	D20-15B	✓	✓	✓	✓	✗	✗	✓	✗	✗	✗	✗	Overhaul	
61	Selasa, 12 Maret 2024	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
62		R-2												Modtank	
63	Selasa, 12 Maret 2024	R-3	✓	✓	✗	✓	✓	✓	✓	✓	✗	✗	✗	Good with note	FWL Error
64		R-4												Overhaul	
65	Selasa, 12 Maret 2024	R-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good	
66	Selasa, 12 Maret 2024	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	Good	
67	Selasa, 12 Maret 2024	R-7	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
68	Selasa, 12 Maret 2024	R-8	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good	
69		R-9												Overhaul	
70		R-10												Overhaul	
71	Selasa, 12 Maret 2024	D20-08	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓	Good	Water level sensor not available
72	Kamis, 14 Maret 2024	R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	



No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
73	Kamis, 14 Maret 2024	V-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
74	Kamis, 14 Maret 2024	V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
75	Kamis, 14 Maret 2024	V-5	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✗	Good	Tangki tdk digunakan, ATG dimatikan
76	Kamis, 14 Maret 2024	V-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
77	Kamis, 14 Maret 2024	V-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
78	Rabu, 6 Maret 2024	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
79	Rabu, 6 Maret 2024	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
80	Rabu, 6 Maret 2024	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
81	Rabu, 6 Maret 2024	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
82	Kamis, 7 Maret 2024	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
83	Kamis, 7 Maret 2024	O-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
84	Kamis, 7 Maret 2024	O-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
85	Kamis, 7 Maret 2024	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
86	Jum'at, 8 Maret 2024	O-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
87		O-10												Overhaul	
88	Jum'at, 8 Maret 2024	O-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
89	Jum'at, 8 Maret 2024	O-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
90	Jum'at, 8 Maret 2024	O-13	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
91	Jum'at, 8 Maret 2024	O-14	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
92	Rabu, 6 Maret 2024	D20-17	✓	✗	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good with note	MST Rusak, Gak ada Spare
93	Rabu, 6 Maret 2024	D20-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
94	Senin, 5 Maret 2024	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
95	Senin, 5 Maret 2024	O-16	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	Good	
96	Senin, 5 Maret 2024	O-17	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
97	Senin, 21 Februari 2024	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
98	Senin, 21 Februari 2024	O-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
99	Senin, 21 Februari 2024	O-20	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
100	Senin, 21 Februari 2024	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
101	Senin, 21 Februari 2024	O-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
102	Senin, 21 Februari 2024	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
103	Senin, 21 Februari 2024	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
104	Senin, 21 Februari 2024	O-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
105	Rabu, 6 Maret 2024	D20-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
106	Rabu, 6 Maret 2024	D20-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
107	Rabu, 6 Maret 2024	P-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
108	Rabu, 6 Maret 2024	P-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	Good	
109	Senin, 21 Februari 2024	P-1	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
110	Senin, 21 Februari 2024	P-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
111	Senin, 12 Maret 2024	P-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
112	Senin, 21 Februari 2024	P-4	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
113		P-5												Overhaul	
114	Senin, 21 Februari 2024	P-7	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
115	Senin, 21 Februari 2024	P-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
116	Selasa, 19 Maret 2024	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
117	Selasa, 12 Maret 2024	D-320-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
118	Selasa, 12 Maret 2024	D-320-02A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
119	Selasa, 12 Maret 2024	D-320-02B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
120		C20-01A												Overhaul	
121	Selasa, 12 Maret 2024	C20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
122															

ATG Systems				Tank Master Status		Power Switch		Shroud Cable		
Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU
0	2	2	0	4	4	0	16	8	39	53

**NOTE :**

\*\*\* FWL = Free Water Level  
RDU = Remote Display Unit

MST = Multi Spot Temperature  
RTG = Radar Tank Gauge

PT. Control Systems



Instrument MA4

