



Control Systems

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM "

Periode Ke : Januari 2024

No	Hari/Tanggal	Nama Tangkai	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
1	Senin, 21 Desember 2024	A-1	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
2	Senin, 21 Desember 2024	A-2	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
3	Senin, 21 Desember 2024	A-3	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	Good	
4	Senin, 21 Desember 2024	A-4	✓	✓	✗	✓	✓	✓	✓	✗	✓	✗	✗	Good with note	Sensor FWL Broken, Gak ada Spare
5	Senin, 21 Desember 2024	A-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Cleaning	
6		A-6												Overhaul	
7		A-7												Modtank	
8	Rabu, 23 Desember 2024	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
9		A-16												Modtank	
10		A-17												Overhaul	
11	Rabu, 23 Desember 2024	A-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Cleaning	
12	Selasa, 19 Januari 2024	A-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
13	Rabu, 23 Desember 2024	A-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
14	Selasa, 23 Desember 2024	A-21												Overhaul	
15	Selasa, 23 Desember 2024	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
16	Selasa, 23 Desember 2024	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
17	Selasa, 23 Desember 2024	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
18	Selasa, 23 Desember 2024	A-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
19	Selasa, 23 Desember 2024	A-26	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	Good	
20	Selasa, 23 Desember 2024	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
21		A-28												Overhaul	
22	Jum'at, 25 Desember 2024	A-29	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
23	Jum'at, 25 Desember 2024	A-30	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Cleaning	
24	Jum'at, 25 Desember 2024	A-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
25	Jum'at, 25 Desember 2024	A-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	Good	
26	Jum'at, 25 Desember 2024	A-33	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	Water level sensor not available
27	Selasa, 19 Januari 2024	E-1	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✓	Overhaul	
28	Senin, 28 Desember 2024	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
29	Senin, 28 Desember 2024	E-3	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	Good with note	FWL Error
30	Selasa, 19 Januari 2024	E-4	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✓	Overhaul	
31	Senin, 28 Desember 2024	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
32	Senin, 28 Desember 2024	E-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
33	Selasa, 19 Januari 2024	E-7	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✓	Overhaul	
34		T-901												Overhaul	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Functional	Shroud Cable	RTG	MST	RDU		
35	Selasa, 29 Desember 2024	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
36	Selasa, 29 Desember 2024	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
37	Selasa, 29 Desember 2024	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
38		T-201	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✓	Overhaul	
39	Selasa, 29 Desember 2024	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
40	Selasa, 29 Desember 2024	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
41	Senin, 21 Desember 2024	V-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
42	Senin, 21 Desember 2024	V-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
43	Senin, 21 Desember 2024	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
44	Senin, 21 Desember 2024	D20-05B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
45	Senin, 21 Desember 2024	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
46	Senin, 21 Desember 2024	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
47		D20-06A												Modtrank	
48	Senin, 21 Desember 2024	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
49	Senin, 21 Desember 2024	D20-07A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
50	Senin, 21 Desember 2024	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
51	Senin, 21 Desember 2024	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
52	Kamis, 14 Januari 2024	D20-04A	✓	✗		✓	✓	✓	✓	✓	✓	✓	✓	Good with note	Temp Spot 2, 3 dan 4 Error
53	Senin, 28 Desember 2024	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
54	Senin, 28 Desember 2024	D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
55	Senin, 28 Desember 2024	D20-01A	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	✗	Good	
56	Senin, 28 Desember 2024	D20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
57	Senin, 28 Desember 2024	D20-13A	✓	✓	✓	✓	✗	✗	✓	✗	✗	✗	✗	Overhaul	
58	Senin, 28 Desember 2024	D20-13B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good	
59	Kamis, 14 Januari 2024	D20-15A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
60	Senin, 28 Desember 2024	D20-15B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good	
61	Selasa, 12 Januari 2024	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
62		R-2												Modtrank	
63	Selasa, 12 Januari 2024	R-3	✓	✓	✗	✓	✓	✓	✓	✓	✗	✗	✗	Good with note	FWL Error
64	Selasa, 12 Januari 2024	R-4												Cleaning	
65	Selasa, 12 Januari 2024	R-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good	
66	Selasa, 12 Januari 2024	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	Good	
67	Selasa, 12 Januari 2024	R-7	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good	
68	Selasa, 12 Januari 2024	R-8	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good	
69		R-9												Overhaul	
70		R-10												Overhaul	
71	Selasa, 12 Januari 2024	D20-08	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓	Good	Water level sensor not available
72	Kamis, 14 Januari 2024	R-11	✓	✓	✓	✓	✗	✗	✓	✓	✓	✗	✗	Good	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
73		V-3	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✓	Overhaul	
74		V-4	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✗	Good	ATG dimatikan
75	Kamis, 14 Januari 2024	V-5	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✓	Good	
76	Kamis, 14 Januari 2024	V-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
77	Kamis, 14 Januari 2024	V-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
78	Rabu, 6 Januari 2024	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
79	Rabu, 6 Januari 2024	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
80	Rabu, 6 Januari 2024	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
81	Rabu, 6 Januari 2024	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
82	Kamis, 7 Januari 2024	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
83	Kamis, 7 Januari 2024	O-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
84	Kamis, 7 Januari 2024	O-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
85	Kamis, 7 Januari 2024	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
86	Jum'at, 8 Januari 2024	O-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
87		O-10												Overhaul	
88	Jum'at, 8 Januari 2024	O-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
89	Jum'at, 8 Januari 2024	O-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
90	Jum'at, 8 Januari 2024	O-13	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
91	Jum'at, 8 Januari 2024	O-14	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	MST Rusak, Gak ada Spare
92	Rabu, 6 Januari 2024	D20-17		✗	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good with note	
93	Rabu, 6 Januari 2024	D20-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
94	Senin, 5 Januari 2024	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
95	Senin, 5 Januari 2024	O-16	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	Good	
96	Senin, 5 Januari 2024	O-17	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
97	Senin, 21 Desember 2024	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
98	Senin, 21 Desember 2024	O-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
99	Senin, 21 Desember 2024	O-20	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	Good	
100	Senin, 21 Desember 2024	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
101	Senin, 21 Desember 2024	O-22	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
102	Senin, 21 Desember 2024	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
103	Senin, 21 Desember 2024	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
104	Senin, 21 Desember 2024	O-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
105	Rabu, 6 Januari 2024	D20-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
106	Rabu, 6 Januari 2024	D20-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
107	Rabu, 6 Januari 2024	P-31	✓	✓	✓	✓	✗	✗	✓	✗	✓	✗	✗	Good	
108	Rabu, 6 Januari 2024	P-32	✓	✓	✓	✓	✗	✗	✓	✓	✗	✗	✗	Good	
109	Senin, 21 Desember 2024	P-1	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
110	Senin, 21 Desember 2024	P-2	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	Good	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
111	Senin, 12 Januari 2024	P-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
112	Senin, 21 Desember 2024	P-4	✓	✓	✓	✓	✓	✓		✓	✓	✓	✓	Good	
113	Senin, 21 Desember 2024	P-5	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	Good	
114	Senin, 21 Desember 2024	P-7	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
115	Senin, 21 Desember 2024	P-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
116	Selasa, 19 Januari 2024	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
117	Selasa, 12 Januari 2024	D-320-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
118	Selasa, 12 Januari 2024	D-320-02A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
119	Selasa, 12 Januari 2024	D-320-02B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
120	Selasa, 12 Januari 2024	C20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
121	Selasa, 12 Januari 2024	C20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
122															

ATG Systems				Tank Master Status		Power Switch		Shroud Cable		
Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU
0	2	3	0	10	10	1	17	11	42	56

NOTE :

PT. Control Systems

Instrument M44




ALTAN YK.

*** FWL = Free Water Level
RDU = Remote Display Unit

MST = Multi Spot Temperature
RTG = Radar Tank Gauge