

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM "

Periode Ke : Maret 2023

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
1	Rabu, 22/02/2023	A-1	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
2	Rabu, 22/02/2023	A-2	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
3	Rabu, 22/02/2023	A-3	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗	✓	✓	
4	Rabu, 22/02/2023	A-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
5		A-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
6		A-6	OVERHAUL													
7		A-7	✓	✓	✓	✓	✗	✗								WIKI
8	Senin, 20/02/2023	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
9		A-16	MOD TANK													
10	Senin, 20/02/2023	A-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
11	Senin, 20/02/2023	A-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
12		A-19	TANK CLEANING													
13	Senin, 20/02/2023	A-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
14	Senin, 20/02/2023	A-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
15	Selasa, 21/02/2023	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
16	Selasa, 21/02/2023	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
17	Selasa, 21/02/2023	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
18	Selasa, 21/02/2023	A-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
19	Selasa, 21/02/2023	A-26	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗	✓	✓	
20	Selasa, 21/02/2023	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
21	Selasa, 21/02/2023	A-28	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
22	Senin, 13/03/2023	A-29	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
23	Senin, 13/03/2023	A-30	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
24	Senin, 13/03/2023	A-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
25	Senin, 13/03/2023	A-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
26	Senin, 13/03/2023	A-33	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	MST tidak support FWL
27	Senin, 20/02/2023	E-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
28	Senin, 20/02/2023	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
29	Senin, 20/02/2023	E-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
30		E-4	TANK CLEANING													
31	Senin, 20/02/2023	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
32	Senin, 20/02/2023	E-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
33	Senin, 20/02/2023	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan	
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST		
34		T-901	TANK CLEANING														
35	Selasa, 21/02/2023	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
36	Selasa, 21/02/2023	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
37	Selasa, 21/02/2023	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
38	Selasa, 21/02/2023	T-201	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓		
39	Selasa, 21/02/2023	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓		
40	Selasa, 21/02/2023	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓		
41	Kamis, 02/03/2023	V-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
42	Kamis, 02/03/2023	V-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
43	Jum'at, 24/02/2023	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	Intermitten, PT. Pinaras	
44	Jum'at, 24/02/2023	D20-05B	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	✓	✓	Intermitten, PT. Pinaras	
45	Jum'at, 24/02/2023	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	Intermitten, PT. Pinaras	
46	Jum'at, 24/02/2023	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	Intermitten, PT. Pinaras	
47		D20-06A	MOD TANK														
48	Jum'at, 24/02/2023	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	Intermitten, PT. Pinaras	
49	Jum'at, 24/02/2023	D20-07A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	Intermitten, PT. Pinaras	
50	Jum'at, 24/02/2023	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	Intermitten, Kabel RDU Putus	
51	Jum'at, 24/02/2023	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	Intermitten, PT. Pinaras	
52		D20-04A	TANK CLEANING														
53	Jum'at, 24/02/2023	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
54	Selasa, 21/02/2023	D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
55	Selasa, 21/02/2023	D20-01A	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✗	✓	✓	Power Switch Rusak, Tangki Sibuk	
56	Selasa, 21/02/2023	D20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓		
57	Selasa, 21/02/2023	D20-13A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
58	Selasa, 21/02/2023	D20-13B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
59		D20-15A	MOD TANK														
60	Selasa, 21/02/2023	D20-15B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
61	Jum'at, 24/02/2023	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓		
62		R-2	MOD TANK														
63	Jum'at, 24/02/2023	R-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓		
64	Jum'at, 24/02/2023	R-4	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	✓	✓		
65	Jum'at, 24/02/2023	R-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
66	Jum'at, 24/02/2023	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓		
67	Jum'at, 24/02/2023	R-7	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓		
68	Jum'at, 24/02/2023	R-8	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓		
69		R-9	OVERHAUL														
70		R-10	OVERHAUL														

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
71	Jum'at, 10/03/2023	D20-08	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	MST tidak support FWL
72	Jum'at, 10/03/2023	R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
73	Kamis, 02/03/2023	V-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
74	Kamis, 02/03/2023	V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
75	Kamis, 02/03/2023	V-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
76	Kamis, 02/03/2023	V-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
77	Kamis, 02/03/2023	V-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
78	Senin, 06/03/2023	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
79	Senin, 06/03/2023	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
80	Jum'at, 27/02/2023	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
81	Jum'at, 27/02/2023	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
82	Jum'at, 27/02/2023	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
83	Jum'at, 27/02/2023	O-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
84	Jum'at, 27/02/2023	O-6	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	✓	
85	Jum'at, 27/02/2023	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	
86	Rabu, 22/02/2023	O-9	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
87	Rabu, 22/02/2023	O-10	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
88	Rabu, 22/02/2023	O-11	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
89	Rabu, 22/02/2023	O-12	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✓	✓	✓	
90	Rabu, 22/02/2023	O-13	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✓	✓	✓	
91	Rabu, 22/02/2023	O-14	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✗	✓	✓	Power Switch Rusak, menunggu penggantian PT. Pinaras
92	Rabu, 01/03/2023	D20-17	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	MST Rusak, Gak ada Spare
93	Rabu, 01/03/2023	D20-18	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
94	Rabu, 22/02/2023	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
95	Rabu, 22/02/2023	O-16	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	✓	
96	Rabu, 22/02/2023	O-17	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
97	Rabu, 22/02/2023	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
98	Jum'at, 17/03/2023	O-19	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	
99	Jum'at, 17/03/2023	O-20	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
100	Jum'at, 17/03/2023	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
101	Jum'at, 17/03/2023	O-22	✓	✓	✓	✓	✓	✓								WIKA
102	Jum'at, 17/03/2023	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
103	Jum'at, 17/03/2023	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
104		O-25	OVERHAUL													
105	Kamis, 15/03/2023	D20-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
106	Kamis, 15/03/2023	D20-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
107	Kamis, 15/03/2023	P-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
108	Kamis, 15/03/2023	P-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
109	Rabu, 01/03/2023	P-1	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
110	Rabu, 01/03/2023	P-2	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
111		P-3	TANK CLEANING MOD TANK													
112		P-4														
113	Kamis, 09/03/2023	P-5	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
114	Kamis, 09/03/2023	P-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
115	Kamis, 09/03/2023	P-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
116	Kamis, 09/03/2023	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
117	Jum'at, 03/03/2023	D-320-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
118	Jum'at, 03/03/2023	D-320-02A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
119	Jum'at, 03/03/2023	D-320-02B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
120	Kamis, 09/03/2023	C20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
121	Kamis, 09/03/2023	C20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Intermitten
122																
			0	1	0	0	1	1	2	28	34	43	63	0	0	

NOTE :

a. Pemasangan shroud cable :

A-24, A-25, E-1, E-2, E-3, E-4, E-5, E-6, E-7, T-201, T-202, V-1, V-2, R-4, D20-08, V-3, V-4, V-5, V-6, V-7, N-4

b. MST 020-17 akan ~~tidak~~ bisa diganti pasca. overhaul, karena MST tidak bisa dikeluarkan dari atas.

PT.Control Systems



Instrument MA4

