

Verifikasi ATG Pekerjaan TSA Preventive Maintenance Peralatan ATG Area UTL RU V BALIKPAPAN

Bulan: Dury 2024

No	Hari / tanggal	Tanki	Area	Level Liquid (mm)						Operator	
				Pengukuran			Koreksi			operator	
				ATG	Manual	Selisih	ATG	Manual	Selisih	Nama	Paraf
1	Fam. 13/6/20	U-10		7711	7701	-10				4	Nother
2	Kam, 13/6/24	U-11	Ę	7970	7920	0					
3	Kam, 13/6/29	U-12		6277	6267	-10					
4	Fan, 13/6/29	U-13		10 600	10.580	-90					
5		U-14									

NOTE:

* ATG = Automatic Tank Gauge

PT.CS

PUNY

MiMutad

MA-1

HADIO