


Monthly Report Pekerjaan TSA Preventive Maintenance Peralatan ATG Area OM, LAWE LAWE, DHP, BPP I dan UTL RU V BALIKPAPAN

Thursday, September 21, 2023

ATG PERFOMANCE







LIST ITEM	STATUS
Troubleshoot Kabel R-8 dan R-9	_
 Troubleshoot Tankhub P-8 dan O-22 	×
Troubleshoot Kabel MA4 Lama ke Loading	V
Troubleshoot ATG R-3 "Div Error"	1

KERUSAKAN SPARE PART

LIST ITEM	STATUS
 Display GWR U-11 dan U-10 (UTL). 	Rusak
MST D20-17 "Menunggu Overhaul".	Rusak
Spot 4 Temperature D20-05A Rusak	Rusak
• Sensor FWL A-4	Rusak



Total Resetting level Monthly



Assist re-Calibration ATG

N-2, N-4, A-6, TK-101-T1B, TK-101-T1D, TK-101-T1F, TK-101-T1G, R-5, R-7

Total Verifikasi : 107
Total On Call : 3
Total Kerusakan SparePart : 2
Total Assist re-Calibration ATG : 9

PT. Control Systems

Mengetahui, PT. Pertamina RU V Balikpapan

ALPAN 79-