

Check List Peralatan ATG Pekerjaan "TSA Preventive Maintenance Peralatan ATG Area DHP"

Periode Ke : Agustus 2014

			ATG Systems	8		Powe	Power Switch		Shroud Cable		Outerall	
NO Hari/Tanggal	Nama Tangki	Level	Interface	TankHub	wireless	Fungsional	Fungsional Shroud Cable	GWR	TankHub	MUHT	Status	Keterangan
1500/8/61, must	T-01A	1	<	1	Y	1	1	<	<	<	Good	√ Good
2 Summ 19/8/2014	T-01B	<	0	<	<	×.	<	<		<	Good	✓ Good
3	V-16	0	0	<		<		<			Bad	Bad Dalam proses pengadaan barang
4 Sunus 19/8/224	V-17	<	0	*		<	\ \ \ \ \	<			Good	Good
200 10/0 /2014	V-178	<	0	4		<		<			Good	

NOTE:

*** FWL = Free Water Level

RDU = Remote Display Unit

GWR = Guided Wave Radar

MST = Multi Spot Temperature RTG = Radar Tank Gauge

Instrument MA2

PT.Control Systems