


Monthly Report Pekerjaan TSA Preventive Maintenance Peralatan ATG Area OM, LAWE LAWE, DHP, BPP I dan UTL RU V BALIKPAPAN

Thursday, September 19, 2024

ATG PERFOMANCE



PROBLEM FOUND


LIST ITEM	STATUS
Pergantian wireless to wired ATG A33.	Fix
Troubleshoot MST E-04 "Diganti dengan MST O-19 lama."	Fix
● Troubleshoot MST A-20 "On Progress."	Hold

KERUSAKAN SPARE PART

LIST ITEM	STATUS
 Display GWR U-11 dan U-10 (UTL). 	Rusak
 MST D20-17 "Menunggu Overhaul". 	Rusak
GWR V-16 DHP "Menunggu modul"	Rusak
● GFD O-21, O-23 dan D20-11	Rusak



Total Resetting level Monthly



Assist re-Calibration ATG

Total Verifikasi : 107
Total On Call : 10
Total Kerusakan SparePart : 1

Total Assist re-Calibration ATG

PT. Control Systems

Mengetahui, PT. Pertamina RU V Balikpapan

M. 180001

T'