

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM "

Periode Ke : April 2024

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
1	Senin, 21 Maret 2024	A-1	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
2	Senin, 21 Maret 2024	A-2	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
3	Senin, 21 Maret 2024	A-3	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	Good	
4	Senin, 21 Maret 2024	A-4	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
5	Senin, 21 Maret 2024	A-5	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✗	Cleaning	
6	Senin, 21 Maret 2024	A-6												Overhaul	
7	Senin, 21 Maret 2024	A-7												Modtank	
8	Rabu, 23 Maret 2024	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
9	Rabu, 23 Maret 2024	A-16												Modtank	
10	Rabu, 23 Maret 2024	A-17												Overhaul	
11	Rabu, 23 Maret 2024	A-18	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✓	Cleaning	
12	Selasa, 19 April 2024	A-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
13	Rabu, 23 Maret 2024	A-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
14	Selasa, 19 April 2024	A-21												Overhaul	
15	Selasa, 23 Maret 2024	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
16	Selasa, 23 Maret 2024	A-23	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✗	Good	FWL Error
17	Selasa, 23 Maret 2024	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
18	Selasa, 23 Maret 2024	A-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
19	Selasa, 23 Maret 2024	A-26	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	Good	
20	Selasa, 23 Maret 2024	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
21	Jumat, 25 Maret 2024	A-28												Overhaul	
22	Jumat, 25 Maret 2024	A-29	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
23	Jumat, 25 Maret 2024	A-30												Modtank	
24	Jumat, 25 Maret 2024	A-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
25	Jumat, 25 Maret 2024	A-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	Good	
26	Jumat, 25 Maret 2024	A-33	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	Water level sensor not available
27	Selasa, 19 April 2024	E-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
28	Senin, 28 Maret 2024	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
29	Senin, 28 Maret 2024	E-3	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	Good with note	FWL Error
30	Selasa, 19 April 2024	E-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
31	Senin, 28 Maret 2024	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
32	Senin, 28 Maret 2024	E-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Cleaning	
33	Selasa, 19 April 2024	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
34	Selasa, 29 Maret 2024	T-901	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status			Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU			
35	Selasa, 29 Maret 2024	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	FWL Error	
36	Selasa, 29 Maret 2024	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good		
37	Selasa, 29 Maret 2024	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good		
38	Selasa, 29 Maret 2024	T-201	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	Good		
39	Selasa, 29 Maret 2024	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good		
40	Selasa, 29 Maret 2024	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	Overhaul	
41	Senin, 21 Maret 2024	V-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good		
42	Senin, 21 Maret 2024	V-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good		
43	Senin, 21 Maret 2024	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good		
44	Senin, 21 Maret 2024	D20-05B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good		
45	Senin, 21 Maret 2024	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	Modtank	
46	Senin, 21 Maret 2024	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good		
47	Senin, 21 Maret 2024	D20-06A												Modtank		
48	Senin, 21 Maret 2024	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good		
49	Senin, 21 Maret 2024	D20-07A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good		
50	Senin, 21 Maret 2024	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	Temp Spot 2, 3 dan 4 Error	
51	Senin, 21 Maret 2024	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good		
52	Kamis, 14 April 2024	D20-04A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good		
53	Senin, 28 Maret 2024	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good		
54	Senin, 28 Maret 2024	D20-04C	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good with note		
55	Senin, 28 Maret 2024	D20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	Cleaning	
56	Senin, 28 Maret 2024	D20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good		
57	Senin, 28 Maret 2024	D20-13A												Modtank		
58	Senin, 28 Maret 2024	D20-13B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good		
59	Kamis, 14 April 2024	D20-15A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good		
60	Senin, 28 Maret 2024	D20-15B	✓	✓	✓	✓	✗	✗	✓	✗	✗	✗	✗	Modtank	Modtank	
61	Selasa, 12 April 2024	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good		
62	Selasa, 12 April 2024	R-2												Modtank		
63	Selasa, 12 April 2024	R-3	✓	✓	✗	✓	✓	✓	✓	✓	✗	✗	✗	Good with note		
64	Selasa, 12 April 2024	R-4				✓								Overhaul		
65	Selasa, 12 April 2024	R-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good	Good	
66	Selasa, 12 April 2024	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	Good		
67	Selasa, 12 April 2024	R-7	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	Good		
68	Selasa, 12 April 2024	R-8	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good		
69	Selasa, 12 April 2024	R-9												Overhaul		
70	Selasa, 12 April 2024	R-10												Overhaul	Water level sensor not available	
71	Selasa, 12 April 2024	D20-08	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓	Good		
72	Kamis, 14 April 2024	R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good		

No	Harf/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
73	Kamis, 14 April 2024	V-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	Tanki tdk digunakan, ATG dimatikan
74	Kamis, 14 April 2024	V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
75	Kamis, 14 April 2024	V-5	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✗	Good	
76	Kamis, 14 April 2024	V-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
77	Kamis, 14 April 2024	V-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
78	Rabu, 6 April 2024	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
79	Rabu, 6 April 2024	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
80	Rabu, 6 April 2024	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Cleaning	
81	Rabu, 6 April 2024	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
82	Kamis, 7 April 2024	O-3	✓	✓	✗	✓	✓	✓	✓	✓	✓	✗	✗	Good	FWL Error
83	Kamis, 7 April 2024	O-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
84	Kamis, 7 April 2024	O-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
85	Kamis, 7 April 2024	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
86	Jum'at, 8 April 2024	O-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
87	Jum'at, 8 April 2024	O-10	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Overhaul	
88	Jum'at, 8 April 2024	O-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
89	Jum'at, 8 April 2024	O-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
90	Jum'at, 8 April 2024	O-13	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
91	Jum'at, 8 April 2024	O-14	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	Good with note MST Rusak, Gak ada Spare
92	Rabu, 6 April 2024	D20-17	✓	✗	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good with note	
93	Rabu, 6 April 2024	D20-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
94	Senin, 5 April 2024	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
95	Senin, 5 April 2024	O-16	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	Good	
96	Senin, 5 April 2024	O-17	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
97	Senin, 21 Maret 2024	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
98	Senin, 21 Maret 2024	O-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
99	Senin, 21 Maret 2024	O-20	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
100	Senin, 21 Maret 2024	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
101	Senin, 21 Maret 2024	O-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
102	Senin, 21 Maret 2024	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
103	Senin, 21 Maret 2024	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
104	Senin, 21 Maret 2024	O-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
105	Rabu, 6 April 2024	D20-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
106	Rabu, 6 April 2024	D20-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
107	Rabu, 6 April 2024	P-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
108	Rabu, 6 April 2024	P-32	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
109	Senin, 21 Maret 2024	P-1	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	Good	
110	Senin, 21 Maret 2024	P-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	

No	Hari/Tanggal	Nama Tangki	ATG Systems			Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
111	Senin, 12 April 2024	P-3	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓	Good
112	Senin, 21 Maret 2024	P-4	✓	✓		✓	✓	✓			✓	✓	✓	Good
113	Senin, 21 Maret 2024	P-5												Overhaul
114	Senin, 21 Maret 2024	P-7	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good
115	Senin, 21 Maret 2024	P-8	✓	✓	✓	✓	✓	✓		✓	✓	✓	✓	Good
116	Selasa, 19 April 2024	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
117	Selasa, 12 April 2024	D-320-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
118	Selasa, 12 April 2024	D-320-02A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
119	Selasa, 12 April 2024	D-320-02B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
120	Selasa, 12 April 2024	C20-01A	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓	Good
121	Selasa, 12 April 2024	C20-01B	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓	Good
122														

ATG Systems					Tank Master Status		Power Switch		Shroud Cable		
Level	Temp	FWL	RDU		Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU
0	2	5	0		4	4	0	16	8	39	53

NOTE :

PT Control Systems

Instrument MA4




*** FWL = Free Water Level
RDU = Remote Display Unit

MST = Multi Spot Temperature
RTG = Radar Tank Gauge