


Monthly Report Pekerjaan TSA Preventive Maintenance Peralatan ATG Area OM, LAWE LAWE, DHP, BPP I dan UTL RU V BALIKPAPAN

Friday, April 19, 2024

ATG PERFOMANCE






LIST ITEM	STATUS
Kurang Power FJB14 dan FJB 17 "Menunggu MCB dan orang listrik"	Hold
Troubleshoot temperatur ATG D20-04C "Menunggu tanki stanby, Perlu ganti card"	Hold
Pergantian THE R-3 "Div Error"	Fix
	and the same of

KERUSAKAN SPARE PART

LIST ITEM	STATUS
 Display GWR U-11 dan U-10 (UTL). 	Rusak
MST D20-17 "Menunggu Overhaul".	Rusak



Total Resetting level Monthly



Assist re-Calibration ATG

O-4, O-18, O-9, O-19, O-21, O-23, O-11, O-13, O-14, D320-2A, P-8, O-20, O-24, D320-2B, D320-12

Total Verifikasi : 93
Total On Call : 6
Total Kerusakan SparePart :
Total Assist re-Calibration ATG : 15

PT. Control Systems

Mengetahui, PT. Pertamina RU V Balikpapan

perono r.