

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM "

Periode ke : Agustus 2024

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan	
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU			
1	Senin, 21 juli 2024	A-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
2	Senin, 21 juli 2024	A-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
3	Senin, 21 juli 2024	A-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
4	Senin, 21 juli 2024	A-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
5	Senin, 21 juli 2024	A-5													Cleaning	
6	Senin, 21 juli 2024	A-6													Overhaul	
7	Senin, 21 juli 2024	A-7													Modtank	
8	Rabu, 23 juli 2024	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
9	Rabu, 23 juli 2024	A-16													Modtank	
10	Rabu, 23 juli 2024	A-17													Overhaul	
11	Rabu, 23 juli 2024	A-18													Overhaul	
12	Selasa, 19 agustus 2024	A-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
13	Rabu, 23 juli 2024	A-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
14	Selasa, 19 agustus 2024	A-21													Overhaul	
15	Selasa, 23 juli 2024	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
16	Selasa, 23 juli 2024	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
17	Selasa, 23 juli 2024	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
18	Selasa, 23 juli 2024	A-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
19	Selasa, 23 juli 2024	A-26	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
20	Selasa, 23 juli 2024	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
21	Jum'at, 25 juli 2024	A-28													Overhaul	
22	Jum'at, 25 juli 2024	A-29	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
23	Jum'at, 25 juli 2024	A-30													Modtank	
24	Jum'at, 25 juli 2024	A-31	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
25	Jum'at, 25 juli 2024	A-32	✓	✗	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	Good	
26	Jum'at, 25 juli 2024	A-33	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	Water level sensor tidak tersedia
27	Selasa, 19 agustus 2024	E-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
28	Senin, 28 juli 2024	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
29	Senin, 28 juli 2024	E-3													Overhaul	
30	Selasa, 19 agustus 2024	E-4	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good with note	Spot 2 Temperatur Rusak
31	Senin, 28 juli 2024	E-5	✓	✓		✓	✓	✓	✓	✓	✓	✓		✗	Good	
32	Senin, 28 juli 2024	E-6													Overhaul	
33	Selasa, 19 agustus 2024	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
34	Selasa, 29 juli 2024	T-901	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	

No	Hari/Tanggal	Nama Tangki	ATG Systems					Tank Master Status			Power Switch			Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU					
35	Selasa, 29 juli 2024	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
36	Selasa, 29 juli 2024	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
37	Selasa, 29 juli 2024	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
38	Selasa, 29 juli 2024	T-201	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good with note	FWL Rusak
39	Selasa, 29 juli 2024	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
40	Selasa, 29 juli 2024	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
41	Senin, 21 juli 2024	V-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
42	Senin, 21 juli 2024	V-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
43	Senin, 21 juli 2024	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
44	Senin, 21 juli 2024	D20-05B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
45	Senin, 21 juli 2024	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
46	Senin, 21 juli 2024	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	Good	
47	Senin, 21 juli 2024	D20-06A															Modtrank	
48	Senin, 21 juli 2024	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	Good	
49	Senin, 21 juli 2024	D20-07A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	Good	
50	Senin, 21 juli 2024	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
51	Senin, 21 juli 2024	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
52	Kamis, 14 agustus 2024	D20-04A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
53	Senin, 28 juli 2024	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
54	Senin, 28 juli 2024	D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
55	Senin, 28 juli 2024	D20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	Good	
56	Senin, 28 juli 2024	D20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	Good	
57	Senin, 28 juli 2024	D20-13A															Modtrank	
58	Senin, 28 juli 2024	D20-13B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	✓	Good	
59	Kamis, 14 agustus 2024	D20-15A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
60	Senin, 28 juli 2024	D20-15B															Modtrank	
61	Selasa, 12 agustus 2024	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗			✓	Good	
62	Selasa, 12 agustus 2024	R-2															Modtrank	
63	Selasa, 12 agustus 2024	R-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✓	✓	✓	Good with note	
64	Selasa, 12 agustus 2024	R-4															Overhaul	
65	Selasa, 12 agustus 2024	R-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	✓	Good	
66	Selasa, 12 agustus 2024	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	✓	Good	
67	Selasa, 12 agustus 2024	R-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	Good	
68	Selasa, 12 agustus 2024	R-8	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	✓	Good	
69	Selasa, 12 agustus 2024	R-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
70	Selasa, 12 agustus 2024	R-10							✓	✓	✓	✓	✓	✓	✓	✓	Good with note	Dalam proses instalasi
71	Selasa, 12 agustus 2024	D20-08	✓	✓		✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
72	Kamis, 14 agustus 2024	R-11							✓	✓	✓		✓	✓	✓	✓	Cleaning	Water level sensor tidak tersedia

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
73	Kamis, 14 agustus 2024	V-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
74	Kamis, 14 agustus 2024	V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
75	Kamis, 14 agustus 2024	V-5	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✗	Good	Tanki tdk digunakan, ATG dimatikan
76	Kamis, 14 agustus 2024	V-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
77	Kamis, 14 agustus 2024	V-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
78	Rabu, 6 agustus 2024	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
79	Rabu, 6 agustus 2024	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
80	Rabu, 6 agustus 2024	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Overhaul	
81	Rabu, 6 agustus 2024	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
82	Kamis, 7 agustus 2024	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
83	Kamis, 7 agustus 2024	O-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
84	Kamis, 7 agustus 2024	O-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
85	Kamis, 7 agustus 2024	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
86	Jum'at, 8 agustus 2024	O-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
87	Jum'at, 8 agustus 2024	O-10	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
88	Jum'at, 8 agustus 2024	O-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
89	Jum'at, 8 agustus 2024	O-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
90	Jum'at, 8 agustus 2024	O-13	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
91	Jum'at, 8 agustus 2024	O-14	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Overhaul	
92	Rabu, 6 agustus 2024	D20-17	✓	✗	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good with note	MST Rusak, Tidak bisa dilepas menunggu Overhaul
93	Rabu, 6 agustus 2024	D20-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Cleaning	
94	Senin, 5 agustus 2024	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
95	Senin, 5 agustus 2024	O-16	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Cleaning	
96	Senin, 5 agustus 2024	O-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
97	Senin, 21 juli 2024	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
98	Senin, 21 juli 2024	O-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
99	Senin, 21 juli 2024	O-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
100	Senin, 21 juli 2024	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
101	Senin, 21 juli 2024	O-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
102	Senin, 21 juli 2024	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
103	Senin, 21 juli 2024	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
104	Senin, 21 juli 2024	O-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
105	Rabu, 6 agustus 2024	D20-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
106	Rabu, 6 agustus 2024	D20-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
107	Rabu, 6 agustus 2024	P-31	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
108	Rabu, 6 agustus 2024	P-32	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
109	Senin, 21 juli 2024	P-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
110	Senin, 21 juli 2024	P-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	

No	Har/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
111	Senin, 12 agustus 2024	P-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
112	Senin, 21 juli 2024	P-4	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
113	Senin, 21 juli 2024	P-5												Overhaul	
114	Senin, 21 juli 2024	P-7	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
115	Senin, 21 juli 2024	P-8	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
116	Selasa, 19 agustus 2024	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
117	Selasa, 12 agustus 2024	D-320-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
118	Selasa, 12 agustus 2024	D-320-02A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
119	Selasa, 12 agustus 2024	D-320-02B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
120	Selasa, 12 agustus 2024	C20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
121	Selasa, 12 agustus 2024	C20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
122															

ATG Systems				Tank Master Status		Power Switch		Shroud Cable		
Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU
0	3	1	0	1	1	0	3	6	27	41


PT Control Systems

Instrument MA4

NOTE :

*** FWL = Free Water Level
RDU = Remote Display Unit

MST = Multi Spot Temperature
RTG = Radar Tank Gauge




ACFAN