



Control Systems

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area UTL "

Periode Ke : Februari 2023

No	Hari/Tanggal	Nama Tangki	ATG Systems		HMI Status	Power Switch		Shroud Cable			Grounding			Keterangan
			Level	RDU		Fungsional	Shroud Cable	GWR	RDU	THUM	GWR	RDU	THUM	
1		U-10	✓	✓				✓	✓		✗	✗		Display GWR Mati
2		U-11	✓	✓				✓	✓		✗	✗		Display GWR Mati
3		U-12	✓					✓			✗			
4		U-13	✓		✓			✓		✓	✗		✓	
5		U-14	✓	✓	✓			✓	✓	✓	✓	✓	✓	

NOTE :

PT. Control Systems

Instrument MA1




mustafa