G

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area UTL "

Control Systems												Periode Ke : JUN 1017		
No		Nama Tangki	ATG Systems		HMI Status	Power Switch		Shroud Cable			Grounding			Keterangan
			Level	RDU	HIVII Status	Fungsional	Shroud Cable	GWR	RDU	THUM	GWR	RDU	THUM	Keterangan
1	Daby (14/6/25	U-10	✓	1				√.	· V		1	V		Display GWR Mati
2	Robin 19/6/29	U-11	1	1				1	1		1	1		Display GWR Mati
3	Chlara 13/6/23	U-12	1					V			V			
4	Salara, 13/6/23	U-13	1		V			1		~	~		✓	
5	Clara 13/6/23	U-14	1	1	V			1	1	1	1	1	1	

NOTE:

PT.Control Systems

Instrument MA1