

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM "

Periode Ke : Oktober 2024

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
1	Senin, 21 September 2024	A-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
2	Senin, 21 September 2024	A-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
3	Senin, 21 September 2024	A-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
4	Senin, 21 September 2024	A-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
5	Senin, 21 September 2024	A-5												Cleaning	
6	Senin, 21 September 2024	A-6												Overhaul	
7	Senin, 21 September 2024	A-7												Modtank	
8	Rabu, 23 September 2024	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
9	Rabu, 23 September 2024	A-16												Modtank	
10	Rabu, 23 September 2024	A-17												Overhaul	
11	Rabu, 23 September 2024	A-18												Overhaul	
12	Selasa, 19 Oktober 2024	A-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
13	Rabu, 23 September 2024	A-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
14	Selasa, 19 Oktober 2024	A-21												Overhaul	
15	Selasa, 23 September 2024	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
16	Selasa, 23 September 2024	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
17	Selasa, 23 September 2024	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
18	Selasa, 23 September 2024	A-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
19	Selasa, 23 September 2024	A-26	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
20	Selasa, 23 September 2024	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
21	Jum'at, 25 September 2024	A-28												Overhaul	
22	Jum'at, 25 September 2024	A-29	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
23	Jum'at, 25 September 2024	A-30												Modtank	
24	Jum'at, 25 September 2024	A-31	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
25	Jum'at, 25 September 2024	A-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	Good	
26	Jum'at, 25 September 2024	A-33	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	Water level sensor tidak tersedia
27	Selasa, 19 Oktober 2024	E-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
28	Senin, 28 September 2024	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
29	Senin, 28 September 2024	E-3												Overhaul	
30	Selasa, 19 Oktober 2024	E-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
31	Senin, 28 September 2024	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
32	Senin, 28 September 2024	E-6												Overhaul	
33	Selasa, 19 Oktober 2024	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
34	Selasa, 29 September 2024	T-801	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	

No	Hari/Tanggal	Nama Tangki	ATG Systems			Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Functional	Shroud Cable	RTG	MST	RDU	
35	Selasa, 29 September 2024	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
36	Selasa, 29 September 2024	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
37	Selasa, 29 September 2024	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
38	Selasa, 29 September 2024	T-201	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	Good with note
39	Selasa, 29 September 2024	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good
40	Selasa, 29 September 2024	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
41	Senin, 21 September 2024	V-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
42	Senin, 21 September 2024	V-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
43	Senin, 21 September 2024	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good
44	Senin, 21 September 2024	D20-05B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good
45	Senin, 21 September 2024	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good
46	Senin, 21 September 2024	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good
47	Senin, 21 September 2024	D20-06A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Modtank
48	Senin, 21 September 2024	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good
49	Senin, 21 September 2024	D20-07A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good
50	Senin, 21 September 2024	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
51	Senin, 21 September 2024	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
52	Kamis, 14 Oktober 2024	D20-04A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
53	Senin, 28 September 2024	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
54	Senin, 28 September 2024	D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
55	Senin, 28 September 2024	D20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good
56	Senin, 28 September 2024	D20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good
57	Senin, 28 September 2024	D20-13A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Modtank
58	Senin, 28 September 2024	D20-13B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good
59	Kamis, 14 Oktober 2024	D20-15A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
60	Senin, 28 September 2024	D20-15B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Modtank
61	Selasa, 12 Oktober 2024	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good
62	Selasa, 12 Oktober 2024	R-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Modtank
63	Selasa, 12 Oktober 2024	R-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	Good
64	Selasa, 12 Oktober 2024	R-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Overhaul
65	Selasa, 12 Oktober 2024	R-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good
66	Selasa, 12 Oktober 2024	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	Good
67	Selasa, 12 Oktober 2024	R-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good
68	Selasa, 12 Oktober 2024	R-8	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Good
69	Selasa, 12 Oktober 2024	R-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
70	Selasa, 12 Oktober 2024	R-10	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
71	Selasa, 12 Oktober 2024	D20-08	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good
72	Kamis, 14 Oktober 2024	R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Overhaul

Water level sensor tidak tersedia

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Functional	Shroud Cable	RTG	MST	RDU		
73	Kamis, 14 Oktober 2024	V-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
74	Kamis, 14 Oktober 2024	V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
75	Kamis, 14 Oktober 2024	V-5	✓	✓	✓	✓	✗	✗	✓	✓	✓	✓	✗	Good	Tanki tak digunakan, ATG dimatikan
76	Kamis, 14 Oktober 2024	V-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
77	Kamis, 14 Oktober 2024	V-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
78	Rabu, 6 Oktober 2024	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
79	Rabu, 6 Oktober 2024	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
80	Rabu, 6 Oktober 2024	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Overhaul	
81	Rabu, 6 Oktober 2024	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
82	Kamis, 7 Oktober 2024	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
83	Kamis, 7 Oktober 2024	O-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
84	Kamis, 7 Oktober 2024	O-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
85	Kamis, 7 Oktober 2024	O-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
86	Jumat, 8 Oktober 2024	O-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Good	
87	Jumat, 8 Oktober 2024	O-10	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
88	Jumat, 8 Oktober 2024	O-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
89	Jumat, 8 Oktober 2024	O-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
90	Jumat, 8 Oktober 2024	O-13	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
91	Jumat, 8 Oktober 2024	O-14	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Overhaul	
92	Rabu, 6 Oktober 2024	D20-17	✓	✗	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good with tank	MST Rusak, Tank bisa dilepas menunggu Overhaul
93	Rabu, 6 Oktober 2024	D20-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Cleaning	
94	Senin, 5 Oktober 2024	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
95	Senin, 5 Oktober 2024	O-16	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Cleaning	
96	Senin, 5 Oktober 2024	O-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
97	Senin, 21 September 2024	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
98	Senin, 21 September 2024	O-19	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	Good	
99	Senin, 21 September 2024	O-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Good	
100	Senin, 21 September 2024	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
101	Senin, 21 September 2024	O-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
102	Senin, 21 September 2024	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
103	Senin, 21 September 2024	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
104	Senin, 21 September 2024	O-25	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
105	Rabu, 6 Oktober 2024	D20-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
106	Rabu, 6 Oktober 2024	D20-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
107	Rabu, 6 Oktober 2024	P-31	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
108	Rabu, 6 Oktober 2024	P-32	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
109	Senin, 21 September 2024	P-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
110	Senin, 21 September 2024	P-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Overall Status	Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU		
111	Senin, 12 Oktober 2024	P-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
112	Senin, 21 September 2024	P-4	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
113	Senin, 21 September 2024	P-5												Overhaul	
114	Senin, 21 September 2024	P-7	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
115	Senin, 21 September 2024	P-8	✓	✓	✓	✓	✓	✓			✓	✓	✓	Good	
116	Selasa, 19 Oktober 2024	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
117	Selasa, 12 Oktober 2024	D-320-12	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
118	Selasa, 12 Oktober 2024	D-320-02A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
119	Selasa, 12 Oktober 2024	D-320-02B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
120	Selasa, 12 Oktober 2024	C20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
121	Selasa, 12 Oktober 2024	C20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	Good	
122															

ATG Systems				Tank Master Status		Power Switch		Shroud Cable		
Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU
0	1	1	0	1	1	0	3	6	27	41

NOTE :

PT. Centric Systems

Instrument MA4

*** FWL = Free Water Level
RDU = Remote Display Unit

MST = Multi Spot Temperature
RTG = Radar Tank Gauge



