

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM, Lawe-lawe, dan DHP

Periode Ke : Des - Jan 2022

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
1	Selasa, 21-12-2021	A-1	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
2	Selasa, 21-12-2021	A-2	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
3	Selasa, 21-12-2021	A-3	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗	✓	✓	
4	Selasa, 21-12-2021	A-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
5	Selasa, 21-12-2021	A-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
6	Selasa, 21-12-2021	A-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
7	Selasa, 21-12-2021	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
8	Selasa, 21-12-2021	A-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
9	Selasa, 21-12-2021	A-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
10	Selasa, 21-12-2021	A-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
11	Selasa, 21-12-2021	A-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
12	Selasa, 21-12-2021	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
13	Selasa, 21-12-2021	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
14	Selasa, 21-12-2021	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	✓	
15		A-25														
16	Kamis, 30-12-2021	A-26	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗	✓	✓	
17	Kamis, 30-12-2021	A-27	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
18	Kamis, 30-12-2021	A-28	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
19	Kamis, 30-12-2021	A-30	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
20	Kamis, 30-12-2021	A-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
21	Kamis, 30-12-2021	A-32	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	✓	
22	Kamis, 30-12-2021	A-33	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
23	Kamis, 16-12-2021	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
24	Kamis, 16-12-2021	E-3	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	FWL Error, Gland kabel jelek, kemasukan Air
25	Kamis, 16-12-2021	E-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
26	Kamis, 16-12-2021	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
27	Kamis, 16-12-2021	E-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
28	Kamis, 16-12-2021	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
29		T-901														
30	Kamis, 16-12-2021	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
31	Kamis, 16-12-2021	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
32	Kamis, 16-12-2021	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	

TANK CLEANING

TANK CLEANING

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
33	Kamis, 16-12-2021	T-201	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
34	Kamis, 16-12-2021	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
35	Kamis, 16-12-2021	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
36	Kamis, 06-01-2022	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
37	Kamis, 06-01-2022	D20-05B	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	✓	✓	
38	Kamis, 06-01-2022	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	Intermitten
39	Kamis, 06-01-2022	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
40	Kamis, 06-01-2022	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
41	Kamis, 06-01-2022	D20-07A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
42	Kamis, 06-01-2022	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
43	Kamis, 06-01-2022	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
44	Kamis, 06-01-2022	D20-04A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
45	Kamis, 06-01-2022	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
46	Kamis, 06-01-2022	D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
47	Kamis, 06-01-2022	D20-01A	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✗	✓	✓	
48		D20-01B														Tankhub not support FWL
49	Rabu, 05-12-2021	D20-08	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
50	Rabu, 05-12-2021	D20-13A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
51	Rabu, 05-12-2021	D20-13B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
52		D20-15A														MODIFIKASI TANKI RDMP
53	Rabu, 05-12-2021	D20-15B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	✓	✓	
54	Jumat, 17-12-2021	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
55	Jumat, 17-12-2021	R-2	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
56	Jumat, 17-12-2021	R-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
57	Jumat, 17-12-2021	R-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
58	Jumat, 17-12-2021	R-5	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
59	Jumat, 17-12-2021	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
60	Jumat, 17-12-2021	R-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
61	Jumat, 17-12-2021	R-8	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✓	✓	
62	Jumat, 17-12-2021	R-9	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	✓	
63	Jumat, 17-12-2021	R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✓	
64		V-4														TANK CLEANING
65		V-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
66	Kamis, 22-12-2021	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
67	Kamis, 22-12-2021	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
68	Kamis, 22-12-2021	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	
69	Kamis, 22-12-2021	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	MST	
70	Jum'at, 17-12-2021	O-3	✓	✓	✓	✓	✓	✓	✓	✓	X	X	X	✓	✓	
71	Jum'at, 17-12-2021	O-4	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	✓	✓	
72	Jum'at, 17-12-2021	O-6	✓	✓	✓	✓	✓	✓	✓	X	✓	X	✓	✓	✓	
73	Jum'at, 17-12-2021	O-8	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	✓	✓	
74	Jum'at, 17-12-2021	O-9	✓	✓	✓	✓	✓	✓	✓	✓	X	X	X	✓	✓	
75	Jum'at, 17-12-2021	O-10	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	✓	✓	
76	Jum'at, 17-12-2021	O-11	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	✓	✓	
77	Jum'at, 17-12-2021	O-12	✓	✓	✓	✓	✓	✓	✓	X	✓	✓	✓	✓	✓	
78	Jum'at, 17-12-2021	O-13	✓	✓	✓	✓	✓	✓	✓	X	✓	✓	✓	✓	✓	
79	Jum'at, 17-12-2021	O-14	✓	✓	✓	✓	✓	✓	X	X	X	X	X	✓	✓	
80	Jum'at, 07-01-2022	D20-17	✓	X	X	✓	✓	✓	✓	✓	✓	✓	X	✓	✓	MST Rusak, Mainhole MST keil
81	Jum'at, 07-01-2022	D20-18	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	✓	✓	
82	Senin, 20-12-2021	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	✓	
83	Senin, 20-12-2021	O-16	✓	✓	✓	✓	✓	✓	✓	X	X	X	✓	✓	✓	
84	Senin, 20-12-2021	O-17	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	✓	✓	
85	Senin, 20-12-2021	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
86	Senin, 20-12-2021	O-19	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	✓	✓	
87	Senin, 20-12-2021	O-20	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	✓	✓	
88	Senin, 20-12-2021	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
89	Senin, 20-12-2021	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
90	Senin, 20-12-2021	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
91		O-25														
92		D20-11														
93		D20-12														
94	Rabu, 12-01-2022	P-31	✓	✓	✓	✓	✓	✓	✓	X	✓	X	X	✓	✓	
95	Rabu, 12-01-2022	P-32	✓	✓	✓	✓	✓	✓	✓	✓	X	X	X	✓	✓	
96	Rabu, 12-01-2022	P-1	✓	✓	✓	✓	✓	✓	✓	X	✓	X	X	✓	✓	
97	Rabu, 12-01-2022	P-2	✓	✓	✓	✓	✓	✓	✓	✓	X	X	X	✓	✓	
98		P-3														
99	Rabu, 12-01-2022	P-5	✓	✓	✓	✓	✓	✓	✓	✓	X	X	X	✓	✓	
100	Rabu, 12-01-2022	P-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
101	Rabu, 12-01-2022	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	X	X	X	✓	✓	
102		TK-101-T1A														
103	Senin, 03-01-2022	TK-101-T1B	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	✓	
104	Senin, 03-01-2022	TK-101-T1C	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	✓	
105	Senin, 03-01-2022	TK-101-T1D	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	✓	
106	Senin, 03-01-2022	TK-101-T1E	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	✓	

TANK CLEANING

MODIFIKASI TANKI RDMP

MODIFIKASI TANKI RDMP

Spot 2 and 4 Temp broken

MODIFIKASI TANKI RDMP

TANK CLEANING

No	Hari/Tanggal	Nama Tangki	ATG Systems			Tank Master Status		Power Switch		Shroud Cable			Ground		Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	RTG	
107	Senin, 03-01-2022	TK-101-T1F	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
108	Senin, 03-01-2022	TK-101-T1G	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	

NOTE : Agenda Troubleshoot Bulan Depan


DHP												
NO	Hari/Tanggal	Nama Tangki	ATG Systems			Komunikasi wireless	Power Switch		Shroud Cable		Ground	Keterangan
			Level	Interface	TankHub		Fungsional	Shroud Cable	GW/R	TankHub		
1	Senin, 04-01-2022	T-01A	✓				✓		✓		✓	
2	Senin, 04-01-2022	T-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	

NOTE :

PT Control Systems


M. Harko

Intrument MA2


M. Asmi D.

Intrument MA4


ALFAN
-R-