



## Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM, Lawe-lawe, dan DHP

Oil Movement

Periode Ke :

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
1	Kan. 7. 12. 20	A-1	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
2	Pnb. 2. 12. 20	A-2	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
3	Kan. 19. 11. 20	A-3	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
4	Sla. 17. 11. 20	A-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
5	Sla. 17. 11. 20	A-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
6	Kan. 19. 11. 20	A-6	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
7	Sun. 10. 12. 20	A-15	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
8	Kan. 3. 12. 20	A-17	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
9	Sun. 16. 11. 20	A-21	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
10	Kan. 9. 11. 20	A-22	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
11	Sun. 16. 11. 20	A-23	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
12	Sun. 16. 11. 20	A-24	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
13	Sun. 16. 11. 20	A-25	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
14	Sun. 16. 11. 20	A-26	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
15	Sun. 16. 11. 20	A-27	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
16	Sun. 16. 11. 20	A-28	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
17		A-29	MODIFIKASI RDNMP											
18	Kan. 19. 11. 20	A-30	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
19	Kan. 19. 11. 20	A-31	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
20	Kan. 19. 11. 20	A-32	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
21		A-33	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
22	Sla. 17. 11. 20	E-3	✓	✓	Error.		✓	✓	✓	✗	✗	✗	✗	
23	Sla. 17. 11. 20	E-4	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
24	Kan. 19. 11. 20	E-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
25	Sla. 17. 11. 20	E-6	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
26	Sla. 17. 11. 20	E-7	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
27	Sun. 14. 11. 20	T-901	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
28	Kan. 19. 11. 20	T-902	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
29	Kan. 19. 11. 20	T-903	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
30	Kan. 19. 11. 20	T-904	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
31	Sla. 17. 11. 20	T-201	✓	✓	Error.		✓	✓	✓	✗	✗	✗	✗	
32	Sla. 17. 11. 20	T-202	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
33	Sla. 19. 11. 20	T-203	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	



No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
34	Sun. 1. 09. 11. 00	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
35	Sun. 2. 09. 11. 00	D20-05B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
36	Sun. 1. 12. 00	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
37	Sun. 2. 12. 00	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
38	Sun. 1. 12. 00	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
39	Sun. 2. 11. 00	D20-07A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
40	Sun. 3. 12. 00	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
41	Sun. 1. 12. 00	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
42	Sun. 1. 12. 00	D20-04A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
43	Sun. 2. 12. 00	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
44	Sun. 1. 12. 00	D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
45	Sun. 1. 12. 00	D20-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
46	Sun. 1. 12. 00	D20-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
47	Sun. 4. 12. 00	D20-08	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
48	Sun. 1. 11. 00	D20-13A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
49	Sun. 1. 11. 00	D20-13B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
50	Sun. 1. 11. 00	D20-15A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
51	Sun. 1. 11. 00	D20-15B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
52	Sun. 1. 12. 00	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
53	Sun. 1. 12. 00	R-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
54	Sun. 2. 11. 00	R-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
55	Sun. 2. 11. 00	R-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
56	Sun. 3. 11. 00	R-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
57	Sun. 1. 12. 00	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
58	Sun. 2. 11. 00	R-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
59	Sun. 2. 11. 00	R-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
60	Sun. 3. 12. 00	R-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
61		R-10	TANK CLEANING											
62	Sun. 2. 12. 00	R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
63	Sun. 2. 12. 00	V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
64		V-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
65	Sun. 1. 12. 00	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
66	Sun. 1. 12. 00	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
67	Sun. 1. 12. 00	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
68	Sun. 3. 12. 00	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
69	Sun. 1. 12. 00	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
70		O-4	TANK CLEANING											



No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
71	Pabu. 18.11.20	0-6	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✓	
72	Sumu. 16.11.20	0-8	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	
73	Pabu. 18.11.20	0-9	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	
74	Pabu. 18.11.20	0-10	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗	
75		0-11	✓	✓	✓	✓	✓	✓	✓					
76	Sumu. 30.11.20	0-12	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✓	Intermitter.
77	Sumu. 30.11.20	0-13	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	
78	Pabu. 18.11.20	0-14	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	
79	Sum. 3.12.20	D20-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
80	Sum 4.12.20	D20-18	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	
81	Pabu. 18.11.20	0-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	Temp. Rusak, ATG wiring.
82	Sumu. 30.11.20	0-16	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✓	
83	Selum. 15.12.20	0-17	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
84	Pabu. 18.11.20	0-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
85	Sumu. 30.11.20	0-19	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✓	
86	Sumu. 30.11.20	0-20	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
87	Pabu. 18.11.20	0-21	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
88		0-22	MODIFIKASI				CPAIL	RDMP						
89	Pabu 18.11.20.	0-23	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
90	Sum. 30.11.20	0-24	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	
91	Sum 30.11.20	0-25	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
92	Sum. 19.11.20	D20-11	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
93	Sum. 30.11.20	D20-12	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
94	Sum 30.11.20	P-31	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	
95	Sum 30.11.20	P-32	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	
96	Sum 30.11.20	P-1	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	
97	Sum 30.11.20	P-2	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	
98	Sum 30.11.20	P-3	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
99		P-4	✓	✓	✓	✓	✓	✓	✓				✗	
100	Selum. 15.12.20	P-5	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	
101	Sum. 30.11.20	P-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	TANK CLEANING
102	Sum. 3.12.20	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
103	Sum. 3.12.20	TK-101-T1A												
104	Sum 3.12.20	TK-101-T1B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
105	Sum 3.12.20	TK-101-T1C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
106	Sum. 3.12.20	TK-101-T1D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
107	Sum 3.12.20	TK-101-T1E	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
108	Sm. 7. 12. 20	TK-101-T1F	✓	✓	✓	✓	✓	✓						
109	Sm. 8. 12. 20	TK-101-T1G	✓	✓	✓	✓	✓	✓						

DHP

NO	Hari/Tanggal	Nama Tangki	ATG Systems			Power Switch		Shroud Cable		Keterangan	
			Level	Interface	TankHub	Komunikasi wireless	Fungsional	Shroud Cable	GWR		TankHub
1	Sm. 12. 12. 20	T-01A	✓	✓	✓	✓	✓	✓	✓	✓	
2	Sm. 13. 12. 20	T-01B	✓	✓	✓	✓	✓	✓	✓	✓	


NOTE :

FJB 14 intermiten.

PT. Control Systems

Instrument MA2

Instrument MA4

  
M. Haidi

  
M. Haidi

M. Haidi T.