

Check List Peralatan ATG Pekerjaan " TSA Preventive Maintenance Peralatan ATG Area OM, Lawe-lawe, dan DHP

Oil Movement

Periode ke : April - Mei 2021

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
1	Rabu, 21/04/2021	A-1	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗		
2	Kamis, 22/04/2021	A-2	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗		
3	Kamis, 22/04/2021	A-3	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗		
4	Kamis, 22/04/2021	A-4	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗		
5	Rabu, 21/04/2021	A-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗		
6	Rabu, 21/04/2021	A-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗		
7	Jumat, 30/04/2021	A-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
8	Kamis, 22/04/2021	A-17	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
9	Kamis, 22/04/2021	A-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
10	Kamis, 22/04/2021	A-20	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
11	Jumat, 30/04/2021	A-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
12	Rabu, 21/04/2021	A-22	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗		
13	Rabu, 21/04/2021	A-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗		
14	Rabu, 21/04/2021	A-24	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓		
15		A-25	OVERHALL											
16	Rabu, 21/04/2021	A-26	✓	✓	✓	✓	✓	✓	✗	✗	✓	✗		
17	Rabu, 21/04/2021	A-27	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗		
18	Rabu, 21/04/2021	A-28	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗		
19	Jumat, 30/04/2021	A-30	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
20	Selasa, 11/05/2021	A-31	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗		
21	Selasa, 11/05/2021	A-32	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗		
22	Jumat, 30/04/2021	A-33	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗		
23	Jumat, 16/04/2021	E-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
24	Jumat, 16/04/2021	E-3	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
25	Jumat, 16/04/2021	E-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗		
26	Jumat, 16/04/2021	E-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗		
27	Jumat, 16/04/2021	E-6	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗		
28	Jumat, 16/04/2021	E-7	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
29		T-901	OVERHALL											
30	Kamis, 22/04/2021	T-902	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
31	Kamis, 22/04/2021	T-903	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
32	Kamis, 22/04/2021	T-904	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
33	Selasa, 11/05/2021	T-201	✓	✓	✗	✓	✓	✓	✓	✓	✓	✗	FWL Error	

OVERHAUL

OVERHAUL

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
34	Jumat, 30/04/2021	T-202	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
35	Jumat, 30/04/2021	T-203	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
36	Selasa, 11/05/2021	D20-05A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
37	Rabu, 06/05/2021	D20-05B	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✗	
38	Kamis, 07/05/2021	D20-05C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
39	Selasa, 11/05/2021	D20-05D	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	
40	Selasa, 11/05/2021	D20-06B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	
41	Rabu, 05/05/2021	D20-07A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	Intermitten
42	Rabu, 05/05/2021	D20-07B	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	Intermitten
43	Rabu, 05/05/2021	D20-07C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	
44	Selasa, 11/05/2021	D20-04A	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
45	Selasa, 11/05/2021	D20-04B	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
46	Selasa, 11/05/2021	D20-04C	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
47	Selasa, 11/05/2021	D20-01A	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	✗	
48		D20-01B												
49	Senin, 10/05/2021	D20-08	✓	✓	✗	✓	✗	✗	✓	✓	✓	✓	✓	Communication still not connected, cause voltage leak
50	Rabu, 28/04/2021	D20-13A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
51	Rabu, 28/04/2021	D20-13B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
52	Rabu, 28/04/2021	D20-15A	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
53	Rabu, 28/04/2021	D20-15B	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
54	Rabu, 06/05/2021	R-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	
55	Rabu, 28/04/2021	R-2	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	
56	Rabu, 28/04/2021	R-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	
57	Selasa, 27/04/2021	R-4	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	
58	Rabu, 28/04/2021	R-5	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
59	Senin, 26/04/2021	R-6	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	
60	Selasa, 27/04/2021	R-7	✓	✓	✓	✓	✓	✓	✓	✗	✓	✗	✗	
61	Senin, 26/04/2021	R-8	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	✗	
62	Senin, 26/04/2021	R-9	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
63	Selasa, 11/05/2021	R-11	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	
64	Senin, 10/05/2021	V-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	Intermitten
65	Selasa, 11/05/2021	V-5	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
66	Jumat, 23/04/2021	N-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
67	Jumat, 23/04/2021	N-4	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
68	Jumat, 23/04/2021	O-1	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
69	Jumat, 23/04/2021	O-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	
70	Selasa, 11/05/2021	O-3	✓	✓	✓	✓	✓	✓	✓	✓	✗	✗	✗	

OVERHAUL

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	MST	RDU	
71	Selasa, 27/04/2021	O-4	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	
72	Rabu, 28/04/2021	O-6	✓	✓	✓	✓	✓	✓	✓	X	✓	X	✓	
73	Rabu, 28/04/2021	O-8	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	ATG often restart by itself
74	Jumat, 23/04/2021	O-9	✓	✓	✓	✓	✓	✓	✓	✓	X	✓	X	
75	Jumat, 23/04/2021	O-10	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	
76	Jumat, 23/04/2021	O-11	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	
77	Senin, 10/05/2021	O-12	✓	✓	✓	✓	✓	✓	✓	X	✓	✓	✓	
78	Jumat, 23/04/2021	O-13	✓	✓	✓	✓	✓	✓	✓	X	✓	✓	✓	Intermitten
79	Jumat, 23/04/2021	O-14	✓	✓	✓	✓	✓	✓	X	X	X	X	X	
80	Senin, 10/05/2021	D20-17	✓	X	✓	✓	✓	✓	✓	✓	✓	✓	X	Intermitten
81	Jumat, 07/05/2021	D20-18	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	
82	Selasa, 27/04/2021	O-15	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	
83	Senin, 26/04/2021	O-16	✓	✓	✓	✓	✓	✓	✓	X	X	X	✓	
84	Selasa, 11/05/2021	O-17	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	
85	Selasa, 11/05/2021	O-18	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
86	Selasa, 27/04/2021	O-19	✓	✓	✓	✓	✓	✓	✓	✓	X	X	✓	
87	Selasa, 27/04/2021	O-20	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	
88	Senin, 26/04/2021	O-21	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
89	Senin, 26/04/2021	O-23	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
90	Kamis, 07/05/2021	O-24	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
91		O-25	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	
92	Kamis, 07/05/2021	D20-11	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	
93		D20-12												Spot 2 and 4 Temp broken
94	Senin, 26/04/2021	P-31	✓	✓	✓	✓	✓	✓	✓	X	✓	X	X	
95	Senin, 26/04/2021	P-32	✓	✓	✓	✓	✓	✓	✓	✓	X	X	X	
96	Senin, 26/04/2021	P-1	✓	✓	✓	✓	✓	✓	✓	X	✓	X	X	
97	Rabu, 28/04/2021	P-2	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
98	Rabu, 28/04/2021	P-3	✓	✓	✓	✓	✓	✓	✓	X	X	X	X	
99	Rabu, 28/04/2021	P-5	✓	✓	✓	✓	✓	✓	✓	✓	X	X	X	Intermitten
100	Jumat, 07/05/2021	P-8	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	
101	Jumat, 07/05/2021	D20-03	✓	✓	✓	✓	✓	✓	✓	✓	X	X	X	Intermitten
102	Senin, 5/4/2021	TK-101-T1A												
103	Senin, 10/05/2021	TK-101-T1B	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	
104	Senin, 10/05/2021	TK-101-T1C	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	
105	Senin, 10/05/2021	TK-101-T1D	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	
106	Senin, 10/05/2021	TK-101-T1E	✓	✓	✓	✓	✓	✓	✓	✓	✓	X	X	
107	Senin, 10/05/2021	TK-101-T1F	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	

OVERHAUL

TANK CLEANING

No	Hari/Tanggal	Nama Tangki	ATG Systems				Tank Master Status		Power Switch		Shroud Cable			Keterangan
			Level	Temp	FWL	RDU	Tank Master	Intranet	Fungsional	Shroud Cable	RTG	M/ST	RDU	
108	Senin, 10/05/2021	TK-101-T1G	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		


DHP												Keterangan
NO	Hari/Tanggal	Nama Tangki	ATG Systems			Komunikasi wireless	Power Switch		Shroud Cable			
			Level	Interface	TankHub		Fungsional	Shroud Cable	GWR	TankHub	THUMB	
1	Senin, 10/05/2021	T-01A	✓	✓	✓	✓	✓	✓	✓	✓	✓	
2	Senin, 10/05/2021	T-01B	✓	✓	✓	✓	✓	✓	✓	✓	✓	


NOTE :


PT Control Systems

Instrument MA2

Instrument MA4




M. FADHIL RAHMAD.


M. FADHIL RAHMAD.